



YOLO COUNTY

Department of Community Services

Environmental Health Division

292 W. Beamer Street, Woodland CA 95695

Phone: (530) 666-8646 Fax: (530) 669-1448

WATER WELL MINIMUM SETBACK DISTANCE

Site Feature	Minimum Setback Distance (feet)	
	Domestic/AG Wells	Public or Community Wells
Animal or fowl enclosure	100	100
Hazardous materials storage	100	100
Watertight septic tank	50	150
Subsurface sewage leach field	100	150
Cesspool or seepage pit	150	150
Public road right-of-way	*See note	100 *See note
Any Sewer line (sanitary, industrial, or storm; main or lateral)	50	150

*Contact Yolo County Public Works (ph. 530-666-8775) to confirm whether an encroachment permit is required.