Quarterly Report for Disinfectant Residuals Compliance For Systems Using Chlorine or Chloramines

System Name: **WILD WINGS** System No.: **5710011**

Calendar Year: **2017** Quarter: **3**

1st Quarter

	Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
Previous Year	April		1.00
	May		1.10
	June		0.90
	July		1.00
	August		1.00
	September		1.10
	October		1.00
	November		1.00
	December		1.00
Current Year	January	2	1.15
	February	2	1.15
	March	2	1.35
Running Annual Average (RAA):			1.06
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl_2)			☑ Yes ☐ No

2nd Quarter

	Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
Previous Year	July		1.00
	August		1.00
	September		1.10
	October		1.00
	November		1.00
	December		1.00
Current Year	January		1.15
	February		1.15
	March		1.35
	April	2	1.10
	May	2	1.25
	June	0	1.27
Running Annual Average (RAA):			1.11
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl_2)			☑ Yes ☐ No

3rd Quarter

	Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
Previous Yr	October		1.00
	November		1.00
	December		1.00
Current Year	January		1.15
	February		1.15
	March		1.35
	April		1.10
	May		1.25
	June		1.27
	July	10	1.10
	August	2	1.05
	September	2	1.00
Running Annual Average (RAA):			1.12
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl_2)			☑ Yes ☐ No

4th Quarter

	Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
Current Year	January		1.15
	February		1.15
	March		1.35
	April		1.10
	May		1.25
	June		1.27
	July		1.10
	August		1.05
	September		1.00
	October		0.80
	November		0.80
	December		1.80
Running Annual Average (RAA):			1.15
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl_2)			☑ Yes ☐ No

Comments:

Signature: Paul Bishop Date: 10/6/2017