



# County of Yolo

Department of Community Services

Environmental Health Division

292 West Beamer St., Woodland, CA 95695

Phone (530) 666-8646 | Email: Ehealth@yolocounty.gov

## State Small Water System Permit Application

System Name: \_\_\_\_\_

Site Address: \_\_\_\_\_

The \_\_\_\_\_ (applicant) hereby makes application to the Environmental Health Division for a Water Supply Permit to operate a:

State Small Water System, defined under the California Health and Safety Code, Section 116275 as “a system for the provision of piped water to the public for human consumption that serves at least five, but not more than 14, service connections and does not regularly serve drinking water to more than an average of 25 individuals daily for more than 60 days out of the year.”

Pursuant to the provisions of the California Safe Drinking Water Act (Health & Safety Code, Section 116270) please provide the following information:

1. Description of source (well, spring, surface Water): \_\_\_\_\_
2. Is water treatment provided, and if so, what is the treatment purpose? \_\_\_\_\_  
\_\_\_\_\_
3. Do you have a well completion report (well log)? \_\_\_\_\_ (If so, please attach a copy. If not, please submit a request to the CA Department of Water Resources  
<https://water.ca.gov/Programs/Groundwater-Management/Wells/Well-Completion-Reports> )

I /We declare under penalty of perjury that the statements on this application and on the accompanying attachments are correct to my/our knowledge and that I/we are acting under authority and direction of the responsible legal entity under whose name this application is made.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Printed Name & Title: \_\_\_\_\_

Email: \_\_\_\_\_ Phone Number: \_\_\_\_\_

### **Staff Use Only**

System Number:

Facility ID:

**WATER SUPPLY REQUIREMENTS FOR STATE SMALL WATER SYSTEMS**  
**CCR Title 22, Section 64211-64217**

**PERMIT**

A State Small Water System using an approved domestic water well is required to obtain a *State Small Water Supply Permit* issued by Yolo County Environmental Health.

**CONSTRUCTION & SUPPLY**

The water well must meet current well construction standards for a domestic well.

The water system must provide sufficient water to supply a minimum of 3 gallons per minute for at least 24 hours for each service connection served.

**TECHNICAL REPORT**

Submit a technical report to the local health officer as part of the permit application. The report shall:

- Describe the system service area, distribution system including storage and pumping facilities, the water source including source capacity, water quality, and any water treatment facilities.
- Identify the owner of the system and the party responsible for day-to-day operation of the system.
- Include an emergency notification and system operating plan for the system.

**CONSUMER NOTIFICATION**

Provide the following notice to the consumers served by the state small water system:

*“The domestic water supply for this area is provided by a state small water system. State regulatory requirements for operation of a state small water system are less extensive than requirements for larger public water systems. If you have questions concerning your water supply, you should contact [insert (1) name of water system, (2) name of responsible person, and (3) telephone number] or your local health department.”*

This notice shall be by direct delivery on an annual basis or by continuous posting at a central location within the area served by the state small water system.

**TESTING REQUIREMENTS**

Water supplied by the State Small Water System will be subject to the following minimum water quality standards:

**Initial Testing:**

- Bacteriological (*Total Coliform & E. coli*)
- Nitrate
- Nitrite
- Fluoride, Iron, Manganese, Chlorides, Total dissolved solids
- Inorganic Chemicals (Title 22 Table 64431-A)
- VOCs (if vulnerable)

**Ongoing Testing:** The following constituents will be required to be routinely monitored. Testing frequency will be determined based on initial results.

- Bacteriological
- Nitrate
- Nitrite

All water quality tests must be conducted by a laboratory certified for drinking water analyses in California through the Environmental Laboratory Accreditation Program (ELAP). Please refer to the Yolo County website for a list of certified laboratories.