

Electronic Report Transmittal Form

Attention: Brendan Kenny (916) 464-4635
Central Valley Regional Water Quality Control Board
11020 Sun Center Drive #200
Rancho Cordova, Ca 95670-6114

Discharger: Wild Wings County Service Area
Name of Facility: Wild Wings Water Recycling Facility
MRP No: R5-2002-0077
CIWQS Place ID: 272537
County: Yolo

I am hereby submitting to the Central Valley Water Board the following information:

Check all that apply:

Technical Report Title and Date **Self-Monitoring Report for Wild Wings**

Monthly Monitoring Report for the Month of **August 2017**

1st / 2nd / 3rd / 4th (**circle one**) Quarterly Monitoring Report for the year_____.

1st / 2nd (**circle one**) Semi-annual Monitoring Report for the year_____.

Annual Monitoring Report for the year_____.

Violation Notification:

During the Monitoring period, there **were** / were not (circle one) any violations of the WDRs.

1. The Violations were:

One exceedance of total coliform on the 13th greater than 23 MPN/100 mL. The result was 49 MPN/100 mL.

2. Have the violations been corrected? **Yes** / No. If no, what will be done to correct the violations:

Certification Statement:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Signature: *P. Bishop*

Phone: **540-492-2332**

Printed Name: **Paul Bishop**

Date: **9/29/2017**

Electronic Report Submittal:

To submit the electronic reports please do the following:

1. First, make a PDF copy of your report and include this form as the first page of the report.
2. Attach the PDF file to the email.
3. Send the email and PDF attachment to:
Centralvalleysacramento@waterboards.ca.gov (Please note that in order to ensure your reports are cataloged correctly and routed to the appropriate Regional Board staff, only one report/attachment shall be included with each e-mail.)

DATE	Influent Monitoring						Secondary Monitoring			Tertiary Effluent Monitoring				Tertiary Effluent Monitoring						
	Flow	pH	EC	TDS	BOD ₅	TSS	pH	BOD ₅	TSS	Flow	Turbidity	Cl2	Total Coliform	pH	BOD ₅	TSS	EC	TDS	TKN	Nitrate(N)
2013	Influent	Influent	Influent	Influent	Influent	Influent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent
	GPD	pH units	umhos/cm	mg/L	mg/L	mg/L	pH units	mg/L	mg/L	GPD	NTU	mg/L	MPN/100 ml	pH units	mg/L	mg/L	umhos/cm	mg/L	mg/L	mg/L
	Metered	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Continuous	Continuous	Continuous	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab
	Daily	Weekly	Weekly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Daily	Daily	Daily	Daily	Weekly	Weekly	Weekly	Monthly	Monthly	Monthly	Monthly
1-Aug	53600									214720	1.00	>11.0	<1.8							
2-Aug	47800									267542	0.70	>11.0	<1.8		ND	ND				
3-Aug	141900	7.2	1550				7.3			215146	0.60	>11.0	<1.8	7.1						
4-Aug	68850									264068	1.90	>11.0	<1.8							
5-Aug	68850									264068	1.70	>11.0	<1.8							
6-Aug	77900									26890	1.10	>11.0	<1.8							
7-Aug	76100									512890	0.80	>11.0	<1.8							
8-Aug	61500	7.4	1420							593415	1.00	>11.0	<1.8	7.3						
9-Aug	61500									59341	2.00	>11.0	<1.8							
10-Aug	61500									120317	1.00	>11.0	23		ND	ND				
11-Aug	61800									264293	2.10	>11.0	<1.8							
12-Aug	53700									255982	2.20	>11.0	<1.8							
13-Aug	64200	7.4	1620							197161	1.80	>11.0	49	7.4						
14-Aug	64200									17161	1.90	>11.0	<1.8							
15-Aug	64200									17161	1.80	>11.0	<1.8							
16-Aug	64200									197161	1.90	>11.0	<1.8							
17-Aug	64200	7.6	1517							197161	2.20	>11.0	<1.8	7.7						
18-Aug	64300									557161	0.90	>11.0	<1.8							
19-Aug	57400									148071	0.80	>11.0	<1.8							
20-Aug	57400									148071	1.00	>11.0	4.5		ND	ND				
21-Aug	57400									148073	1.70	>11.0	<1.8							
22-Aug	57400									147079	0.70	>11.0	<1.8	7.1						
23-Aug	57400	7.2	1510							148071	1.10	>11.0	<1.8				1250			
24-Aug	57400									148071	2.00	>11.0	<1.8							
25-Aug	57400									148071	2.00	>11.0	<1.8		ND	ND				
26-Aug	41400	7.3	1560							148061	1.70	>11.0	<1.8	7.0						
27-Aug	41400									148081	1.10	>11.0	<1.8							
28-Aug	41400									148071	2.00	>11.0	<1.8							
29-Aug	41400									148071	2.10	>11.0	<1.8							
30-Aug	41400									296309	1.10	>11.0	<1.8							
31-Aug	124,200			850	72	98	4.6	ND		57177	1.00	>11.0	<1.8		ND	ND		540	0.39	3.4
TOTAL	1,953,300									6,222,915										
AVG.	63,010	43,730	1530	850.0	72.0	98.0	7.30	0	0	200,739	1.45	#DIV/0!	0.00	7.3	#DIV/0!		1,250	#DIV/0!	#DIV/0!	#DIV/0!
MINIMUM	41,400	50,340	1420	850.0	72.0	98.0	7.3	5	0	17161	0.6	0.0		7.0	0.0		1,250	0	0.00	0.0
MAXIMUM	141,900	7.2	1,620	850	72.0	98.0	7	5	0	593,415	2.2	0		7.7	0.0		1,250	0	0.00	0.0
Requirement #1	AVG.-100 MG	Min 6.5					Min 6.5				AVG. 2.0	Min 1.0	MED 2.2	Min 6.5						
Times Exceeded	0	0	0				0				0	0	0	0						
Requirement #2		Max 8.5		Max 1500			Max 8.5				Max 10		Max 23	Max 8.5	Max 10	Max 10			Max 1500	
Times Exceeded	0			0			0				0		1.0	0	0	0			0	

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all the attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations.

P. Bishop

Signature of Principle Executive Officer or Authorized Agent

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0033 COC #: 179922
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff (17H0033-01) WW Sampled: 08/01/17 09:00 Received: 08/01/17 12:00									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705721	08/01/17	08/03/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0110 COC #: 179923
--	--	--

Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff. (17H0110-02) WW Sampled: 08/02/17 08:30 Received: 08/02/17 12:30									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1705790	08/03/17	08/08/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1705788	08/03/17	08/03/17	SM2540D	
MLSS (17H0110-03) WW Sampled: 08/02/17 08:35 Received: 08/02/17 12:30									
Total Suspended Solids	1600	5.0	mg/L	1	1705788	08/03/17	08/03/17	SM2540D	

CALIFORNIA LABORATORY SERVICES

Page 3 of 5

08/09/17 12:50

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0110 COC #: 179923
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff. (17H0110-01) WW Sampled: 08/02/17 09:00 Received: 08/02/17 12:30									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705761	08/02/17	08/06/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0181 COC #: 179925
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17H0181-01) WW Sampled: 08/03/17 09:00 Received: 08/03/17 11:30									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705799	08/03/17	08/05/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

Page 2 of 3

08/11/17 12:26

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0231 COC #: 179926
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17H0231-01) WW Sampled: 08/04/17 09:00 Received: 08/04/17 11:45									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705837	08/04/17	08/06/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0271 COC #: 179927
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17H0271-01) WW Sampled: 08/05/17 09:00 Received: 08/05/17 12:25									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705860	08/05/17	08/07/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0282 COC #: 179928
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff (17H0282-01) WW Sampled: 08/06/17 09:00 Received: 08/06/17 12:15									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705861	08/06/17	08/10/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0326 COC #: 179929
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17H0326-01) Water Sampled: 08/07/17 09:00 Received: 08/07/17 14:10									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705883	08/07/17	08/09/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0370 COC #: 179930
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff (17H0370-01) WW Sampled: 08/08/17 09:00 Received: 08/08/17 12:30									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705915	08/08/17	08/12/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0445 COC #: 179931
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff (17H0445-01) WW Sampled: 08/09/17 09:00 Received: 08/09/17 12:45									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705961	08/09/17	08/11/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0529 COC #: 179932
--	--	--

Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert Eff. (17H0529-02) WW Sampled: 08/10/17 08:30 Received: 08/10/17 14:15									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1706031	08/11/17	08/16/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1706020	08/11/17	08/11/17	SM2540D	
MLSS (17H0529-03) WW Sampled: 08/10/17 08:40 Received: 08/10/17 14:15									
Total Suspended Solids	1300	5.0	mg/L	1	1706020	08/11/17	08/11/17	SM2540D	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0529 COC #: 179932
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert Eff. (17H0529-01) WW Sampled: 08/10/17 09:00 Received: 08/10/17 14:15									
Total Coliforms	23	1.8	MPN/100 mL	1	1706004	08/10/17	08/13/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0564 COC #: 179933
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17H0564-01) WW Sampled: 08/11/17 09:00 Received: 08/11/17 11:20									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706029	08/11/17	08/13/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0598 COC #: 179934
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff (17H0598-01) WW Sampled: 08/12/17 09:00 Received: 08/12/17 12:40									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706067	08/12/17	08/14/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0606 COC #: 179935
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff (17H0606-01) WW Sampled: 08/13/17 09:00 Received: 08/13/17 12:12									
Total Coliforms	49	1.8	MPN/100 mL	1	1706068	08/13/17	08/17/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0624 COC #: 179936
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert. Eff. (17H0624-01) WW Sampled: 08/14/17 09:00 Received: 08/14/17 11:50									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706080	08/14/17	08/16/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0679 COC #: 179937
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17H0679-01) WW Sampled: 08/15/17 09:00 Received: 08/15/17 11:55									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706123	08/15/17	08/17/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0748 COC #: 181414
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17H0748-01) WW Sampled: 08/16/17 09:00 Received: 08/16/17 12:00									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706170	08/16/17	08/18/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0819 COC #: 181415
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17H0819-01) WW Sampled: 08/17/17 09:00 Received: 08/17/17 12:10									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706219	08/17/17	08/19/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0869 COC #: 181416
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17H0869-01) WW Sampled: 08/18/17 09:00 Received: 08/18/17 12:15									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706257	08/18/17	08/20/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0903 COC #: 181417
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17H0903-01) WW Sampled: 08/19/17 09:00 Received: 08/19/17 09:00									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706284	08/19/17	08/21/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0905 COC #: 181418
--	--	--

Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17H0905-02) WW Sampled: 08/20/17 08:30 Received: 08/20/17 11:50									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1706283	08/20/17	08/25/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1706356	08/23/17	08/23/17	SM2540D	
MLSS (17H0905-03) WW Sampled: 08/20/17 08:35 Received: 08/20/17 11:50									
Total Suspended Solids	620	5.0	mg/L	1	1706356	08/23/17	08/23/17	SM2540D	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0905 COC #: 181418
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17H0905-01) WW Sampled: 08/20/17 09:00 Received: 08/20/17 11:50									
Total Coliforms	4.5	1.8	MPN/100 mL	1	1706286	08/20/17	08/24/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0930 COC #: 181419
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17H0930-01) WW Sampled: 08/21/17 09:00 Received: 08/21/17 12:30									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706298	08/21/17	08/23/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H0991 COC #: 181420
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17H0991-01) WW Sampled: 08/22/17 09:00 Received: 08/22/17 12:05									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706335	08/22/17	08/24/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H1052 COC #: 181421
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff (17H1052-01) WW Sampled: 08/23/17 09:00 Received: 08/23/17 11:55									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706375	08/23/17	08/25/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H1124 COC #: 181422
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17H1124-01) WW Sampled: 08/24/17 09:00 Received: 08/24/17 12:00									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706419	08/24/17	08/26/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H1172 COC #: 181423
--	--	--

Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17H1172-02) WW Sampled: 08/25/17 08:30 Received: 08/25/17 11:47									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1706428	08/25/17	08/30/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1706503	08/28/17	08/28/17	SM2540D	
MLSS (17H1172-03) WW Sampled: 08/25/17 08:40 Received: 08/25/17 11:47									
Total Suspended Solids	820	5.0	mg/L	1	1706503	08/28/17	08/28/17	SM2540D	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H1172 COC #: 181423
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17H1172-01) WW Sampled: 08/25/17 09:00 Received: 08/25/17 11:47									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706457	08/25/17	08/27/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H1198 COC #: 181424
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17H1198-01) WW Sampled: 08/26/17 09:00 Received: 08/26/17 12:21									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706498	08/26/17	08/28/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H1208 COC #: 181425
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17H1208-01) WW Sampled: 08/27/17 09:00 Received: 08/27/17 12:02									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706500	08/27/17	08/29/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H1242 COC #: 181426
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17H1242-01) WW Sampled: 08/28/17 09:00 Received: 08/28/17 12:20									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706514	08/28/17	08/30/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H1284 COC #: 181427
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17H1284-01) WW Sampled: 08/29/17 09:00 Received: 08/29/17 12:10									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706548	08/29/17	08/31/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H1347 COC #: 181428
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert Eff. (17H1347-01) WW Sampled: 08/30/17 09:00 Received: 08/30/17 12:05									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706587	08/30/17	09/01/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H1398 COC #: 181430
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff (17H1398-01) WW Sampled: 08/31/17 09:00 Received: 08/31/17 12:40									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706630	08/31/17	09/02/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17H1392 COC #: 181429
--	--	--

Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Inf. (17H1392-01) WW Sampled: 08/31/17 09:00 Received: 08/31/17 12:40									
Biochemical Oxygen Demand	72	3.0	mg/L	1	1706649	09/01/17	09/06/17	SM5210B	
Total Dissolved Solids	850	10	"	"	1706657	09/01/17	09/05/17	SM2540C	
Total Suspended Solids	98	5.0	"	"	1706660	09/01/17	09/01/17	SM2540D	
2nd Eff. (17H1392-02) WW Sampled: 08/31/17 09:00 Received: 08/31/17 12:40									
Biochemical Oxygen Demand	4.6	3.0	mg/L	1	1706649	09/01/17	09/06/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1706660	09/01/17	09/01/17	SM2540D	
tert. Eff. (17H1392-03) WW Sampled: 08/31/17 09:00 Received: 08/31/17 12:40									
Ammonia as N	0.17	0.10	mg/L	1	1706666	09/01/17	09/01/17	SM4500-NH3C	
Biochemical Oxygen Demand	ND	3.0	"	"	1706649	09/01/17	09/06/17	SM5210B	
Nitrate as N	3.4	0.40	"	"	1706605	08/31/17	08/31/17	EPA 300.0	
Nitrate/Nitrite as N	3.4	0.40	"	"	"	"	"	"	
Total Dissolved Solids	540	10	"	"	1706657	09/01/17	09/05/17	SM2540C	
Total Kjeldahl Nitrogen	0.39	0.20	"	"	1706675	09/01/17	09/01/17	SM4500-NH3C	
Total Nitrogen	3.8	0.40	"	"	1706676	09/01/17	09/01/17	EPA 351.3/300	
Total Suspended Solids	ND	5.0	"	"	1706660	09/01/17	09/01/17	SM2540D	
MLSS (17H1392-04) WW Sampled: 08/31/17 09:00 Received: 08/31/17 12:40									
Total Suspended Solids	1000	5.0	mg/L	1	1706660	09/01/17	09/01/17	SM2540D	
Storage Pond (17H1392-05) Wastewater Sampled: 08/31/17 09:00 Received: 08/31/17 12:40									
Nitrate/Nitrite as N	0.69	0.40	mg/L	1	1706605	08/31/17	08/31/17	EPA 300.0	
Total Dissolved Solids	530	10	"	"	1706657	09/01/17	09/05/17	SM2540C	
Total Kjeldahl Nitrogen	1.2	0.20	"	"	1706675	09/01/17	09/01/17	SM4500-NH3C	
Total Nitrogen	1.9	0.40	"	"	1706676	09/01/17	09/01/17	EPA 351.3/300	