

Electronic Report Transmittal Form

Attention: Brendan Kenny (916) 464-4635
Central Valley Regional Water Quality Control Board
11020 Sun Center Drive #200
Rancho Cordova, Ca 95670-6114

Discharger: Wild Wings County Service Area
Name of Facility: Wild Wings Water Recycling Facility
MRP No: R5-2002-0077
CIWQS Place ID: 272537
County: Yolo

I am hereby submitting to the Central Valley Water Board the following information:

Check all that apply:

Technical Report Title and Date **Self-Monitoring Report for Wild Wings**

Monthly Monitoring Report for the Month of **July 2017**

1st / 2nd / 3rd / 4th (**circle one**) Quarterly Monitoring Report for the year_____.

1st / 2nd (**circle one**) Semi-annual Monitoring Report for the year_____.

Annual Monitoring Report for the year_____.

Violation Notification:

During the Monitoring period, there were / **were not** (circle one) any violations of the WDRs.

1. The Violations were:
2. Have the violations been corrected? Yes / No. If no, what will be done to correct the violations:

DATE	Influent Monitoring			Secondary Monitoring						Tertiary Effluent Monitoring				Tertiary Effluent Monitoring						TKN	Nitrate(N)
	Flow	pH	EC	TDS	BOD ₅	TSS	pH	BOD ₅	TSS	Flow	Turbidity	Cl2	Total Coliform	pH	BOD ₅	TSS	EC	TDS			
2013	Influent	Influent	Influent	Influent	Influent	Influent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent
	GPD	pH units	umhos/cm	mg/L	mg/L	mg/L	pH units	mg/L	mg/L	GPD	NTU	mg/L	MPN/100 ml	pH units	mg/L	mg/L	umhos/cm	mg/L	mg/L	mg/L	mg/L
	Metered	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Continuous	Continuous	Continuous	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab
	Daily	Weekly	Weekly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Daily	Daily	Daily	Daily	Weekly	Weekly	Weekly	Monthly	Monthly	Monthly	Monthly	Monthly
1-Jul	62,700									58724	2.00	<11.0	2								
2-Jul	74,400									61470	2.00	<11.0	<1.8								
3-Jul	32,100									72813	2.00	<11.0	<1.8								
4-Jul	57,100									93771	1.90	<11.0	<1.8								
5-Jul	51,100	7.3	1317.0				7.41			87614	1.40	<11.0	<1.8	7.3			1051				
6-Jul	58,500									208288	0.90	<11.0	<1.8								
7-Jul	71,200									257638	1.00	<11.0	<1.8		ND	ND					
8-Jul	60,100									271201	0.80	<11.0	<1.8								
9-Jul	52,200									247792	1.00	<11.0	<1.8								
10-Jul	54,900									197914	0.70	<11.0	<1.8								
11-Jul	48,800	7.4	1411							240882	0.38	<11.0	<1.8	7.4							
12-Jul	58,100									203341	0.60	<11.0	<1.8								
13-Jul	61,100									140166	1.10	<11.0	<1.8		ND	ND					
14-Jul	30,900									167500	0.80	<11.0	<1.8								
15-Jul	66,300									187991	0.50	<11.0	<1.8								
16-Jul	60,900	7.2	1287							231401	0.90	<11.0	<1.8	7.1							
17-Jul	80,800									125920	0.70	<11.0	<1.8								
18-Jul	64,500									66728	0.40	<11.0	<1.8								
19-Jul	48,100									58082	1.50	<11.0	<1.8		ND	ND					
20-Jul	56,300									63834	0.40	<11.0	<1.8								
21-Jul	58,700									70570	0.60	<11.0	<1.8								
22-Jul	67,900									81072	0.80	<11.0	<1.8								
23-Jul	60,100	7.2	1215							60330	0.90	<11.0	7.8	7.2							
24-Jul	57,200									25316	1.10	<11.0	<1.8								
25-Jul	55,600									220750	1.00	<11.0	<1.8								
26-Jul	59,300									63000	0.60	<11.0	2								
27-Jul	58,800									61725	0.60	<11.0	<1.8								
28-Jul	59,800	7.3	1216							62601	1.00	<11.0	<1.8	7.2	ND	ND					
29-Jul	60,200									64711	0.60	<11.0	2								
30-Jul	57,120									59722	0.70	<11.0	<1.8								
31-Jul	58,160			830	57	62		ND	ND	64500	0.60	<11.0	<1.8		ND	ND		570	ND	3.8	
TOTAL	1,802,980	36	6,446	830	57	62	7	0	0	3877367	29	0		36	0	0	1,051	570	0	4	
AVG.	58,161	7.3	1289	#DIV/0!	#DIV/0!	#DIV/0!	7.4			125076	0.95	#DIV/0!		7.2	#DIV/0!		1,051	#DIV/0!	#DIV/0!	#DIV/0!	
MINIMUM	30,900	7.2	1215	0	0	0	7.4	0	0	25316	0.38	0.00	<1.8	7.1	0.0	0.00	1,051	0	0.00	0.0	
MAXIMUM	80,800	7.4	1411	0	0	0	7.4	0	0	271201	2.00	0.00	7.80	7.4	0.0	0.00	1,051	0	0.00	0.0	
Requirement #1							Min 6.5				AVG. 2.0		MED 2.2								
Times Exceeded							0				#DIV/0!		0								
Requirement #2				Max 1500			Max 8.5				Max 10		Max 23	Max 8.5	Max 10	Max 10		Max 1500			
Times Exceeded				0			0				57.0		0.0	0	1	0		0			

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all the attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations.

P. Bishop

Signature of Principle Executive Officer or Authorized Agent

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0008 COC #: 178489
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff (17G0008-01) WW Sampled: 07/01/17 09:00 Received: 07/01/17 12:30									
Total Coliforms	2.0	1.8	MPN/100 mL	1	1704913	07/01/17	07/03/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

Page 2 of 3

07/11/17 12:30

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0012 COC #: 178490
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert. Eff. (17G0012-01) WW Sampled: 07/02/17 09:00 Received: 07/02/17 12:26									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1704914	07/02/17	07/04/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0031 COC #: 178491
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17G0031-01) WW Sampled: 07/03/17 09:00 Received: 07/03/17 12:45									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1704931	07/03/17	07/05/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0091 COC #: 178492
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17G0091-01) WW Sampled: 07/04/17 09:00 Received: 07/04/17 12:45									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1704958	07/04/17	07/06/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0114 COC #: 178493
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert EFF (17G0114-01) WW Sampled: 07/05/17 09:00 Received: 07/05/17 13:00									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1704972	07/05/17	07/07/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0185 COC #: 178494
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff (17G0185-01) WW Sampled: 07/06/17 09:00 Received: 07/06/17 13:00									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705022	07/06/17	07/08/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0269 COC #: 178495
--	--	--

Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff (17G0269-02) WW Sampled: 07/07/17 08:30 Received: 07/07/17 12:20									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1705039	07/07/17	07/12/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1705084	07/10/17	07/10/17	SM2540D	
MLSS (17G0269-03) WW Sampled: 07/07/17 08:40 Received: 07/07/17 12:20									
Total Suspended Solids	1900	5.0	mg/L	1	1705084	07/10/17	07/10/17	SM2540D	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0269 COC #: 178495
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff (17G0269-01) WW Sampled: 07/07/17 09:00 Received: 07/07/17 12:20									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705053	07/07/17	07/09/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

Page 2 of 3

07/17/17 10:54

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0308 COC #: 178496
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
WW Tert. Eff. (17G0308-01) WW Sampled: 07/08/17 09:00 Received: 07/08/17 12:30									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705090	07/08/17	07/10/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

Page 2 of 3

07/17/17 10:55

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0319 COC #: 178497
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17G0319-01) WW Sampled: 07/09/17 09:00 Received: 07/09/17 12:30									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705091	07/09/17	07/13/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0335 COC #: 178498
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17G0335-01) WW Sampled: 07/10/17 09:00 Received: 07/10/17 11:55									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705101	07/10/17	07/12/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0403 COC #: 178499
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff (17G0403-01) WW Sampled: 07/11/17 09:00 Received: 07/11/17 13:05									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705141	07/11/17	07/13/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0480 COC #: 178500
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff (17G0480-01) WW Sampled: 07/12/17 09:00 Received: 07/12/17 13:00									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705182	07/12/17	07/14/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0549 COC #: 180865
--	--	--

Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff (17G0549-02) WW Sampled: 07/13/17 09:00 Received: 07/13/17 12:20									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1705189	07/13/17	07/18/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1705247	07/14/17	07/14/17	SM2540D	
MLSS (17G0549-03) WW Sampled: 07/13/17 09:00 Received: 07/13/17 12:20									
Total Suspended Solids	1800	5.0	mg/L	1	1705247	07/14/17	07/14/17	SM2540D	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0549 COC #: 180865
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff (17G0549-01) WW Sampled: 07/13/17 09:00 Received: 07/13/17 12:20									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705216	07/13/17	07/15/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0624 COC #: 180866
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17G0624-01) WW Sampled: 07/14/17 09:00 Received: 07/14/17 12:45									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705263	07/14/17	07/16/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0666 COC #: 180868
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17G0666-01) WW Sampled: 07/15/17 09:00 Received: 07/15/17 12:45									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705293	07/15/17	07/17/17	SM 9221	
Pintail (17G0666-02) Water Sampled: 07/15/17 09:10 Received: 07/15/17 12:45									
E. Coli	Absent	0.0	N/A	1	1705300	07/15/17	07/16/17	SM 9223	
Residual Chlorine	1.00	0.10	mg/L	"	"	07/15/17	07/15/17	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	07/15/17	07/16/17	SM 9223	
Mandarin (17G0666-03) Water Sampled: 07/15/17 09:15 Received: 07/15/17 12:45									
E. Coli	Absent	0.0	N/A	1	1705300	07/15/17	07/16/17	SM 9223	
Residual Chlorine	1.20	0.10	mg/L	"	"	07/15/17	07/15/17	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	07/15/17	07/16/17	SM 9223	
Mallard (17G0666-04) Water Sampled: 07/15/17 09:15 Received: 07/15/17 12:45									
E. Coli	Absent	0.0	N/A	1	1705300	07/15/17	07/16/17	SM 9223	
Residual Chlorine	1.00	0.10	mg/L	"	"	07/15/17	07/15/17	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	07/15/17	07/16/17	SM 9223	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0679 COC #: 180869
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17G0679-01) WW Sampled: 07/16/17 09:00 Received: 07/16/17 12:30									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705294	07/16/17	07/18/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0694 COC #: 180870
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17G0694-01) WW Sampled: 07/17/17 09:00 Received: 07/17/17 12:25									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705302	07/17/17	07/21/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

Page 2 of 3

07/25/17 14:30

National O&M, Inc
P.O. Box 21187
Roanoke, VA 24018

Project: Wild Wings Recycling Facility
Project Number: [none]
Project Manager: Paul Bishop

CLS Work Order #: 17G0774
COC #: 180871

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17G0774-01) WW Sampled: 07/18/17 09:00 Received: 07/18/17 13:50									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705354	07/18/17	07/20/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0840 COC #: 180872
--	--	--

Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17G0840-02) WW Sampled: 07/19/17 08:00 Received: 07/19/17 13:30									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1705432	07/20/17	07/25/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1705422	07/20/17	07/20/17	SM2540D	
MLSS (17G0840-03) WW Sampled: 07/19/17 08:10 Received: 07/19/17 13:30									
Total Suspended Solids	2200	5.0	mg/L	1	1705422	07/20/17	07/20/17	SM2540D	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0840 COC #: 180872
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17G0840-01) WW Sampled: 07/19/17 09:00 Received: 07/19/17 13:30									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705393	07/19/17	07/21/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0912 COC #: 179910
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Final Effluent (17G0912-01) WW Sampled: 07/20/17 08:30 Received: 07/20/17 11:45									
E. Coli	<1.8	1.8	MPN/100 mL	1	1705438	07/20/17	07/22/17	SM 9221	
Fecal Coliforms	<1.8	1.8	"	"	"	"	"	"	
Total Coliforms	<1.8	1.8	"	"	"	"	"	"	

CALIFORNIA LABORATORY SERVICES

Page 2 of 3

07/28/17 10:50

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0987 COC #: 179911
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Final Effluent (17G0987-01) WW Sampled: 07/21/17 09:00 Received: 07/21/17 13:30									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705483	07/21/17	07/23/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G1006 COC #: 179912
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff (17G1006-01) WW Sampled: 07/22/17 09:00 Received: 07/22/17 12:30									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705504	07/22/17	07/24/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G1024 COC #: 179913
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17G1024-01) WW Sampled: 07/23/17 09:00 Received: 07/23/17 12:23									
Total Coliforms	7.8	1.8	MPN/100 mL	1	1705505	07/23/17	07/25/17	SM 9221	
Pintail (17G1024-02) WW Sampled: 07/23/17 08:50 Received: 07/23/17 12:23									
E. Coli	Absent	0.0	N/A	1	1705520	07/23/17	07/24/17	SM 9223	
Total Coliforms	Absent	0.0	"	"	"	"	"	"	"
Mandarin (17G1024-03) WW Sampled: 07/23/17 08:40 Received: 07/23/17 12:23									
E. Coli	Absent	0.0	N/A	1	1705520	07/23/17	07/24/17	SM 9223	
Total Coliforms	Absent	0.0	"	"	"	"	"	"	"
Mallard (17G1024-04) WW Sampled: 07/23/17 08:30 Received: 07/23/17 12:23									
E. Coli	Absent	0.0	N/A	1	1705520	07/23/17	07/24/17	SM 9223	
Total Coliforms	Absent	0.0	"	"	"	"	"	"	"

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G1043 COC #: 179914
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert. Eff. (17G1043-01) WW Sampled: 07/24/17 09:00 Received: 07/24/17 11:55									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705514	07/24/17	07/28/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G1102 COC #: 179915
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert. Eff. (17G1102-01) WW Sampled: 07/25/17 09:00 Received: 07/25/17 12:35									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705556	07/25/17	07/27/17	SM 9221	
Pintail (17G1102-02) WW Sampled: 07/25/17 08:30 Received: 07/25/17 12:35									
E. Coli	Absent	0.0	N/A	1	1705554	07/25/17	07/26/17	SM 9223	
Total Coliforms	Absent	0.0	"	"	"	"	"	"	"
Mallard (17G1102-03) WW Sampled: 07/25/17 08:35 Received: 07/25/17 12:35									
E. Coli	Absent	0.0	N/A	1	1705554	07/25/17	07/26/17	SM 9223	
Total Coliforms	Absent	0.0	"	"	"	"	"	"	"
Mandarin (17G1102-04) WW Sampled: 07/25/17 08:40 Received: 07/25/17 12:35									
E. Coli	Absent	0.0	N/A	1	1705554	07/25/17	07/26/17	SM 9223	
Total Coliforms	Absent	0.0	"	"	"	"	"	"	"

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G1155 COC #: 179916
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert. Eff. (17G1155-01) WW Sampled: 07/26/17 09:00 Received: 07/26/17 12:17									
Total Coliforms	2.0	1.8	MPN/100 mL	1	1705589	07/26/17	07/30/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G1206 COC #: 179917
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert. Eff. (17G1206-01) WW Sampled: 07/27/17 09:00 Received: 07/27/17 11:15									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705621	07/27/17	07/29/17	SM 9221	
Pintail (17G1206-02) WW Sampled: 07/27/17 08:30 Received: 07/27/17 11:15									
E. Coli	Absent	0.0	N/A	1	1705623	07/27/17	07/28/17	SM 9223	
Total Coliforms	Absent	0.0	"	"	"	"	"	"	"
Mandarin (17G1206-03) WW Sampled: 07/27/17 08:40 Received: 07/27/17 11:15									
E. Coli	Absent	0.0	N/A	1	1705623	07/27/17	07/28/17	SM 9223	
Total Coliforms	Absent	0.0	"	"	"	"	"	"	"
Mallard (17G1206-04) WW Sampled: 07/27/17 08:50 Received: 07/27/17 11:15									
E. Coli	Absent	0.0	N/A	1	1705623	07/27/17	07/28/17	SM 9223	
Total Coliforms	Absent	0.0	"	"	"	"	"	"	"

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G1251 COC #: 179918
--	--	--

Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff. (17G1251-02) WW Sampled: 07/28/17 08:30 Received: 07/28/17 15:20									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1705638	07/28/17	08/02/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1705708	08/01/17	08/01/17	SM2540D	
MLSS (17G1251-03) WW Sampled: 07/28/17 08:40 Received: 07/28/17 15:20									
Total Suspended Solids	1900	5.0	mg/L	1	1705708	08/01/17	08/01/17	SM2540D	

CALIFORNIA LABORATORY SERVICES

Page 3 of 5

08/04/17 13:55

National O&M, Inc
P.O. Box 21187
Roanoke, VA 24018

Project: Wild Wings Recycling Facility
Project Number: [none]
Project Manager: Paul Bishop

CLS Work Order #: 17G1251
COC #: 179918

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert. Eff. (17G1251-01) WW Sampled: 07/28/17 09:00 Received: 07/28/17 15:20									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705656	07/28/17	07/30/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G1262 COC #: 179919
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff (17G1262-01) WW Sampled: 07/29/17 09:00 Received: 07/29/17 12:05									
Total Coliforms	2.0	1.8	MPN/100 mL	1	1705674	07/29/17	08/01/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G1268 COC #: 179920
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff (17G1268-01) WW Sampled: 07/30/17 09:00 Received: 07/30/17 12:15									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705677	07/30/17	08/01/17	SM 9221	
Mallard (17G1268-02) Water Sampled: 07/30/17 08:30 Received: 07/30/17 12:15									
E. Coli	Absent	0.0	N/A	1	1705679	07/30/17	07/31/17	SM 9223	
Total Coliforms	Absent	0.0	"	"	"	"	"	"	"
Mandarin (17G1268-03) Water Sampled: 07/30/17 08:40 Received: 07/30/17 12:15									
E. Coli	Absent	0.0	N/A	1	1705679	07/30/17	07/31/17	SM 9223	
Total Coliforms	Absent	0.0	"	"	"	"	"	"	"

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G1289 COC #: 179921
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert. Eff (17G1289-01) WW Sampled: 07/31/17 09:00 Received: 07/31/17 14:30									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1705691	07/31/17	08/02/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17G0669 COC #: 180867
--	--	--

Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Inf (17G0669-01) WW Sampled: 07/16/17 07:30 Received: 07/16/17 12:30									
Biochemical Oxygen Demand	57	3.0	mg/L	1	1705295	07/16/17	07/21/17	SM5210B	
Total Dissolved Solids	830	10	"	"	1705334	07/18/17	07/19/17	SM2540C	
Total Suspended Solids	62	5.0	"	"	1705332	07/18/17	07/18/17	SM2540D	
2nd Eff. (17G0669-02) WW Sampled: 07/16/17 07:40 Received: 07/16/17 12:30									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1705295	07/16/17	07/21/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1705332	07/18/17	07/18/17	SM2540D	
Tert. Eff. (17G0669-03) WW Sampled: 07/16/17 07:50 Received: 07/16/17 12:30									
Ammonia as N	ND	0.10	mg/L	1	1705342	07/18/17	07/18/17	SM4500-NH3C	
Biochemical Oxygen Demand	ND	3.0	"	"	1705295	07/16/17	07/21/17	SM5210B	
Nitrate as N	3.8	2.0	"	5	1705274	07/17/17	07/17/17	EPA 300.0	
Nitrate/Nitrite as N	3.8	2.0	"	"	"	"	"	"	
Total Dissolved Solids	570	10	"	1	1705334	07/18/17	07/19/17	SM2540C	
Total Kjeldahl Nitrogen	ND	0.20	"	"	1705331	07/18/17	07/18/17	SM4500-NH3C	
Total Nitrogen	4.0	0.40	"	"	1705344	07/18/17	07/18/17	EPA 351.3/300	
Total Suspended Solids	ND	5.0	"	"	1705332	07/18/17	07/18/17	SM2540D	
MLSS (17G0669-04) WW Sampled: 07/16/17 08:05 Received: 07/16/17 12:30									
Total Suspended Solids	2000	5.0	mg/L	1	1705332	07/18/17	07/18/17	SM2540D	
Storage Pond (17G0669-05) Wastewater Sampled: 07/16/17 08:15 Received: 07/16/17 12:30									
Nitrate/Nitrite as N	ND	2.0	mg/L	5	1705274	07/17/17	07/17/17	EPA 300.0	
Total Dissolved Solids	500	10	"	1	1705334	07/18/17	07/19/17	SM2540C	
Total Kjeldahl Nitrogen	0.54	0.20	"	"	1705331	07/18/17	07/18/17	SM4500-NH3C	
Total Nitrogen	1.5	0.40	"	"	1705344	07/18/17	07/18/17	EPA 351.3/300	