

## Electronic Report Transmittal Form

Attention: Brendan Kenny (916) 464-4635  
Central Valley Regional Water Quality Control Board  
11020 Sun Center Drive #200  
Rancho Cordova, Ca 95670-6114

Discharger: Wild Wings County Service Area  
Name of Facility: Wild Wings Water Recycling Facility  
MRP No: R5-2002-0077  
CIWQS Place ID: 272537  
County: Yolo

I am hereby submitting to the Central Valley Water Board the following information:

### **Check all that apply:**

Technical Report Title and Date **Self-Monitoring Report for Wild Wings**

Monthly Monitoring Report for the Month of **May 2017**

1<sup>st</sup> / 2<sup>nd</sup> / 3<sup>rd</sup> / 4<sup>th</sup> (**circle one**) Quarterly Monitoring Report for the year \_\_\_\_\_.

1<sup>st</sup> / 2<sup>nd</sup> (**circle one**) Semi-annual Monitoring Report for the year \_\_\_\_\_.

Annual Monitoring Report for the year \_\_\_\_\_.

### **Violation Notification:**

During the Monitoring period, there were / were not (circle one) any violations of the WDRs.

1. The Violations were:

2. Have the violations been corrected? Yes / No. If no, what will be done to correct the violations:

**Comments:**

We encountered higher than normal flows from May 18<sup>th</sup> through May 22<sup>nd</sup> causing the plant to be hydraulically overloaded and causing our secondary clarifier to washout periodically over that time. Our daily flow averages have been 70k to 75k. The flows were:

May 18<sup>th</sup> 87,600 gals.  
May 19<sup>th</sup> 120,800 gals.  
May 20<sup>th</sup> 105,600 gals.  
May 21<sup>st</sup> 112,100 gals.  
May 22<sup>nd</sup> 98,600 gals.


**Equipment Maintenance/Repairs:**

- The online turbidity and chlorine meter sample pumps were replaced on May 26<sup>th</sup>.
- We installed a new chlorine Hach CL17 analyzer to replace the SureFlow unit on June 1<sup>st</sup>.
- We repaired the SCADA system on June 2<sup>nd</sup> to restore continuous SCADA recordings of the chlorine and turbidity analyzers.

**Certification Statement:**

*"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."*

Signature: \_\_\_\_\_



Phone: **540-492-2332**

Printed Name: **Paul Bishop**

Date: **6/30/2017**


**Electronic Report Submittal:**

To submit the electronic reports please do the following:

1. First, make a PDF copy of your report and include this form as the first page of the report.
2. Attach the PDF file to the email.
3. Send the email and PDF attachment to:  
[Centralvalleysacramento@waterboards.ca.gov](mailto:Centralvalleysacramento@waterboards.ca.gov) (Please note that in order to ensure your reports are cataloged correctly and routed to the appropriate Regional Board staff, only one report/attachment shall be included with each e-mail.)

DATE	Influent Monitoring						Secondary Monitoring			Tertiary Effluent Monitoring				Tertiary Effluent Monitoring						TKN	Nitrate(N)		
	Flow	pH	EC	TDS	BOD <sub>5</sub>	TSS	pH	BOD <sub>5</sub>	TSS	Flow	Turbidity	Cl2	Total Coliform	pH	BOD <sub>5</sub>	TSS	EC	TDS	Effluent			Effluent	Effluent
2013	Influent	Influent	Influent	Influent	Influent	Influent	Effluent	Effluent	Effluent	GPD	NTU	Effluent	Effluent	pH units	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent
	GPD	pH units	umhos/cm	mg/L	mg/L	mg/L	pH units	mg/L	mg/L	GPD	NTU	mg/L	MPN/100 ml	pH units	mg/L	mg/L	umhos/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Metered	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Continuous	Continuous	Continuous	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab
	Daily	Weekly	Weekly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Daily	Daily	Daily	Daily	Weekly	Weekly	Weekly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly
1-May	79,000	7.2	1518							76929	2.00	>11	<1.8	7.2									
2-May	52,100									100373	1.40	>11	<1.8										
3-May	72,200									103883	2.00	>11	<1.8			ND	ND						
4-May	68,900			820.0	200	220		11	6.7	178540	1.00	>11	<1.8		ND	11				560	3.3	ND	
5-May	52,000									83781	1.70	>11	<1.8										
6-May	58,000									67468	2.00	>11	<1.8										
7-May	58,800	7.1	1550.0							67420	2.00	>11	<1.8	7.1									
8-May	76,500									78174	2.00	>11	<1.8										
9-May	112,500									51326	2.00	>11	2										
10-May	10,300									106641	1.20	>11	<1.8		3.8	15							
11-May	56,800									70327	2.00	>11	<1.8										
12-May	56,100	7.3	1420.0					7.4		63496	2.00	>11	<1.8	7.4									
13-May	59,500									66197	1.20	>11	<1.8										
14-May	59,700									73274	1.90	>11	<1.8										
15-May	65,800									57372	2.00	>11	<1.8										
16-May	51,200									61357	2.00	>11	2										
17-May	36,000	7.4	1620.0							129336	2.00	>11	2	7.6									
18-May	87,600									137360	2.10	>11	<1.8		20	10							
19-May	120,800									144565	1.00	>11	<1.8										
20-May	105,100									104007	1.1	>11	<1.8										
21-May	112,100									112876	1.9	>11	<1.8										
22-May	98,600									52747	1.1	>11	<1.8										
23-May	62,200									58597	2	>11	<1.8	7.5			1120						
24-May	60,900									6404	1.8	>11	<1.8		22	ND							
25-May	42,400	7.7	1517.0							39844	2	5	<1.8										
26-May	49,200									53057	2	>11	<1.8										
27-May	47,100									47213	1.3	>11	<1.8										
28-May	75,700									46524	2	>11	<1.8	7.8									
29-May	55,800									37245	2.2	>11	<1.8										
30-May	69,900									25624	1.8	>11	<1.8										
31-May	66,100									75732	2.00	>11	<1.8										
TOTAL	2,078,900									2,377,689													
AVG.	67,061	7.3	1525	820	200	220		11.0		76,700	1.76	>11	<1.8	7.4	9.2		1,120	560	3.3	0.0			
MINIMUM	10,300	7.1	1420	820	200	220		11.0		6,404	1.00	5.00	<1.8	7.1	ND		1,120	560	3.3	0.0			
MAXIMUM	120,800	7.7	1620	820	200	220		11.0		178,540	2.20	>11	2.0	7.8	22.0		1,120	560	3.3	0.0			
Requirement #1	AVG. - 100 MG	Min 6.5		6.00				Min 6.5		AVG. 2.0	Min 1.0	MED 2.2	Min 6.5										
Times Exceeded	0.00	0.0	0.0	2				0		0		0	0										
Requirement #2		Max 8.5		2.00				Max 8.5		Max 10		Max 23	Max 8.5	Max 10	Max 10						Max 1500		
Times Exceeded		0.0		2.00				0		0		0.0	0	0	0						0		

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all the attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations.

  
 Signature of Principle Executive Officer or Authorized Agent



# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/08/17 14:12

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17E0023 COC #: 180943
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff. (17E0023-01) WW Sampled: 05/01/17 09:00 Received: 05/01/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708155	05/01/17	05/03/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/09/17 13:48

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17E0119 COC #: 180944
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17E0119-01) WW Sampled: 05/02/17 09:00 Received: 05/02/17 13:00</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703194	05/02/17	05/04/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 5

05/10/17 13:42

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17E0206 COC #: 180945
--	--	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17E0206-02) WW</b> Sampled: 05/03/17 08:30 Received: 05/03/17 12:45									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1703260	05/04/17	05/09/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1703263	05/04/17	05/04/17	SM2540D	
<b>MLSS (17E0206-03) WW</b> Sampled: 05/03/17 08:35 Received: 05/03/17 12:45									
Total Suspended Solids	2400	5.0	mg/L	1	1703263	05/04/17	05/04/17	SM2540D	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 3 of 5

05/10/17 13:42

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17E0206 COC #: 180945
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17E0206-01) WW Sampled: 05/03/17 09:00 Received: 05/03/17 12:45</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703239	05/03/17	05/05/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510



# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/11/17 14:17

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Vince Neill	CLS Work Order #: 17E0264 COC #: 180946
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff. (17E0264-01) WW Sampled: 05/04/17 09:00 Received: 05/04/17 12:15</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703274	05/04/17	05/06/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Vince Neill	CLS Work Order #: 17E0263 COC #: 180947
--	--	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Wild Wings Inf. (17E0263-01) WW    Sampled: 05/04/17 07:30    Received: 05/04/17 12:15</b>									
Biochemical Oxygen Demand	200	3.0	mg/L	1	1703313	05/05/17	05/10/17	SM5210B	
Total Dissolved Solids	820	10	"	"	1703305	05/05/17	05/08/17	SM2540C	
Total Suspended Solids	220	5.0	"	"	1703304	05/05/17	05/05/17	SM2540D	
<b>Wild Wings 2nd. Eff. (17E0263-02) WW    Sampled: 05/04/17 07:40    Received: 05/04/17 12:15</b>									
Biochemical Oxygen Demand	11	3.0	mg/L	1	1703313	05/05/17	05/10/17	SM5210B	
Total Suspended Solids	6.7	5.0	"	"	1703304	05/05/17	05/05/17	SM2540D	
<b>Wild Wings Tert. Eff. (17E0263-03) WW    Sampled: 05/04/17 07:50    Received: 05/04/17 12:15</b>									
Ammonia as N	2.8	0.10	mg/L	1	1703301	05/05/17	05/05/17	SM4500-NH3C	
Biochemical Oxygen Demand	ND	3.0	"	"	1703313	05/05/17	05/10/17	SM5210B	
Nitrate as N	ND	0.40	"	"	1703247	05/04/17	05/04/17	EPA 300.0	
Nitrate/Nitrite as N	ND	0.40	"	"	"	"	"	"	
Total Dissolved Solids	560	10	"	"	1703305	05/05/17	05/08/17	SM2540C	
Total Kjeldahl Nitrogen	3.3	0.20	"	"	1703314	05/05/17	05/05/17	SM4500-NH3C	
Total Nitrogen	3.3	0.40	"	"	1703318	05/05/17	05/05/17	EPA 351.3/300	
Total Suspended Solids	11	5.0	"	"	1703304	05/05/17	05/05/17	SM2540D	
<b>Wild Wings MLSS (17E0263-04) WW    Sampled: 05/04/17 08:05    Received: 05/04/17 12:15</b>									
Total Suspended Solids	2300	5.0	mg/L	1	1703304	05/05/17	05/05/17	SM2540D	
<b>Wild Wings Storage Pond (17E0263-05) WW    Sampled: 05/04/17 08:10    Received: 05/04/17 12:15</b>									
Nitrate/Nitrite as N	ND	0.40	mg/L	1	1703247	05/04/17	05/04/17	EPA 300.0	
Total Dissolved Solids	540	10	"	"	1703305	05/05/17	05/08/17	SM2540C	
Total Kjeldahl Nitrogen	1.4	0.20	"	"	1703314	05/05/17	05/05/17	SM4500-NH3C	
Total Nitrogen	1.4	0.40	"	"	1703318	05/05/17	05/05/17	EPA 351.3/300	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/12/17 12:16

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Vince Neill	CLS Work Order #: 17E0329 COC #: 180948
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17E0329-01) WW Sampled: 05/05/17 09:00 Received: 05/05/17 12:40</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703317	05/05/17	05/07/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/15/17 12:23

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Vince Neill	<b>CLS Work Order #: 17E0355</b> COC #: 180949
--	--	---

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>TERT EFF (17E0355-01) WW</b> Sampled: 05/06/17 09:00 Received: 05/06/17 12:40									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703343	05/06/17	05/10/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/15/17 12:23

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17E0363 COC #: 180950
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17E0363-01) WW Sampled: 05/07/17 09:00 Received: 05/07/17 12:45</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703344	05/07/17	05/09/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/15/17 12:24

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Vince Neill	CLS Work Order #: 17E0379 COC #: 180951
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff (17E0379-01) WW Sampled: 05/08/17 09:00 Received: 05/08/17 12:35</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703374	05/08/17	05/10/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/16/17 09:27

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Vince Neill

CLS Work Order #: 17E0470  
COC #: 178436

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff. (17E0470-01) WW Sampled: 05/09/17 09:00 Received: 05/09/17 13:00</b>									
Total Coliforms	2.0	1.8	MPN/100 mL	1	1703392	05/09/17	05/13/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 5

05/17/17 15:32

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Vince Neill	CLS Work Order #: 17E0536 COC #:
--	--	-------------------------------------

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff. (17E0536-02) WW</b> Sampled: 05/10/17 08:15 Received: 05/10/17 12:55									
Biochemical Oxygen Demand	3.8	3.0	mg/L	1	1703454	05/11/17	05/16/17	SM5210B	
Total Suspended Solids	15	5.0	"	"	1703495	05/12/17	05/12/17	SM2540D	
<b>MLSS (17E0536-03) WW</b> Sampled: 05/10/17 08:15 Received: 05/10/17 12:55									
Total Suspended Solids	2300	5.0	mg/L	1	1703495	05/12/17	05/12/17	SM2540D	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510



# CALIFORNIA LABORATORY SERVICES

Page 3 of 5

05/17/17 15:32

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Vince Neill	CLS Work Order #: 17E0536 COC #:
--	--	-------------------------------------

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff. (17E0536-01) WW Sampled: 05/10/17 09:00 Received: 05/10/17 12:55</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703431	05/10/17	05/14/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/18/17 13:45

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Vince Neill	CLS Work Order #: 17E0593 COC #: 178438
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17E0593-01) WW Sampled: 05/11/17 09:00 Received: 05/11/17 12:45</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703467	05/11/17	05/15/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/19/17 13:47

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Vince Neill	CLS Work Order #: 17E0634 COC #: 178439
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff. (17E0634-01) WW Sampled: 05/12/17 09:00 Received: 05/12/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703506	05/12/17	05/14/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/22/17 12:10

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: John Honea	CLS Work Order #: 17E0666 COC #: 178440
--	---	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17E0666-01) WW Sampled: 05/13/17 09:00 Received: 05/13/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703543	05/13/17	05/15/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/22/17 12:11

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: John Honea	CLS Work Order #: 17E0670 COC #: 178441
--	---	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17E0670-01) WW Sampled: 05/14/17 09:00 Received: 05/14/17 12:43</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703544	05/14/17	05/16/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/22/17 12:11

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: John Honea	CLS Work Order #: 17E0686 COC #: 178442
--	---	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff. (17E0686-01) WW Sampled: 05/15/17 09:00 Received: 05/15/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708554	05/15/17	05/19/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/23/17 10:32

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: John Honea

CLS Work Order #: 17E0734  
COC #: 178443

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff (17E0734-01) WW</b> Sampled: 05/16/17 09:00 Received: 05/16/17 12:45									
<b>Total Coliforms</b>	2.0	1.8	MPN/100 mL	1	1703595	05/16/17	05/19/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/24/17 12:07

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: John Honea

CLS Work Order #: 17E0791  
COC #: 178444

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17E0791-01) WW</b> <b>Sampled: 05/17/17 09:00</b> <b>Received: 05/17/17 13:00</b>									
<b>Total Coliforms</b>	2.0	1.8	MPN/100 mL	1	1703628	05/17/17	05/21/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510



# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: John Honea	CLS Work Order #: 17E0844 COC #: 178445
--	---	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff. (17E0844-02) WW Sampled: 05/18/17 08:30 Received: 05/18/17 12:45</b>									
Biochemical Oxygen Demand	20	3.0	mg/L	1	1708672	05/19/17	05/24/17	SM5210B	
Total Suspended Solids	10	5.0	"	"	1708723	05/22/17	05/22/17	SM2540D	
<b>MLSS (17E0844-03) WW Sampled: 05/18/17 08:30 Received: 05/18/17 12:45</b>									
Total Suspended Solids	2100	5.0	mg/L	1	1708723	05/22/17	05/22/17	SM2540D	

# CALIFORNIA LABORATORY SERVICES

Page 3 of 5

05/25/17 14:24

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: John Honea	CLS Work Order #: 17E0844 COC #: 178445
--	---	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert EFF (17E0844-01) WW Sampled: 05/18/17 09:00 Received: 05/18/17 12:45</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703663	05/18/17	05/20/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/26/17 11:33

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: John Honea	CLS Work Order #: 17E0903 COC #: 178446
--	---	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----------------	-------	----------	-------	----------	----------	--------	-------

**Tert. Effluent. (17E0903-01) WW** Sampled: 05/19/17 09:00 Received: 05/19/17 12:20

Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703702	05/19/17	05/23/17	SM 9221	
-----------------	------	-----	------------	---	---------	----------	----------	---------	--

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/30/17 11:54

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: John Honea	CLS Work Order #: 17E0933 COC #: 178447
--	---	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----------------	-------	----------	-------	----------	----------	--------	-------

Tert Eff (17E0933-01) WW Sampled: 05/20/17 09:00 Received: 05/20/17 12:35

Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703721	05/20/17	05/22/17	SM 9221	
-----------------	------	-----	------------	---	---------	----------	----------	---------	--

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/30/17 11:56

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: John Honea

CLS Work Order #: 17E0942  
COC #: 178448

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff. (17E0942-01) WW Sampled: 05/21/17 09:00 Received: 05/21/17 13:05</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708724	05/21/17	05/23/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/30/17 11:56

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: John Honea	CLS Work Order #: 17E0955 COC #: 178449
--	---	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17E0955-01) WW Sampled: 05/22/17 09:00 Received: 05/22/17 12:10</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703733	05/22/17	05/24/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/31/17 10:40

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: John Honea	CLS Work Order #: 17E1013 COC #: 178450
--	---	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17E1013-01) WW</b> Sampled: 05/23/17 09:00 Received: 05/23/17 12:55									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703774	05/23/17	05/25/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 5

06/01/17 14:47

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: John Honea	CLS Work Order #: 17E1082 COC #: 178451
--	---	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff. (17E1082-01) WW Sampled: 05/24/17 13:00 Received: 05/24/17 16:36</b>									
Biochemical Oxygen Demand	22	3.0	mg/L	1	1703834	05/25/17	05/30/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1703830	05/25/17	05/25/17	SM2540D	
<b>MLSS (17E1082-02) WW Sampled: 05/24/17 13:00 Received: 05/24/17 16:36</b>									
Total Suspended Solids	1600	5.0	mg/L	1	1703830	05/25/17	05/25/17	SM2540D	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510



# CALIFORNIA LABORATORY SERVICES

Page 3 of 5

06/01/17 14:47

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: John Honea CLS Work Order #: 17E1082 COC #: 178451
--	---

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff. (17E1082-01) WW Sampled: 05/24/17 13:00 Received: 05/24/17 16:36</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703811	05/24/17	05/26/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: John Honea	CLS Work Order #: 17E1115 COC #: 178452
--	---	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Mandarin St. (17E1115-01) Water</b> Sampled: 05/25/17 08:30 Received: 05/25/17 13:00									
E. Coli	Absent	0.0	N/A	1	1703846	05/25/17	05/26/17	SM 9223	
Residual Chlorine	1.30	0.10	mg/L	"	"	05/25/17	05/25/17	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	05/25/17	05/26/17	SM 9223	
<b>Mallard St. (17E1115-02) Water</b> Sampled: 05/25/17 08:45 Received: 05/25/17 13:00									
E. Coli	Absent	0.0	N/A	1	1703846	05/25/17	05/26/17	SM 9223	
Residual Chlorine	1.20	0.10	mg/L	"	"	05/25/17	05/25/17	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	05/25/17	05/26/17	SM 9223	
<b>Tert. Eff. (17E1115-03) WW</b> Sampled: 05/25/17 09:00 Received: 05/25/17 13:00									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703844	05/25/17	05/29/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

06/05/17 15:25

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: John Honea

CLS Work Order #: 17E1180  
COC #: 178453

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Effluent (17E1180-01) WW Sampled: 05/26/17 09:00 Received: 05/26/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703883	05/26/17	05/30/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

06/27/17 13:26

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17E1207 COC #: 178454
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17E1207-01) WW Sampled: 05/27/17 09:00 Received: 05/27/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703897	05/27/17	05/31/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

06/27/17 13:27

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17E1217 COC #: 178455
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff. (17E1217-01) WW Sampled: 05/28/17 09:00 Received: 05/28/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703898	05/28/17	05/30/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

06/27/17 13:27

National O&M, Inc  
 P.O. Box 21187  
 Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
 Project Number: [none]  
 Project Manager: Paul Bishop

CLS Work Order #: 17E1224  
 COC #: 178456

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff. (17E1224-01) WW Sampled: 05/29/17 09:00 Received: 05/29/17 13:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703899	05/29/17	05/31/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

06/06/17 11:29

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17E1265 COC #: 178457
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff (17E1265-01) WW Sampled: 05/30/17 09:00 Received: 05/30/17 12:45</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703928	05/30/17	06/01/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

06/07/17 12:43

National O&M, Inc  
 P.O. Box 21187  
 Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
 Project Number: [none]  
 Project Manager: Paul Bishop

CLS Work Order #: 17E1296  
 COC #: 178458

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff. (17E1296-01) WW Sampled: 05/31/17 09:00 Received: 05/31/17 12:50</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703982	05/31/17	06/02/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510