

## Electronic Report Transmittal Form

Attention: Brendan Kenny (916) 464-4635  
Central Valley Regional Water Quality Control Board  
11020 Sun Center Drive #200  
Rancho Cordova, Ca 95670-6114

Discharger: Wild Wings County Service Area  
Name of Facility: Wild Wings Water Recycling Facility  
MRP No: R5-2002-0077  
CIWQS Place ID: 272537  
County: Yolo

I am hereby submitting to the Central Valley Water Board the following information:

### **Check all that apply:**

Technical Report Title and Date Self-Monitoring Report for Wild Wings

Monthly Monitoring Report for the Month of April 2017

1<sup>st</sup> / 2<sup>nd</sup> / 3<sup>rd</sup> / 4<sup>th</sup> (**circle one**) Quarterly Monitoring Report for the year \_\_\_\_\_.

1<sup>st</sup> / 2<sup>nd</sup> (**circle one**) Semi-annual Monitoring Report for the year \_\_\_\_\_.

Annual Monitoring Report for the year \_\_\_\_\_.

### **Violation Notification:**

During the Monitoring period, there were / were not (circle one) any violations of the WDRs.

1. The Violations were:
2. Have the violations been corrected? Yes / No. If no, what will be done to correct the violations:

**Certification Statement:**

*"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."*

Signature: Paul Bishop

Phone: 540-492-2332

Printed Name: Paul Bishop

Date: 6/01/2017

**Electronic Report Submittal:**

To submit the electronic reports please do the following:

1. First, make a PDF copy of your report and include this form as the first page of the report.
2. Attach the PDF file to the email.
3. Send the email and PDF attachment to:  
[Centralvalleysacramento@waterboards.ca.gov](mailto:Centralvalleysacramento@waterboards.ca.gov) (Please note that in order to ensure your reports are cataloged correctly and routed to the appropriate Regional Board staff, only one report/attachment shall be included with each e-mail.)

DATE	Flow	Influent Monitoring								Secondary Monitoring						Tertiary Effluent Monitoring						Tertiary Effluent Monitoring					
		pH	EC	TDS	BOD <sub>5</sub>	TSS	pH	BOD <sub>5</sub>	TSS	Flow	Turbidity	CI <sub>2</sub>	Total Coliform	pH	BOD <sub>5</sub>	TSS	EC	TDS	TKN	Nitrate(N)							
2013	Influent	Influent	Influent	Influent	Influent	Influent	Influent	Influent	Influent	Flow	Turbidity	CI <sub>2</sub>	Total Coliform	pH	BOD <sub>5</sub>	TSS	EC	TDS	TKN	Nitrate(N)							
	GPD	pH units	umhos/cm	mg/L	mg/L	mg/L	mg/L	GPD	NTU	mg/L	MFCU/100 ml	pH units	mg/L	mg/L	umhos/cm	mg/L	mg/L	mg/L	mg/L								
	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Continuous	Continuous	Continuous	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab							
1-Apr	38,600	7.3	1427	860	73	49	7.33	2,253,826	1.54	>11	<1.8	7.6	ND	ND	1,213	800	1.1		0.7								
2-Apr	69,400	7.2	1278	860	73	49	7.24	3,256	1.00	>11	<1.8	7.5	ND	ND	1,213	800	1.1		0.7								
3-Apr	72,400	7.3	1613	860	73	49	7.42	213,220	2.40	>11	<1.8	7.7	ND	ND	1,213	800	1.1		0.7								
4-Apr	56,500																										
5-Apr	57,800																										
6-Apr	65,300	7.2	1482.0	880.0	73.0	49.0	7.24	91877	1.60	>11	<1.8	7.7	ND	ND	1213	800	1.1		0.74								
7-Apr	66,700							99534	1.60	>11	<1.8																
8-Apr	61,900							97440	1.60	>11	<1.8																
9-Apr	72,500							73344	2.00	>11	<1.8																
10-Apr	51,300							77823	2.00	>11	<1.8																
11-Apr	56,700							65310	1.50	>11	<1.8																
12-Apr	59,500	7.3	1613.0				7.42	64866	1.60	>11	<1.8																
13-Apr	63,800							63226	1.60	>11	<1.8																
14-Apr	55,500							65272	1.50	>11	<1.8	7.5	ND	ND													
15-Apr	16,200							77394	1.90	>11	<1.8																
16-Apr	129,000							35096	2.40	>11	<1.8																
17-Apr	34,000							96973	2.00	>11	<1.8																
18-Apr	56,700							47932	1.50	>11	<1.8																
19-Apr	53,200							39879	1.40	>11	<1.8																
20-Apr	57,800	7.2	1278.0					27355	2.00	>11	<1.8																
21-Apr	43,700							3256	1.00	>11	<1.8																
22-Apr	42,700							42822	1.20	>11	<1.8																
23-Apr	62,100							47101	1.00	>11	<1.8																
24-Apr	59,200							64706	1.90	>11	<1.8																
25-Apr	47,700							31175	2.00	>11	<1.8																
26-Apr	64,100							57885	1.90	>11	<1.8																
27-Apr	38,600	7.3	1333.0					65327	1.20	>11	<1.8	7.5	ND	ND													
28-Apr	60,200							49211	1.40	>11	<1.8																
29-Apr	42,100							52466	1.90	>11	<1.8																
30-Apr	79,000							3572	2.00	>11	<1.8																
TOTAL	1,734,200							76929	2.00	>11	<1.8																
AVG	57,807	7.3	1427	860	73	49	7.33	2,253,826	1.54	>11	<1.8	7.6	ND	ND	1,213	800	1.1		0.7								
MINIMUM	16,200	7.2	1278	860	73	49	7.24	3,256	1.00	>11	<1.8	7.5	ND	ND	1,213	800	1.1		0.7								
MAXIMUM	129,000	7.3	1613	860	73	49	7.42	213,220	2.40	>11	<1.8	7.7	ND	ND	1,213	800	1.1		0.7								
Requirement #	AVG .100 MG/L Min 6.5			0.00					AVG 2.0			Min 6.5															
Time Exceed	0.00	0.0	0.0	#DIV/0!					0.0		MED 2.2	0	Min 6.5														
Requirement #2	Max 8.5			0.00					Max 10		0	0	Max 10														
Time Exceeded	0.0			0.00					0.0		0	0	Max 10														

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all the attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations.

Signature of Principle Executive Officer or Authorized Agent: *Paul R. Bishop*

Recycled Water Storage Pond Monitoring										Recycled Water Area Monitoring										Surface Water Monitoring S-1									
Total N	NH <sub>3</sub> as N	Freeboard	D.O.	pH	EC	TDS	Total N	Flow	Rainfall	Acres	Application	Application	Nitrogen	TDS	pH	EC	TDS	Nitrate(N)	NH <sub>3</sub> as N	Flow									
mg/L	mg/L	Feet	mg/L	mg/L	umhos/cm	mg/L	mg/L	GPD	Inches	Applied	Rate	Measured	Total	Calculated	Irrigation	Irrigation	Irrigation	mg/L	mg/L	GPM									
Grab	Grab	Measurement	Grab	Grab	Grab	Grab	Grab	Measurement	Measured	Calculated	Calculated	Measured	Calculated	Calculated	Grab	Grab	Grab	Grab	Grab	Grab	Estimated								
Monthly	Monthly	Weekly	Weekly	Weekly	Monthly	Monthly	Monthly	Weekly	Daily	Daily	Daily	Daily	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Weekly								
		7.16						111592	0.00	68	1641	9pm-11am																	
		7.15						111592	0.00	68	1641	9pm-11am																	
		7.17						94178	0.00	68	1395	9pm-11am																	
		7.06						94178	0.00	68	1385	9pm-11am																	
		6.81						111592	0.00	68	1641	9pm-11am																	
1.9	0.19	6.93	7.49	8.5	1211	590	1.0	98161	0.82	68	1444	9pm-11am	18.7	11027															
		7.02						98161	1.13	68	1444	9pm-11am																	
		6.82						0	0.09	0	0	9pm-11am																	
		6.72						0	0.00	0	0	9pm-11am																	
		6.51						0	0.00	0	0	9pm-11am																	
		6.44						0	0.13	0	0	9pm-11am																	
		6.92	5.4	7.8	1141			0	0.00	0	0	9pm-11am																	
		7.14						10789	0.06	18	599	9pm-11am																	
		6.98						0	0.00	0	0	9pm-11am																	
		6.83						0	0.00	0	0	9pm-11am																	
		6.83						10789	0.27	18	599	9pm-11am																	
		6.8						0	0.09	0	0	9pm-11am																	
		6.78	6.8	7.6	1209			0	0.07	0	0	9pm-11am																	
		6.67						166462	0.05	58	2870	9pm-11am																	
		7.06						0	0.05	0	0	9pm-11am																	
		6.99						114141	0.00	38	3004	9pm-11am																	
		7.17						114141	0.00	38	3004	9pm-11am																	
		6.58						114141	0.00	38	3004	9pm-11am																	
		7.66						114141	0.00	38	3004	9pm-11am																	
		7.98						116622	0.02	38	3069	9pm-11am																	
		7.41	5.9	7.5	1234			145813	0.00	58	2514	9pm-11am																	
		6.99						145813	0.00	58	2514	9pm-11am																	
		7.26						145813	0.00	68	2514	9pm-11am																	
		7.6						145813	0.00	58	2514	9pm-11am																	
		7.79						145813	0.00	68	2514	9pm-11am																	
1.9	0.2	7.04	6.4	7.9	1199	590	1.0	2241417	3	36	1394	18.7	11027																
1.9	0.2	6.44	5.4	7.5	1141	590	1.0	74714	0.09	0	0	18.7	11027																
1.9	0.2	7.98	7.5	8.5	1234	590	1.0	0	0.00	0	0	18.7	11027																
								166462	1.13	68	3069	18.7	11027																

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

04/10/17 14:37

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D0003  
COC #: 173158

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17D0003-01) WW Sampled: 04/01/17 09:00 Received: 04/01/17 11:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702399	04/01/17	04/03/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

04/10/17 14:38

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D0015  
COC #: 173159

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff (17D0015-01) WW Sampled: 04/02/17 09:00 Received: 04/02/17 11:50</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702400	04/02/17	04/04/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

04/10/17 15:00

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D0032  
COC #: 173160

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff (17D0032-01) WW Sampled: 04/03/17 09:00 Received: 04/03/17 12:40</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702410	04/03/17	04/05/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

04/11/17 16:07

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D0181  
COC #: 173161

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff. (17D0181-01) WW Sampled: 04/04/17 09:00 Received: 04/04/17 14:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702446	04/04/17	04/06/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510



# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17D0186 COC #: 173162
--	--	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff. (17D0186-02) WW</b> <b>Sampled: 04/05/17 07:00</b> <b>Received: 04/05/17 12:10</b>									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1702460	04/05/17	04/10/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1702525	04/06/17	04/06/17	SM2540D	
<b>MLSS (17D0186-03) WW</b> <b>Sampled: 04/05/17 07:10</b> <b>Received: 04/05/17 12:10</b>									
<b>Total Suspended Solids</b>	<b>2000</b>	5.0	mg/L	1	1702525	04/06/17	04/06/17	SM2540D	

# CALIFORNIA LABORATORY SERVICES

Page 3 of 5

04/12/17 15:06

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D0186  
COC #: 173162

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17D0186-01) WW Sampled: 04/05/17 09:00 Received: 04/05/17 12:10</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702489	04/05/17	04/07/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

# CALIFORNIA LABORATORY SERVICES

Page 3 of 4

04/13/17 14:30

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D0274  
COC #: 173163

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert EFF (17D0274-01) WW Sampled: 04/06/17 09:00 Received: 04/06/17 12:10</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702536	04/06/17	04/08/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc  
 P.O. Box 21187  
 Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
 Project Number: [none]  
 Project Manager: Paul Bishop

CLS Work Order #: 17D0272  
 COC #: 173164

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Wild Wings Inf. (17D0272-01) WW Sampled: 04/06/17 07:00 Received: 04/06/17 12:10</b>									
Biochemical Oxygen Demand	73	3.0	mg/L	1	1702509	04/06/17	04/11/17	SM5210B	
Total Dissolved Solids	860	10	"	"	1702566	04/07/17	04/10/17	SM2540C	
Total Suspended Solids	49	5.0	"	"	1702567	04/07/17	04/07/17	SM2540D	
<b>2nd EFF (17D0272-02) WW Sampled: 04/06/17 07:00 Received: 04/06/17 12:10</b>									
Biochemical Oxygen Demand	25	3.0	mg/L	1	1702509	04/06/17	04/11/17	SM5210B	
Total Suspended Solids	17	5.0	"	"	1702567	04/07/17	04/07/17	SM2540D	
<b>Tert EFF (17D0272-03) WW Sampled: 04/06/17 07:00 Received: 04/06/17 12:10</b>									
Ammonia as N	0.19	0.10	mg/L	1	1702565	04/07/17	04/07/17	SM4500-NH3C	
Biochemical Oxygen Demand	ND	3.0	"	"	1702509	04/06/17	04/11/17	SM5210B	
Nitrate as N	0.74	0.40	"	"	1702504	04/06/17	04/07/17	EPA 300.0	
Nitrate/Nitrite as N	0.74	0.40	"	"	"	"	"	"	
Total Dissolved Solids	800	10	"	"	1702566	04/07/17	04/10/17	SM2540C	
Total Kjeldahl Nitrogen	1.1	0.20	"	"	1702638	04/11/17	04/11/17	SM4500-NH3C	
Total Nitrogen	1.9	0.40	"	"	1702641	04/11/17	04/11/17	EPA 351.3/300	
Total Suspended Solids	12	5.0	"	"	1702567	04/07/17	04/07/17	SM2540D	
<b>MISS (17D0272-04) WW Sampled: 04/06/17 07:00 Received: 04/06/17 12:10</b>									
Total Suspended Solids	1700	5.0	mg/L	1	1702567	04/07/17	04/07/17	SM2540D	
<b>Storage Pond (17D0272-05) Wastewater Sampled: 04/06/17 07:00 Received: 04/06/17 12:10</b>									
Nitrate/Nitrite as N	ND	0.40	mg/L	1	1702504	04/06/17	04/07/17	EPA 300.0	
Total Dissolved Solids	590	10	"	"	1702566	04/07/17	04/10/17	SM2540C	
Total Kjeldahl Nitrogen	1.0	0.20	"	"	1702638	04/11/17	04/11/17	SM4500-NH3C	
Total Nitrogen	1.0	0.40	"	"	1702641	04/11/17	04/11/17	EPA 351.3/300	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

04/14/17 14:18

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D0331  
COC #: 173165

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert EFF (17D0331-01) WW Sampled: 04/07/17 09:00 Received: 04/07/17 11:45</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702568	04/07/17	04/09/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

04/17/17 15:19

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D0397  
COC #: 173166

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>WW Tert eff (17D0397-01) WW Sampled: 04/08/17 09:00 Received: 04/08/17 12:40</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702593	04/08/17	04/10/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

04/17/17 15:20

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D0400  
COC #: 173167

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>WW tert. Eff. (17D0400-01) WW Sampled: 04/09/17 09:00 Received: 04/09/17 12:15</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702594	04/09/17	04/11/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17D0428 COC #: 173168
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>WW Tert. Eff. (17D0428-01) WW Sampled: 04/10/17 09:00 Received: 04/10/17 12:50</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702601	04/10/17	04/12/17	SM 9221	



# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

04/18/17 14:15

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D0504  
COC #: 180847

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>WW tert. Eff. (17D0504-01) WW Sampled: 04/11/17 09:00 Received: 04/11/17 11:45</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702643	04/11/17	04/13/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17D0592 COC #: 180848
--	--	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17D0592-01) WW Sampled: 04/12/17 09:00 Received: 04/12/17 13:20</b>									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1702734	04/13/17	04/18/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1702749	04/14/17	04/14/17	SM2540D	
<b>MLSS (17D0592-02) WW Sampled: 04/12/17 08:00 Received: 04/12/17 13:20</b>									
<b>Total Suspended Solids</b>	<b>2000</b>	5.0	mg/L	1	1702749	04/14/17	04/14/17	SM2540D	

# CALIFORNIA LABORATORY SERVICES

Page 3 of 5

04/26/17 12:24

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D0592  
COC #: 180848

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17D0592-01) WW Sampled: 04/12/17 09:00 Received: 04/12/17 13:20</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702687	04/12/17	04/14/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

04/20/17 14:18

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D0689  
COC #: 180849

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17D0689-01) WW Sampled: 04/13/17 09:00 Received: 04/13/17 13:00</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702730	04/13/17	04/15/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

04/19/17 11:56

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D0740  
COC #: 180850

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17D0740-01) WW Sampled: 04/14/17 09:00 Received: 04/14/17 11:45</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702773	04/14/17	04/16/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17D0775 COC #: 180851
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert EFF (17D0775-01) WW Sampled: 04/15/17 09:00 Received: 04/15/17 12:00</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702795	04/15/17	04/17/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

04/17 16.37

National O&M, Inc	Project: Wild WinPs RecyclinP Facility	
JobBox: 1187	Project Number: [none]	CLS Work Order #: 17D0785
Roanoke, VA : 4018	Project Manager: Paul Bishop	COC #: 18086:

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	ReportinP Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17D0785-01) WW Sampled: 04/16/17 09:00 Received: 04/16/17 11:40</b>									
Total Coliforms	<1	1	MJN/100 mL	1	170: 795	04/15/17	04/18/17	SM 9: : 1	

CA HO2 S ELAJ Accreditation/Registration Number 1: 33

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

04/24/17 12:00

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D0806  
COC #: 180853

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17D0806-01) WW Sampled: 04/17/17 09:00 Received: 04/17/17 13:25</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702815	04/17/17	04/19/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510



# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

04/25/17 13:59

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D0857  
COC #: 180854

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17D0857-01) WW Sampled: 04/18/17 09:00 Received: 04/18/17 12:15</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702846	04/18/17	04/20/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

06/01/17 08:27

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D0923  
COC #: 180856

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17D0923-01) WW Sampled: 04/19/17 09:00 Received: 04/19/17 13:00</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702885	04/19/17	04/21/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

04/27/17 14:47

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D0971  
COC #: 180855

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17D0971-01) WW Sampled: 04/20/17 09:00 Received: 04/20/17 12:20</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702909	04/20/17	04/22/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17D1039 COC #: 180858
--	--	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17D1039-01) WW Sampled: 04/21/17 08:00 Received: 04/21/17 11:45</b>									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1702922	04/21/17	04/26/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1702983	04/24/17	04/24/17	SM2540D	
<b>MLSS (17D1039-02) WW Sampled: 04/21/17 08:13 Received: 04/21/17 11:45</b>									
Total Suspended Solids	1900	5.0	mg/L	1	1702983	04/24/17	04/24/17	SM2540D	

# CALIFORNIA LABORATORY SERVICES

Page 3 of 5

04/28/17 14:50

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D1039  
COC #: 180858

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17D1039-03) WW</b> <b>Sampled: 04/21/17 09:00</b> <b>Received: 04/21/17 11:45</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702932	04/21/17	04/23/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/01/17 13:52

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D1067  
COC #: 180859

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>TERT EFF (17D1067-01) WW</b> <b>Sampled: 04/22/17 09:00</b> <b>Received: 04/22/17 12:00</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702972	04/22/17	04/24/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/01/17 13:59

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D1075  
COC #: 180860

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff (17D1075-01) WW</b> Sampled: 04/23/17 09:00 Received: 04/23/17 11:45									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702973	04/23/17	04/25/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17D1091 COC #: 180861
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff (17D1091-01) WW Sampled: 04/24/17 09:00 Received: 04/24/17 11:35</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1702979	04/24/17	04/26/17	SM 9221	



# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/02/17 14:43

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D1138  
COC #: 180862

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff. (17D1138-01) WW Sampled: 04/25/17 09:00 Received: 04/25/17 12:35</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703012	04/25/17	04/27/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17D1200 COC #: 180863
--	--	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>MLSS (17D1200-02) WW Sampled: 04/26/17 07:30 Received: 04/26/17 12:20</b>									
Total Suspended Solids	2400	5.0	mg/L	1	1703076	04/27/17	04/27/17	SM2540D	
<b>Tert EFF (17D1200-03) WW Sampled: 04/26/17 07:35 Received: 04/26/17 12:20</b>									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1703075	04/27/17	05/02/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1703076	04/27/17	04/27/17	SM2540D	

# CALIFORNIA LABORATORY SERVICES

Page 3 of 5

05/03/17 15:25

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D1200  
COC #: 180863

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert EFF (17D1200-01) WW Sampled: 04/26/17 09:00 Received: 04/26/17 12:20</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703041	04/26/17	04/28/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 3 of 4

05/04/17 13:54

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D1257  
COC #: 180864

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert eFF (17D1257-01) WW Sampled: 04/27/17 09:00 Received: 04/27/17 12:10</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703087	04/27/17	04/29/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 3 of 4

05/04/17 16:39

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17D1290  
COC #: 173103

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert EFF (17D1290-01) WW Sampled: 04/28/17 09:00 Received: 04/28/17 12:00</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703116	04/28/17	04/30/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/08/17 14:07

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17E0005  
COC #: 180941

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>TERT EFF (17E0005-01) WW Sampled: 04/29/17 09:00 Received: 04/29/17 11:50</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703142	04/29/17	05/01/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

[www.californialab.com](http://www.californialab.com)

916-638-7301

Fax: 916-638-4510

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

05/08/17 14:12

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17E0009  
COC #: 180942

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff (17E0009-01) WW Sampled: 04/30/17 09:00 Received: 04/30/17 11:50</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1703143	04/30/17	05/04/17	SM 9221	

CA DOHS ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510