## Quarterly Report for Disinfectant Residuals Compliance For Systems Using Chlorine or Chloramines

System Name:	WILD WINGS	System No.:	5710011
Cycloni Hanio.		eyeten rte.	0/10011

Calendar Year:

2017

Quarter:

3

1st Quarter			
Month		Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
	April		1.00
	Мау		1.10
	June		0.90
Year	July		1.00
<sup>o</sup> revious Year	August		1.00
Previ	September		1.10
	October		1.00
	November		1.00
	December		1.00
ear	January	2	1.15
Current Year	February	2	1.15
Curr	March	2	1.35
Rı	Running Annual Average (RAA):		1.06
Meets standard? (i.e. RAA $\leq$ MRDL of 4.0 mg/L as Cl <sub>2</sub> )		✓ Yes □ No	

2nd Quarter			
	Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
	July		1.00
Previous Year	August		1.00
	September		1.10
	October		1.00
	November		1.00
	December		1.00
	January		1.15
Current Year	February		1.15
	March		1.35
	April	2	1.10
	May	2	1.25
	June	0	1.27
R١	Running Annual Average (RAA):		1.11
Meets standard? (i.e. RAA <u>&lt;</u> MRDL of 4.0 mg/L as Cl <sub>2</sub> )		✓ Yes □ No	

3rd Quarter			
Month		Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
s Yr	October		1.00
Previous Yr	November		1.00
Pre	December		1.00
	January		1.15
	February		1.15
	March		1.35
ear	April		1.10
Current Yea	May		1.25
Curr	June		1.27
	July	10	1.10
	August	2	1.05
	September		0.90
Rı	Running Annual Average (RAA):		1.11
Meets standard?		✓ Yes	
(i.e. RAA $\leq$ MRDL of 4.0 mg/L as Cl <sub>2</sub> )		No No	

4th Quarter			
Month		Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
	January		1.15
Current Year	February		1.15
	March		1.35
	April		1.10
	May		1.25
	June		1.27
<sup>້</sup> ຍ July			1.10
Ō	August		1.05
	September		0.90
	October		0.80
	November		0.80
	December		1.80
Running Annual Average (RAA):		1.14	
Meets standard? (i.e. RAA <u>&lt;</u> MRDL of 4.0 mg/L as Cl <sub>2</sub> )		✓ Yes □ No	

Comments:

Signature:

P. Bishop

Date:

9/6/2017