

Quarterly Report for Disinfectant Residuals Compliance For Systems Using Chlorine or Chloramines

System Name: WILD WINGS System No.: 5710011

Calendar Year: 2017 Quarter: 2

1st Quarter			
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)	
Previous Year	April	1.00	
	May	1.10	
	June	0.90	
	July	1.00	
	August	1.00	
	September	1.10	
	October	1.00	
	November	1.00	
	December	1.00	
	Current Year	January	2
		February	2
		March	2
Running Annual Average (RAA):		1.06	
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

2nd Quarter			
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)	
Previous Year	July	1.00	
	August	1.00	
	September	1.10	
	October	1.00	
	November	1.00	
	December	1.00	
	Current Year	January	1.15
		February	1.15
		March	1.35
		April	2
		May	2
		June	0.80
Running Annual Average (RAA):		1.08	
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

3rd Quarter		
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
Previous Year	October	1.00
	November	1.00
	December	1.00
Current Year	January	1.15
	February	1.15
	March	1.35
	April	1.10
	May	1.25
	June	0.80
	July	0.80
	August	0.81
	September	0.90
Running Annual Average (RAA):		1.03
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

4th Quarter		
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
Current Year	January	1.15
	February	1.15
	March	1.35
	April	1.10
	May	1.25
	June	0.80
	July	0.80
	August	0.81
	September	0.90
	October	0.80
	November	0.80
	December	1.80
Running Annual Average (RAA):		1.06
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Comments:

Signature: *Paul Bishop*

Date: 6/9/2017