

## Electronic Report Transmittal Form

Attention: Brendan Kenny (916) 464-4635  
Central Valley Regional Water Quality Control Board  
11020 Sun Center Drive #200  
Rancho Cordova, Ca 95670-6114

Discharger: Wild Wings County Service Area  
Name of Facility: Wild Wings Water Recycling Facility  
MRP No: R5-2002-0077  
CIWQS Place ID: 272537  
County: Yolo

I am hereby submitting to the Central Valley Water Board the following information:

### **Check all that apply:**

Technical Report Title and Date **Self-Monitoring Report for Wild Wings**

Monthly Monitoring Report for the Month of **September 2017**

1<sup>st</sup> / 2<sup>nd</sup> / 3<sup>rd</sup> / 4<sup>th</sup> (**circle one**) Quarterly Monitoring Report for the year\_\_\_\_\_.

1<sup>st</sup> / 2<sup>nd</sup> (**circle one**) Semi-annual Monitoring Report for the year\_\_\_\_\_.

Annual Monitoring Report for the year\_\_\_\_\_.

### **Violation Notification:**

During the Monitoring period, there were / **were not** (circle one) any violations of the WDRs.

1. The Violations were:
  
  
  
  
  
  
  
  
  
  
2. Have the violations been corrected? Yes / No. If no, what will be done to correct the violations:

**Certification Statement:**

*"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."*

Signature: Paul Bishop

Phone: **540-492-2332**

Printed Name: **Paul Bishop**

Date: **10/31/2017**

**Electronic Report Submittal:**

To submit the electronic reports please do the following:

1. First, make a PDF copy of your report and include this form as the first page of the report.
2. Attach the PDF file to the email.
3. Send the email and PDF attachment to:  
[Centralvalleysacramento@waterboards.ca.gov](mailto:Centralvalleysacramento@waterboards.ca.gov) (Please note that in order to ensure your reports are cataloged correctly and routed to the appropriate Regional Board staff, only one report/attachment shall be included with each e-mail.)

DATE	Influent Monitoring						Secondary Monitoring			Tertiary Effluent Monitoring				Tertiary Effluent Monitoring					TKN	Nitrate(N)	
	Flow	pH	EC	TDS	BOD <sub>5</sub>	TSS	pH	BOD <sub>5</sub>	TSS	Flow	Turbidity	Cl2	Total Coliform	pH	BOD <sub>5</sub>	TSS	EC	TDS			Effluent
2013	Influent	Influent	Influent	Influent	Influent	Influent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent
	GPD	pH units	umhos/cm	mg/L	mg/L	mg/L	pH units	mg/L	mg/L	GPD	NTU	mg/L	MPN/100 ml	pH units	mg/L	mg/L	umhos/cm	mg/L	mg/L	mg/L	mg/L
	Metered	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Continuous	Continuous	Continuous	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab
	Daily	Weekly	Weekly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Daily	Daily	Daily	Daily	Weekly	Weekly	Weekly	Monthly	Monthly	Monthly	Monthly	Monthly
1-Sep	124200	7.4	1080.0				7.2			157,203	1.00	>11.0	<1.8	7.3	ND	5.8	1077				
2-Sep	65200									244,956	0.2	>11.0	<1.8								
3-Sep	64200									217,724	0.7	>11.0	<1.8								
4-Sep	59000									237,992	0.9	>11.0	<1.8								
5-Sep	58700									259,134	1.4	>11.0	<1.8								
6-Sep	79200	7.3	1012.0				7.1			272,649	1.70	>11.0	<1.8	7.2							
7-Sep	134700									215,566	1.4	>11.0	<1.8								
8-Sep	57100									265,134	1	>11.0	<1.8		3.5	7.0					
9-Sep	31000									229,290	1.6	>11.0	<1.8								
10-Sep	12100									214,271	1.2	>11.0	<1.8								
11-Sep	27200									274,721	1.8	>11.0	<1.8								
12-Sep	110200	7.4	1015.0							217,672	2	>11.0	<1.8	7.4							
13-Sep	89700									243,727	1.7	>11.0	<1.8								
14-Sep	97900									257,611	1.4	>11.0	<1.8								
15-Sep	5600									121,791	1.9	>11.0	<1.8								
16-Sep	51200									122,933	1.8	>11.0	<1.8		5.6	7.0					
17-Sep	50100									102,121	1.5	>11.0	<1.8								
18-Sep	23800	7.5	1022.0							208,130	1.3	>11.0	<1.8	7.1							
19-Sep	57900									50,217	1	>11.0	<1.8								
20-Sep	54400									51,299	1.1	>11.0	<1.8								
21-Sep	48700									56114	1.2	>11.0	<1.8		ND	ND					
22-Sep	85000									54871	1.8	>11.0	<1.8								
23-Sep	57600									52729	1.9	>11.0	<1.8								
24-Sep	47700	7.3	1047.0							56767	2	>11.0	<1.8	7.0							
25-Sep	51200									51747	1.7	>11.0	<1.8								
26-Sep	53700									50700	1.4	>11.0	<1.8								
27-Sep	47700									124651	1.50	>11.0	<1.8								
28-Sep	50000									107672	1.80	>11.0	<1.8								
29-Sep	99200	7.1	1031.0	710	240	620		4.9	11	123477	2.00	>11.0	<1.8	7.4	ND	ND		640	0.98	22	
30-Sep	53700									18153	1.80	>11.0	<1.8								
TOTAL	1,847,900									4,661,022											
AVG.	61,597	7.3	1035	710.00	240.00	620.00	7.15	4.90	11.00	300,711	1.46	#DIV/0!	#DIV/0!	7.2	4.55	6.60	1,077	640	0.98	22.0	
MINIMUM	5,600	7.1	1012.0	710.00	240.00	620.00	7.10	4.90	11.00	18153.0	0.2	0.0	0.00	7.0	3.50	5.80	1,077	640	0.98	22.0	
MAXIMUM	134,700	8	1,080	710.00	240.00	620.00	7.20	4.90	11.00	4,661,022	2	0	0.00	7	5.60	7.00	1,077	640	0.98	22.0	
Requirement #1	AVG.-100 MG	Min 6.5					Min 6.5				AVG. 2.0	Min 1.0	MED 2.2	Min 6.5							
Times Exceeded	0	0	0				0				0	1	0	0							
Requirement #2		Max 8.5		Max 1500			Max 8.5				Max 10		Max 23	Max 8.5	Max 10	Max 10			Max 1500		
Times Exceeded		0		0			0				0		0.0	0	0	0			0		
Times Exceeded		0		0			0				0		0.0	0	0	0			0		

*Paul Bishop*

Signature of Principle Executive Officer or Authorized Agent



# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710009 COC #: 181431
--	--	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (1710009-02) WW    Sampled: 09/01/17 09:00    Received: 09/01/17 12:10</b>									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1706649	09/01/17	09/06/17	SM5210B	
<b>Total Suspended Solids</b>	<b>5.8</b>	5.0	"	"	1706695	09/05/17	09/05/17	SM2540D	
<b>MLSS (1710009-03) WW    Sampled: 09/01/17 09:00    Received: 09/01/17 12:10</b>									
<b>Total Suspended Solids</b>	<b>1300</b>	5.0	mg/L	1	1706695	09/05/17	09/05/17	SM2540D	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710009 COC #: 181431
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (1710009-01) WW Sampled: 09/01/17 09:00 Received: 09/01/17 12:10</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706669	09/01/17	09/03/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710053 COC #: 181432
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (1710053-01) WW    Sampled: 09/02/17 09:00    Received: 09/02/17 11:45</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706692	09/02/17	09/04/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710060 COC #: 181433
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (1710060-01) WW Sampled: 09/03/17 09:00 Received: 09/03/17 12:18</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706693	09/03/17	09/05/17	SM 9221	



# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710071 COC #: 181434
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (1710071-01) WW Sampled: 09/04/17 09:00 Received: 09/04/17 13:20</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706694	09/04/17	09/06/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710085 COC #: 181435
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (1710085-01) WW Sampled: 09/05/17 09:00 Received: 09/05/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706708	09/05/17	09/07/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710165 COC #: 179938
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (1710165-01) WW Sampled: 09/06/17 09:00 Received: 09/06/17 12:00</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706756	09/06/17	09/08/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710267 COC #: 179939
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff (1710267-01) WW Sampled: 09/07/17 09:00 Received: 09/07/17 12:40</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706800	09/07/17	09/09/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17I0336 COC #: 179940
--	--	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17I0336-02) WW</b> Sampled: 09/08/17 09:00 Received: 09/08/17 12:05									
Biochemical Oxygen Demand	3.5	3.0	mg/L	1	1706852	09/10/17	09/15/17	SM5210B	
Total Suspended Solids	7.0	5.0	"	"	1706869	09/11/17	09/11/17	SM2540D	
<b>MLSS (17I0336-03) WW</b> Sampled: 09/08/17 09:00 Received: 09/08/17 12:05									
Total Suspended Solids	950	5.0	mg/L	1	1706869	09/11/17	09/11/17	SM2540D	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710336 COC #: 179940
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (1710336-01) WW Sampled: 09/08/17 09:00 Received: 09/08/17 12:05</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706838	09/08/17	09/10/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710361 COC #: 179941
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert EFF (1710361-01) WW Sampled: 09/09/17 09:00 Received: 09/09/17 12:09</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706875	09/09/17	09/11/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710373 COC #: 179942
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (1710373-01) WW Sampled: 09/10/17 09:00 Received: 09/10/17 12:22</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706876	09/10/17	09/12/17	SM 9221	



# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710387 COC #: 179943
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (1710387-01) WW Sampled: 09/11/17 09:00 Received: 09/11/17 12:40</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706880	09/11/17	09/13/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710453 COC #: 179944
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (1710453-01) WW Sampled: 09/12/17 09:00 Received: 09/12/17 12:50</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706920	09/12/17	09/14/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

09/20/17 13:27

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 1710519  
COC #: 179945

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (1710519-01) WW Sampled: 09/13/17 09:00 Received: 09/13/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1706962	09/13/17	09/15/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710583 COC #: 179946
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (1710583-01) WW Sampled: 09/14/17 09:00 Received: 09/14/17 12:25</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707012	09/14/17	09/16/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710646 COC #: 179947
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (1710646-01) WW Sampled: 09/15/17 09:00 Received: 09/15/17 15:05</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707067	09/15/17	09/17/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710673 COC #: 180873
--	--	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (1710673-02) WW Sampled: 09/16/17 08:30 Received: 09/16/17 12:11</b>									
Biochemical Oxygen Demand	5.6	3.0	mg/L	1	1707073	09/17/17	09/22/17	SM5210B	
Total Suspended Solids	7.0	5.0	"	"	1707118	09/19/17	09/19/17	SM2540D	
<b>MLSS (1710673-03) WW Sampled: 09/16/17 08:30 Received: 09/16/17 12:11</b>									
Total Suspended Solids	730	5.0	mg/L	1	1707118	09/19/17	09/19/17	SM2540D	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710673 COC #: 180873
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (1710673-01) WW Sampled: 09/16/17 09:00 Received: 09/16/17 12:11</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707090	09/16/17	09/18/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710675 COC #: 180874
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (1710675-01) WW Sampled: 09/17/17 09:00 Received: 09/17/17 12:11</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707091	09/17/17	09/19/17	SM 9221	



# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710705 COC #: 180875
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (1710705-01) WW Sampled: 09/18/17 09:00 Received: 09/18/17 13:53</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707103	09/18/17	09/20/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710741 COC #: 180876
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (1710741-01) WW Sampled: 09/19/17 09:00 Received: 09/19/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707135	09/19/17	09/21/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710839 COC #: 181466
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (1710839-01) WW Sampled: 09/20/17 09:00 Received: 09/20/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707178	09/20/17	09/22/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710909 COC #: 181467
--	--	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (1710909-02) WW Sampled: 09/21/17 08:30 Received: 09/21/17 12:15</b>									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1707253	09/22/17	09/27/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1707240	09/22/17	09/22/17	SM2540D	
<b>MLSS (1710909-03) WW Sampled: 09/21/17 08:40 Received: 09/21/17 12:15</b>									
Total Suspended Solids	720	5.0	mg/L	1	1707240	09/22/17	09/22/17	SM2540D	

# CALIFORNIA LABORATORY SERVICES

Page 3 of 5

09/28/17 14:01

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710909 COC #: 181467
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (1710909-01) WW Sampled: 09/21/17 09:00 Received: 09/21/17 12:15</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707219	09/21/17	09/23/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710951 COC #: 181468
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (1710951-01) WW Sampled: 09/22/17 09:00 Received: 09/22/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707251	09/22/17	09/24/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710979 COC #: 181469
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (1710979-01) WW    Sampled: 09/23/17 09:10    Received: 09/23/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707275	09/23/17	09/25/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710987 COC #: 181470
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (1710987-01) WW    Sampled: 09/24/17 09:00    Received: 09/24/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707276	09/24/17	09/26/17	SM 9221	



# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1710999 COC #: 181471
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (1710999-01) WW Sampled: 09/25/17 09:00 Received: 09/25/17 12:00</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707293	09/25/17	09/27/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1711061 COC #: 181472
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (1711061-01) WW Sampled: 09/26/17 09:00 Received: 09/26/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707327	09/26/17	09/28/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1711109 COC #: 181473
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (1711109-01) WW Sampled: 09/27/17 09:00 Received: 09/27/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707363	09/27/17	09/29/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 1711180 COC #: 181475
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (1711180-01) WW Sampled: 09/28/17 09:00 Received: 09/28/17 12:00</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707395	09/28/17	09/30/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

10/06/17 14:13

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17I1225 COC #: 181477
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17I1225-01) WW Sampled: 09/29/17 09:00 Received: 09/29/17 12:15</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707429	09/29/17	10/01/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17I1228 COC #: 181476
--	--	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Inf. (17I1228-01) WW Sampled: 09/29/17 09:00 Received: 09/29/17 12:15</b>									
Biochemical Oxygen Demand	240	3.0	mg/L	1	1707408	09/29/17	10/04/17	SM5210B	
Total Dissolved Solids	710	10	"	"	1707461	10/02/17	10/03/17	SM2540C	
Total Suspended Solids	620	5.0	"	"	1707460	10/02/17	10/02/17	SM2540D	
<b>2nd Inf. (17I1228-02) WW Sampled: 09/29/17 09:00 Received: 09/29/17 12:15</b>									
Biochemical Oxygen Demand	4.9	3.0	mg/L	1	1707408	09/29/17	10/04/17	SM5210B	
Total Suspended Solids	11	5.0	"	"	1707460	10/02/17	10/02/17	SM2540D	
<b>tert. Eff. (17I1228-03) WW Sampled: 09/29/17 09:00 Received: 09/29/17 12:15</b>									
Ammonia as N	0.11	0.10	mg/L	1	1707464	10/02/17	10/02/17	SM4500-NH3F-1997	
Biochemical Oxygen Demand	ND	3.0	"	"	1707408	09/29/17	10/04/17	SM5210B	
Nitrate as N	22	2.0	"	5	1707406	09/29/17	09/29/17	EPA 300.0	
Nitrate/Nitrite as N	22	2.0	"	"	"	"	"	"	
Total Dissolved Solids	640	10	"	1	1707461	10/02/17	10/03/17	SM2540C	
Total Kjeldahl Nitrogen	0.98	0.20	"	"	1707472	10/02/17	10/02/17	SM4500-NH3F-1997	
Total Nitrogen	23	0.40	"	"	1707477	10/02/17	10/02/17	EPA 351.3/300	
Total Suspended Solids	ND	5.0	"	"	1707460	10/02/17	10/02/17	SM2540D	
<b>MLSS (17I1228-04) WW Sampled: 09/29/17 09:00 Received: 09/29/17 12:15</b>									
Total Suspended Solids	980	5.0	mg/L	1	1707460	10/02/17	10/02/17	SM2540D	
<b>Storage Pond (17I1228-05) TWW Sampled: 09/29/17 09:00 Received: 09/29/17 12:15</b>									
Nitrate/Nitrite as N	3.6	2.0	mg/L	5	1707406	09/29/17	09/29/17	EPA 300.0	
Total Dissolved Solids	500	10	"	1	1707461	10/02/17	10/03/17	SM2540C	
Total Kjeldahl Nitrogen	1.3	1.0	"	5	1707472	10/02/17	10/02/17	SM4500-NH3F-1997	
Total Nitrogen	4.9	0.40	"	1	1707477	10/02/17	10/02/17	EPA 351.3/300	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

10/09/17 12:50

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J0011 COC #: 181479
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17J0011-01) WW</b> <b>Sampled: 09/30/17 09:00</b> <b>Received: 09/30/17 12:12</b>									
<b>Total Coliforms</b>	<b>1.8</b>	1.8	MPN/100 mL	1	1707465	09/30/17	10/03/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings - Sludge Sample Project Number: [none] Project Manager: Jeff Lambeth	CLS Work Order #: 1710454 COC #: 183159
--	--	--

## CAM 17 Metals

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Grab #1 thru Grab #4 (Comp) (1710454-05) Sludge Sampled: 09/12/17 08:00 Received: 09/12/17 12:50</b>									
Antimony	ND	2.7	mg/kg dry	5	1706988	09/14/17	09/14/17	EPA 6020/7000	
Antimony	ND	2.5	mg/kg	"	"	"	"	EPA 6020	
<b>Arsenic</b>	<b>6.6</b>	1.0	"	"	"	"	"	"	
<b>Arsenic</b>	<b>7.1</b>	1.1	mg/kg dry	"	"	"	"	EPA 6020/7000	
<b>Barium</b>	<b>27</b>	1.0	mg/kg	"	"	"	"	EPA 6020	
<b>Barium</b>	<b>29</b>	1.1	mg/kg dry	"	"	"	"	EPA 6020/7000	
Beryllium	ND	1.1	"	"	"	"	"	"	
Beryllium	ND	1.0	mg/kg	"	"	"	"	EPA 6020	
Cadmium	ND	1.0	"	"	"	"	"	"	
Cadmium	ND	1.1	mg/kg dry	"	"	"	"	EPA 6020/7000	
<b>Chromium</b>	<b>12</b>	1.0	mg/kg	"	"	"	"	EPA 6020	
<b>Chromium</b>	<b>13</b>	1.1	mg/kg dry	"	"	"	"	EPA 6020/7000	
<b>Cobalt</b>	<b>1.0</b>	1.0	mg/kg	"	"	"	"	EPA 6020	
<b>Cobalt</b>	<b>1.1</b>	1.1	mg/kg dry	"	"	"	"	EPA 6020/7000	
<b>Copper</b>	<b>28</b>	1.0	mg/kg	"	"	"	"	EPA 6020	
<b>Copper</b>	<b>30</b>	1.1	mg/kg dry	"	"	"	"	EPA 6020/7000	
Lead	ND	2.5	mg/kg	"	"	"	"	EPA 6020	
Lead	ND	2.7	mg/kg dry	"	"	"	"	EPA 6020/7000	
Mercury	ND	0.090	"	1	1707082	09/18/17	09/19/17	EPA 7471A	
Mercury	ND	0.10	mg/kg	"	"	"	"	"	
<b>Molybdenum</b>	<b>3.0</b>	1.0	"	5	1706988	09/14/17	09/14/17	EPA 6020	
<b>Molybdenum</b>	<b>3.3</b>	1.1	mg/kg dry	"	"	"	"	EPA 6020/7000	
<b>Nickel</b>	<b>6.2</b>	1.0	mg/kg	"	"	"	"	EPA 6020	
<b>Nickel</b>	<b>6.6</b>	1.1	mg/kg dry	"	"	"	"	EPA 6020/7000	
Selenium	ND	2.5	mg/kg	"	"	"	"	EPA 6020	
Selenium	ND	2.7	mg/kg dry	"	"	"	"	EPA 6020/7000	
Silver	ND	1.0	mg/kg	"	"	"	"	EPA 6020	
Silver	ND	1.1	mg/kg dry	"	"	"	"	EPA 6020/7000	
Thallium	ND	1.0	mg/kg	"	"	"	"	EPA 6020	
Thallium	ND	1.1	mg/kg dry	"	"	"	"	EPA 6020/7000	
<b>Vanadium</b>	<b>4.1</b>	1.0	mg/kg	"	"	"	"	EPA 6020	



# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings - Sludge Sample Project Number: [none] Project Manager: Jeff Lambeth	CLS Work Order #: 1710454 COC #: 183159
--	--	--

## CAM 17 Metals

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Grab #1 thru Grab #4 (Comp) (1710454-05) Sludge    Sampled: 09/12/17 08:00    Received: 09/12/17 12:50</b>									
<b>Vanadium</b>	<b>4.4</b>	1.1	mg/kg dry	5	1706988	"	09/14/17	EPA 6020/7000	
<b>Zinc</b>	<b>130</b>	2.5	mg/kg	"	"	"	"	EPA 6020	
<b>Zinc</b>	<b>140</b>	1.1	mg/kg dry	"	"	"	"	EPA 6020/7000	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings - Sludge Sample Project Number: [none] Project Manager: Jeff Lambeth	CLS Work Order #: 1710454 COC #: 183159
--	--	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Grab #1 thru Grab #4 (Comp) (1710454-05) Sludge    Sampled: 09/12/17 08:00    Received: 09/12/17 12:50</b>									
Hexavalent Chromium	ND	10	µg/kg	1	1706931	09/13/17	09/14/17	EPA 7199	
Hexavalent Chromium	ND	11	µg/kg dry	"	"	"	"	"	
<b>Solids, %</b>	<b>93</b>		%	"	1706918	09/12/17	09/13/17	SM 2540B	