

## Electronic Report Transmittal Form

Attention: Brendan Kenny (916) 464-4635  
Central Valley Regional Water Quality Control Board  
11020 Sun Center Drive #200  
Rancho Cordova, Ca 95670-6114

Discharger: Wild Wings County Service Area  
Name of Facility: Wild Wings Water Recycling Facility  
MRP No: R5-2002-0077  
CIWQS Place ID: 272537  
County: Yolo

I am hereby submitting to the Central Valley Water Board the following information:

### Check all that apply:

Technical Report Title and Date Self-Monitoring Report for Wild Wings

Monthly Monitoring Report for the Month of October 2017

1<sup>st</sup> / 2<sup>nd</sup> / 3<sup>rd</sup> / 4<sup>th</sup> (circle one) Quarterly Monitoring Report for the year \_\_\_\_\_.

1<sup>st</sup> / 2<sup>nd</sup> (circle one) Semi-annual Monitoring Report for the year \_\_\_\_\_.

Annual Monitoring Report for the year \_\_\_\_\_.

### Violation Notification:

During the Monitoring period, there were / were not (circle one) any violations of the WDRs.

1. The Violations were: Exceedance for Total Coliform greater than 23 MPN/100ml on the 12<sup>th</sup> & 13<sup>th</sup>.
2. Have the violations been corrected? Yes / No. If no, what will be done to correct the violations:  
Staff replaced the effluent sample pump and put it online. At the time the sample tubing was not disinfected. This has been corrected and no further trouble has been noted.

**Certification Statement:**

*"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."*

Signature: Paul Bishop

Phone: **540-492-2332**

Printed Name: **Paul Bishop**

Date: **12/1/2017**

**Electronic Report Submittal:**

To submit the electronic reports please do the following:

1. First, make a PDF copy of your report and include this form as the first page of the report.
2. Attach the PDF file to the email.
3. Send the email and PDF attachment to:  
[Centralvalleysacramento@waterboards.ca.gov](mailto:Centralvalleysacramento@waterboards.ca.gov) (Please note that in order to ensure your reports are cataloged correctly and routed to the appropriate Regional Board staff, only one report/attachment shall be included with each e-mail.)

DATE	Influent Monitoring						Secondary Monitoring			Tertiary Effluent Monitoring				Tertiary Effluent Monitoring					TKN	Nitrate(N)
	Flow	pH	EC	TDS	BOD <sub>5</sub>	TSS	pH	BOD <sub>5</sub>	TSS	Flow	Turbidity	Cl2	Total Coliform	pH	BOD <sub>5</sub>	TSS	EC	TDS		
2013	Influent	Influent	Influent	Influent	Influent	Influent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent
	GPD	pH units	umhos/cm	mg/L	mg/L	mg/L	pH units	mg/L	mg/L	GPD	NTU	mg/L	MPN/100 ml	pH units	mg/L	mg/L	umhos/cm	mg/L	mg/L	mg/L
	Metered	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Continuous	Continuous	Continuous	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab
	Daily	Weekly	Weekly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Daily	Daily	Daily	Daily	Weekly	Weekly	Weekly	Monthly	Monthly	Monthly	Monthly
1-Oct	75,000									77783	2.00	>11.0	<1.8							
2-Oct	65,500									77783	1.40	>11.0	<1.8							
3-Oct	52,000									67144	1.70	>11.0	<1.8							
4-Oct	48,400									47924	2.00	>11.0	<1.8							
5-Oct	14,800									42956	2.00	>11.0	2							
6-Oct	61,600	7.5	1270				7.5			121310	1.30	>11.0	<1.8	7.3	ND	9.6	1014			
7-Oct	58,100									197721	0.90	>11.0	<1.8							
8-Oct	60,100									261556	1.30	>11.0	<1.8							
9-Oct	66,600									29493	1.70	>11.0	<1.8							
10-Oct	60,000									72650	2.00	>11.0	<1.8							
11-Oct	61,800									72650	2.00	>11.0	<1.8							
12-Oct	44,230	7.4	1311							45762	0.70	>11.0	1600	7.4						
13-Oct	82,970									123838	1.30	>11.0	1600		ND	8.8				
14-Oct	93,400									147610	2.00	>11.0	<1.8							
15-Oct	76,700									134811	1.70	>11.0	<1.8							
16-Oct	59,900									42032	1.90	>11.0	<1.8							
17-Oct	50,200									1243	2.00	>11.0	<1.8							
18-Oct	62,500	7.6	1280							76944	2.00	>11.0	<1.8	7.2						
19-Oct	71,200									79268	0.80	>11.0	<1.8							
20-Oct	64,200									81320	1.80	>11.0	<1.8		4.8	8				
21-Oct	67,500									84878	1.90	>11.0	<1.8							
22-Oct	61,400									81277	1.70	>11.0	<1.8							
23-Oct	67,100									83999	2.00	>11.0	<1.8							
24-Oct	59,700									82766	2.00	>11.0	<1.8							
25-Oct	16,600	7.5	1290							76529	1.90	>11.0	<1.8	7.4						
26-Oct	21,200									91020	2.00	>11.0	<1.8							
27-Oct	27,700									86445	1.70	>11.0	<1.8							
28-Oct	31,000									87655	1.70	>11.0	<1.8		5.6	7.5				
29-Oct	57,600									90753	0.90	>11.0	<1.8							
30-Oct	61,100									41299	1.90	>11.0	<1.8							
31-Oct	124,200			640	180	320	7.6	6.8		57177	2.00	>11.0	<1.8					710	0.94	13
TOTAL	1,824,300									2665596										
AVG.	58,848	7.5	1288	#DIV/0!	#DIV/0!	180	7.5	0		85987	1.68	#DIV/0!	1.8	7.33	0	0	1,014	#DIV/0!	#DIV/0!	#DIV/0!
MINIMUM	14,800	7.4	1270	0	0	0	7.5	0.0	0	1243	0.70	0.0	1.8	7.20	5	8	1,014	0	0.00	0.0
MAXIMUM	124,200	8	1311	0	0	0	7.5	0.0	0	261556	2.00	0	1,600.0	7.40	6	10	1,014	0	0.00	0.0
Requirement #1	AVG.-100 MG	Min 6.5					Min 6.5				AVG. 2.0	Min 1.0	MED 2.2	Min 6.5						
Times Exceeded	0	0	0				0				0	1	0	0						
Requirement #2		Max 8.5		Max 1500			Max 8.5				Max 10		Max 23	Max 8.5	Max 10	Max 10		Max 1500		
Times Exceeded	0			0			0				0		2.0	0	0	0		0		

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all the attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations.

*Paul Bishop*

Signature of Principle Executive Officer or Authorized Agent

Recycling Facility

		Recycled Water Storage Pond Monitoring						Recycled Water Area Monitoring						Surface Water Monitoring S-1				50' ↑		
Total N	NH <sub>3</sub> as N	Freeboard	D.O.	pH	EC	TDS	Total N	Flow	Rainfall	Acreage	Application	Application	Total	TDS	pH	EC	TDS	Nitrate(N)	NH <sub>3</sub> as N	Flow
Effluent	Effluent	Pond	Pond	Pond	Pond	Pond	Pond	Irrigation		Applied	Rate	Period	Nitrogen		Irrigation	Irrigation	Irrigation	Irrigation	Irrigation	Irrigation
mg/L	mg/L	Feet	mg/L	pH units	umhos/cm	mg/L	mg/L	GPD	Inches	acres	gal/acre/day	Hours	lbs/month	lbs/month	pH units	umhos/cm	mg/L	mg/L	mg/L	GPM
Grab	Grab	Measurement	Grab	Grab	Grab	Grab	Grab	Measurement	Measured	Calculated	Calculated	Measured	Calculated	Calculated	Grab	Grab	Grab	Grab	Grab	Estimated
Monthly	Monthly	Weekly	Weekly	Weekly	Monthly	Monthly	Monthly	Weekly	Daily	Daily	Daily	Daily	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Weekly
		6.51						268576	0	68	3950	9pm-11am								
		6.83						0	0	0	0									
		7.2						268576	0	68	3950	9pm-11am								
		7.4						268576	0	68	3950	9pm-11am								
		7.51						101429	0	38	2669	9pm-11am								
		7.86	10.11	7.4	1117			194469	0	48	4051	9pm-11am								
		8.33						194469	0	48	4051	9pm-11am								
		8.59						194469	0	48	4051	9pm-11am								
		7.91						194469	0	48	4051	9pm-11am								
		7.69						194469	0	48	4051	9pm-11am								
		7.4						194469	0	48	40513	9pm-11am								
		7.73	11.09	7.6				194469	0	48	4051	9pm-11am								
		7.76						0	0	0	0									
		7.91						206499	0	68	3036	9pm-11am								
		7.59						206499	0	68	3036	9pm-11am								
		7.43						183638	0	68	2701	9pm-11am								
		7.65						183638	0	68	2701	9pm-11am								
		7.5	10.27	7.3				183638	0	68	2701	9pm-11am								
		7.8						275582	0.03	68	4053	9pm-11am								
		7.39						0	0.1	0	0									
		7.03						232225	0	68	3451	9pm-11am								
		6.24						0	0	0	0									
		6.49						160483	0	68	2360	9pm-11am								
		6.6						0	0	0	0									
		6.73	10.14	7.5				243687	0	68	3584	9pm-11am								
		6.86						0	0	0	0									
		7.1						0	0	0	0									
		7.1						186380	0	68	2741	9pm-11am								
		8.11						0	0	0	0	9pm-11am								
		8.39						186577	0	68	2744	9pm-11am								
14	0.13	8.53				560	6.10	0	0	0	0									
								4517286	0.13											
#DIV/0!	0	7.46	10.4	7.5	1117	#DIV/0!	0	145,719	0.00	43			#DIV/0!							
0	0	6.24	10.1	7.3	1117	0	0	0	0.00	0			0							
0	0	8.59	11	8	1117	0	0	275,582	0.10	68			0							


# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

10/09/17 12:51

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J0013 COC #: 181480
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17J0013-01) WW Sampled: 10/01/17 09:00 Received: 10/01/17 11:45</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707466	10/01/17	10/03/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J0029 COC #: 181481
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17J0029-01) WW Sampled: 10/02/17 09:00 Received: 10/02/17 12:35</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707474	10/02/17	10/04/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J0114 COC #: 181482
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Effluent (17J0114-01) WW    Sampled: 10/03/17 09:00    Received: 10/03/17 13:15</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707516	10/03/17	10/05/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J0186 COC #: 181483
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Effluent (17J0186-01) WW    Sampled: 10/04/17 09:00    Received: 10/04/17 12:05</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707541	10/04/17	10/06/17	SM 9221	



# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

10/12/17 14:06

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17J0283  
COC #: 181484

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Effluent (17J0283-01) WW</b> <b>Sampled: 10/05/17 09:00</b> <b>Received: 10/05/17 12:50</b>									
<b>Total Coliforms</b>	<b>2.0</b>	1.8	MPN/100 mL	1	1707589	10/05/17	10/08/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 5

10/13/17 10:16

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17J0335  
COC #: 181485

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff. (17J0335-01) WW Sampled: 10/06/17 09:00 Received: 10/06/17 13:00</b>									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1707604	10/06/17	10/11/17	SM5210B	
<b>Total Suspended Solids</b>	<b>9.6</b>	5.0	"	"	1707640	10/09/17	10/09/17	SM2540D	
<b>MLSS (17J0335-02) WW Sampled: 10/06/17 09:00 Received: 10/06/17 13:00</b>									
<b>Total Suspended Solids</b>	<b>1100</b>	5.0	mg/L	1	1707640	10/09/17	10/09/17	SM2540D	

# CALIFORNIA LABORATORY SERVICES

Page 3 of 5

10/13/17 10:16

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J0335 COC #: 181485
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff. (17J0335-01) WW Sampled: 10/06/17 09:00 Received: 10/06/17 13:00</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707617	10/06/17	10/08/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J0381 COC #: 179948
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert EFF (17J0381-01) WW Sampled: 10/07/17 09:00 Received: 10/07/17 12:50</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707659	10/07/17	10/09/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J0378 COC #: 179949
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17J0378-01) WW Sampled: 10/08/17 09:00 Received: 10/08/17 12:35</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707660	10/08/17	10/10/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J0407 COC #: 179951
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17J0407-01) WW Sampled: 10/09/17 09:00 Received: 10/09/17 12:05</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707680	10/09/17	10/11/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J0459 COC #: 179952
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17J0459-01) WW Sampled: 10/10/17 09:00 Received: 10/10/17 12:29</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707713	10/10/17	10/12/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

10/26/17 09:30

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J0528 COC #: 179953
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17J0528-01) WW Sampled: 10/11/17 09:00 Received: 10/11/17 12:15</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707750	10/11/17	10/13/17	SM 9221	



# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J0594 COC #: 179954
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17J0594-01) WW Sampled: 10/12/17 09:00 Received: 10/12/17 12:45</b>									
Total Coliforms	>1600	1.8	MPN/100 mL	1	1707783	10/12/17	10/15/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J0668 COC #: 179955
--	--	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17J0668-02) WW Sampled: 10/13/17 08:00 Received: 10/13/17 13:20</b>									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1707796	10/13/17	10/18/17	SM5210B	
<b>Total Suspended Solids</b>	<b>8.8</b>	5.0	"	"	1707875	10/16/17	10/16/17	SM2540D	
<b>MLSS (17J0668-03) WW Sampled: 10/13/17 08:30 Received: 10/13/17 13:20</b>									
<b>Total Suspended Solids</b>	<b>1600</b>	5.0	mg/L	1	1707875	10/16/17	10/16/17	SM2540D	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J0668 COC #: 179955
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17J0668-01) WW Sampled: 10/13/17 09:00 Received: 10/13/17 13:20</b>									
<b>Total Coliforms</b>	<b>1600</b>	1.8	MPN/100 mL	1	1707843	10/13/17	10/16/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J0712 COC #: 179956
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff. (17J0712-01) WW    Sampled: 10/14/17 09:00    Received: 10/14/17 12:00</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707871	10/14/17	10/16/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

10/26/17 09:32

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17J0724  
COC #: 179956

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff. (17J0724-01) WW Sampled: 10/15/17 09:00 Received: 10/15/17 11:50</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707872	10/15/17	10/17/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

10/26/17 09:33

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J0745 COC #: 179958
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17J0745-01) WW Sampled: 10/16/17 09:00 Received: 10/16/17 12:20</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707881	10/16/17	10/18/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

10/26/17 09:37

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J0837 COC #: 179959
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17J0837-01) WW Sampled: 10/17/17 09:00 Received: 10/17/17 12:35</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707927	10/17/17	10/19/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

10/26/17 09:16

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J0906 COC #: 179960
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17J0906-01) WW Sampled: 10/18/17 09:00 Received: 10/18/17 11:55</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707960	10/18/17	10/20/17	SM 9221	



# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J1003 COC #: 179961
--	--	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17J1003-02) WW    Sampled: 10/19/17 09:00    Received: 10/19/17 12:30</b>									
Biochemical Oxygen Demand	4.8	3.0	mg/L	1	1707990	10/19/17	10/24/17	SM5210B	
Total Suspended Solids	8.0	5.0	"	"	1708044	10/23/17	10/23/17	SM2540D	
<b>MLSS (17J1003-03) WW    Sampled: 10/19/17 09:00    Received: 10/19/17 12:30</b>									
Total Suspended Solids	1400	5.0	mg/L	1	1708044	10/23/17	10/23/17	SM2540D	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J1003 COC #: 179961
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17J1003-01) WW Sampled: 10/19/17 09:00 Received: 10/19/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1707986	10/19/17	10/21/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J1069 COC #: 179962
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17J1069-01) WW Sampled: 10/20/17 09:00 Received: 10/20/17 12:20</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708027	10/20/17	10/22/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

10/30/17 13:10

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J1095 COC #: 179963
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17J1095-01) WW Sampled: 10/21/17 09:00 Received: 10/21/17 13:00</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708046	10/21/17	10/23/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

10/30/17 13:11

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J1109 COC #: 179964
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17J1109-01) WW Sampled: 10/22/17 09:00 Received: 10/22/17 12:45</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708047	10/22/17	10/24/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J1138 COC #: 179965
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17J1138-01) WW Sampled: 10/23/17 09:00 Received: 10/23/17 12:50</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708063	10/23/17	10/25/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J1235 COC #: 179966
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff (17J1235-01) WW    Sampled: 10/24/17 09:00    Received: 10/24/17 13:45</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708114	10/24/17	10/26/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J1342 COC #: 179967
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff (17J1342-01) WW    Sampled: 10/25/17 09:00    Received: 10/25/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708163	10/25/17	10/27/17	SM 9221	



# CALIFORNIA LABORATORY SERVICES

Page 1 of 2

11/02/17 13:04

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17J1440  
COC #: 179968

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert Eff (17J1440-01) WW Sampled: 10/26/17 09:00 Received: 10/26/17 13:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708208	10/26/17	10/28/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J1511 COC #: 179969
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17J1511-01) WW Sampled: 10/27/17 09:00 Received: 10/27/17 12:10</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708253	10/27/17	10/29/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J1543 COC #: 179970
--	--	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17J1543-02) WW Sampled: 10/28/17 09:00 Received: 10/28/17 12:50</b>									
Biochemical Oxygen Demand	5.6	3.0	mg/L	1	1708273	10/29/17	11/03/17	SM5210B	
Total Suspended Solids	7.5	5.0	"	"	1708284	10/30/17	10/30/17	SM2540D	
<b>MLSS (17J1543-03) WW Sampled: 10/28/17 09:00 Received: 10/28/17 12:50</b>									
Total Suspended Solids	1400	5.0	mg/L	1	1708284	10/30/17	10/30/17	SM2540D	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J1553 COC #: 179971
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17J1553-01) WW Sampled: 10/29/17 09:00 Received: 10/29/17 11:50</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708291	10/29/17	10/31/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J1575 COC #: 179973
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17J1575-01) WW Sampled: 10/30/17 09:00 Received: 10/30/17 12:10</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708303	10/30/17	11/01/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17J1645 COC #: 179974
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17J1645-01) WW Sampled: 10/31/17 09:00 Received: 10/31/17 12:50</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708345	10/31/17	11/02/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K0016 COC #: 179976
--	--	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Inf. (17K0016-01) WW Sampled: 10/31/17 15:00 Received: 11/01/17 13:00</b>									
Biochemical Oxygen Demand	180	3.0	mg/L	1	1708394	11/02/17	11/07/17	SM5210B	
Total Dissolved Solids	640	10	"	"	1708373	11/01/17	11/02/17	SM2540C	
Total Suspended Solids	320	5.0	"	"	1708397	11/02/17	11/02/17	SM2540D	
<b>2nd Eff. (17K0016-02) WW Sampled: 10/31/17 15:00 Received: 11/01/17 13:00</b>									
Biochemical Oxygen Demand	7.6	3.0	mg/L	1	1708394	11/02/17	11/07/17	SM5210B	
Total Suspended Solids	6.8	5.0	"	"	1708397	11/02/17	11/02/17	SM2540D	
<b>Tert Eff (17K0016-03) WW Sampled: 10/31/17 15:00 Received: 11/01/17 13:00</b>									
Ammonia as N	0.13	0.10	mg/L	1	1708352	11/01/17	11/01/17	SM4500-NH3F-1997	
Biochemical Oxygen Demand	ND	3.0	"	"	1708394	11/02/17	11/07/17	SM5210B	
Nitrate as N	13	2.0	"	5	1708348	11/01/17	11/02/17	EPA 300.0	
Nitrate/Nitrite as N	13	2.0	"	"	"	"	"	"	
Total Dissolved Solids	710	10	"	1	1708373	11/01/17	11/02/17	SM2540C	
Total Kjeldahl Nitrogen	0.94	0.20	"	"	1708408	11/02/17	11/02/17	SM4500-NH3F-1997	
Total Nitrogen	14	0.40	"	"	1708413	11/02/17	11/02/17	EPA 351.3/300	
Total Suspended Solids	5.5	5.0	"	"	1708397	11/02/17	11/02/17	SM2540D	
<b>MLSS (17K0016-04) WW Sampled: 10/31/17 15:00 Received: 11/01/17 13:00</b>									
Total Suspended Solids	1500	5.0	mg/L	1	1708397	11/02/17	11/02/17	SM2540D	
<b>Storage Pond (17K0016-05) TWW Sampled: 10/31/17 15:00 Received: 11/01/17 13:00</b>									
Nitrate/Nitrite as N	3.6	2.0	mg/L	5	1708348	11/01/17	11/02/17	EPA 300.0	
Total Dissolved Solids	560	10	"	1	1708373	11/01/17	11/02/17	SM2540C	
Total Kjeldahl Nitrogen	2.5	1.0	"	5	1708408	11/02/17	11/02/17	SM4500-NH3F-1997	
Total Nitrogen	6.1	0.40	"	1	1708413	11/02/17	11/02/17	EPA 351.3/300	