

### Quarterly Report for Disinfectant Residuals Compliance For Systems Using Chlorine or Chloramines

System Name: WILD WINGS System No.: 5710011

Calendar Year: 2017 Quarter: 4

1st Quarter			
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)	
Previous Year	April	1.00	
	May	1.10	
	June	0.90	
	July	1.00	
	August	1.00	
	September	1.10	
	October	1.00	
	November	1.00	
	December	1.00	
	Current Year	January	2
		February	2
		March	2
Running Annual Average (RAA):		1.06	
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl <sub>2</sub> )		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

2nd Quarter			
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)	
Previous Year	July	1.00	
	August	1.00	
	September	1.10	
	October	1.00	
	November	1.00	
	December	1.00	
	Current Year	January	1.15
		February	1.15
		March	1.35
		April	2
		May	2
		June	0
Running Annual Average (RAA):		1.11	
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl <sub>2</sub> )		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

3rd Quarter			
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)	
Previous Yr	October	1.00	
	November	1.00	
	December	1.00	
Current Year	January	1.15	
	February	1.15	
	March	1.35	
	April	1.10	
	May	1.25	
	June	1.27	
	July	10	
	August	2	
	September	2	
	Running Annual Average (RAA):		1.12
	Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl <sub>2</sub> )		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

4th Quarter		
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
Current Year	January	1.15
	February	1.15
	March	1.35
	April	1.10
	May	1.25
	June	1.27
	July	1.10
	August	1.05
	September	1.00
	October	2
	November	2
	December	1.80
Running Annual Average (RAA):		1.24
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl <sub>2</sub> )		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Comments: \_\_\_\_\_

Signature: Paul Bishop

Date: 12/7/2017