

**Electronic Report Transmittal Form**

Attention: Brendan Kenny (916) 464-4635  
Central Valley Regional Water Quality Control Board  
11020 Sun Center Drive #200  
Rancho Cordova, Ca 95670-6114

Discharger: Wild Wings County Service Area  
Name of Facility: Wild Wings Water Recycling Facility  
MRP No: R5-2002-0077  
CIWQS Place ID: 272537  
County: Yolo

I am hereby submitting to the Central Valley Water Board the following information:

**Check all that apply:**

Technical Report Title and Date **Self-Monitoring Report for Wild Wings**

Monthly Monitoring Report for the Month of **November 2017**

1<sup>st</sup> / 2<sup>nd</sup> / 3<sup>rd</sup> / 4<sup>th</sup> (**circle one**) Quarterly Monitoring Report for the year \_\_\_\_\_.

1<sup>st</sup> / 2<sup>nd</sup> (**circle one**) Semi-annual Monitoring Report for the year \_\_\_\_\_.

Annual Monitoring Report for the year \_\_\_\_\_.

**Violation Notification:**

During the Monitoring period, there were / **were not** (circle one) any violations of the WDRs.

1. The Violations were:
2. Have the violations been corrected? Yes / No. If no, what will be done to correct the violations:

**Certification Statement:**

*"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."*

Signature: Paul Bishop

Phone: **540-492-2322**

Printed Name: **Paul Bishop**

Date: **12/22/2017**

**Electronic Report Submittal:**

To submit the electronic reports please do the following:

1. First, make a PDF copy of your report and include this form as the first page of the report.
2. Attach the PDF file to the email.
3. Send the email and PDF attachment to:  
[Centralvalleysacramento@waterboards.ca.gov](mailto:Centralvalleysacramento@waterboards.ca.gov) (Please note that in order to ensure your reports are cataloged correctly and routed to the appropriate Regional Board staff, only one report/attachment shall be included with each e-mail.)

DATE	Influent Monitoring						Secondary Monitoring			Tertiary Effluent Monitoring				Tertiary Effluent Monitoring					TKN	Nitrate(N)	
	Flow	pH	EC	TDS	BOD <sub>5</sub>	TSS	pH	BOD <sub>5</sub>	TSS	Flow	Turbidity	Cl2	Total Coliform	pH	BOD <sub>5</sub>	TSS	EC	TDS			
2011	Influent	Influent	Influent	Influent	Influent	Influent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent
	GPD	pH units	umhos/cm	mg/L	mg/L	mg/L	pH units	mg/L	mg/L	GPD	NTU	mg/L	MPN/100 ml	pH units	mg/L	mg/L	umhos/cm	mg/L	mg/L	mg/L	mg/L
2013	Metered	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Continuous	Continuous	Continuous	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab
	Daily	Weekly	Weekly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Daily	0.01	Daily	Daily	Weekly	Weekly	Weekly	Monthly	Monthly	Monthly	Monthly	Monthly
1-Nov	49,700	7.3	1271				7.2			611	2.00	>11.0	<1.8	7.2			1210				
2-Nov	56,100									57,424	1.70	>11.0	<1.8								
3-Nov	88,900									176,789	1.40	>11.0	<1.8								
4-Nov	59,900									70,813	1.90	>11.0	<1.8		ND	ND					
5-Nov	59,000									75,723	2.00	>11.0	<1.8								
6-Nov	67,900									74,799	1.10	>11.0	<1.8								
7-Nov	60,000									67,424	1.60	>11.0	<1.8								
8-Nov	61,400	7.2	1117							60101	2.00	>11.0	<1.8	7.1							
9-Nov	71,100									51727	2.00	>11.0	<1.8								
10-Nov	52,000									108546	2.00	>11.0	<1.8								
11-Nov	49,900									80545	1.60	>11.0	<1.8		3.2	6					
12-Nov	52,100									74799	1.00	>11.0	<1.8								
13-Nov	62,600									78111	1.10	>11.0	<1.8								
14-Nov	67,400									60188	1.80	>11.0	<1.8								
15-Nov	61,000	7.5	1070							28540	2.00	>11.0	<1.8	7.2							
16-Nov	57,100									66116	2.00	>11.0	<1.8								
17-Nov	57,600									66116	2.00	>11.0	<1.8								
18-Nov	54,400									83954	2.00	>11.0	<1.8		ND	ND					
19-Nov	51,300									70133	1.70	>11.0	<1.8								
20-Nov	52,200									71221	1.80	>11.0	<1.8								
21-Nov	48,600									58726	1.30	>11.0	<1.8								
22-Nov	84,000	7.4	1160							51782	1.60	>11.0	<1.8	7.2							
23-Nov	71,100									70149	2.00	>11.0	<1.8								
24-Nov	59,100									83483	2.00	>11.0	<1.8								
25-Nov	62,100									90853	1.70	>11.0	<1.8								
26-Nov	58,100									61222	1.40	>11.0	<1.8		ND	ND					
27-Nov	59,700									59727	1.80	>11.0	<1.8								
28-Nov	57,800									64070	2.00	>11.0	<1.8								
29-Nov	52,600	7.5	1220	730	530	1100		ND	5.3	87540	2.00	>11.0	<1.8	7.3	4.9	ND		710	0.52	9.5	
30-Nov	54,700									74616	1.70	>11.0	<1.8								
TOTAL	1,799,400																				
AVG.	59,980	7.4	1,168	730	530	1,100	7	#DIV/0!	5	70,862	1.74	#DIV/0!	#DIV/0!	7.2	4.1	6.00	1,210	710	0.52	9.5	
MINIMUM	48,600	7.2	1,070	730	530	1,100	7	0	5	611	1.00	0.0	0	7.1	3.2	6.00	1,210	710	0.52	9.5	
MAXIMUM	88,900	7.5	1,271	730	530	1,100	7	0	5	176,789	2.00	0.0	0	7.3	4.9	6.00	1,210	710	0.52	9.5	
Requirement #1	AVG.-100 MG	Min 6.5					Min 6.5				AVG. 2.0	Min 1.0	MED 2.2	Min 6.5							
Times Exceeded		0	0				0				0	1.0	0	0							
Requirement #2		Max 8.5		Max 1500			Max 8.5				Max 10		Max 23	Max 8.5	Max 10	Max 10		Max 1500			
Times Exceeded		0		0			0				0		0.0	0	0	0		0			

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all the attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations.

*Paul Bishop*

Signature of Principle Executive Officer or Authorized Agent



# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K0018 COC #: 179975
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K0018-01) WW    Sampled: 11/01/17 09:00    Received: 11/01/17 13:00</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708380	11/01/17	11/03/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

11/09/17 12:26

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

**CLS Work Order #: 17K0115**  
COC #: 179977

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K0115-01) WW Sampled: 11/02/17 09:00 Received: 11/02/17 13:00</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708425	11/02/17	11/04/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K0205 COC #: 179978
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K0205-01) WW    Sampled: 11/03/17 09:00    Received: 11/03/17 14:15</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708454	11/03/17	11/05/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K0226 COC #: 179979
--	--	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K0226-01) WW Sampled: 11/04/17 08:45 Received: 11/04/17 13:00</b>									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1708465	11/05/17	11/10/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1708482	11/06/17	11/06/17	SM2540D	
<b>MLSS (17K0226-02) WW Sampled: 11/04/17 08:50 Received: 11/04/17 13:00</b>									
<b>Total Suspended Solids</b>	<b>1700</b>	5.0	mg/L	1	1708482	11/06/17	11/06/17	SM2540D	



# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K0226 COC #: 179979
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K0226-03) WW Sampled: 11/04/17 09:00 Received: 11/04/17 13:00</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708463	11/04/17	11/06/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

11/13/17 13:43

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K0237 COC #: 179980
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff. (17K0237-01) Wastewater    Sampled: 11/05/17 09:00    Received: 11/05/17 11:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708489	11/05/17	11/07/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K0265 COC #: 179981
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K0265-01) WW    Sampled: 11/06/17 09:00    Received: 11/06/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708502	11/06/17	11/08/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

11/14/17 14:43

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

**CLS Work Order #: 17K0335**  
COC #: 179982

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K0335-01) WW Sampled: 11/07/17 09:00 Received: 11/07/17 12:40</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708547	11/07/17	11/09/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K0428 COC #: 179983
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K0428-01) WW    Sampled: 11/08/17 09:00    Received: 11/08/17 12:50</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708595	11/08/17	11/10/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

11/16/17 14:19

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

**CLS Work Order #: 17K0504**  
COC #: 179984

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K0504-01) WW Sampled: 11/09/17 09:00 Received: 11/09/17 12:05</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708647	11/09/17	11/11/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K0580 COC #: 179985
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K0580-01) WW    Sampled: 11/10/17 09:00    Received: 11/10/17 13:00</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708686	11/10/17	11/12/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K0588 COC #: 179987
--	--	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>MLSS (17K0588-02) WW Sampled: 11/11/17 08:50 Received: 11/11/17 12:50</b>									
<b>Total Suspended Solids</b>	<b>1400</b>	5.0	mg/L	1	1708704	11/13/17	11/13/17	SM2540D	
<b>tert. Eff. (17K0588-03) WW Sampled: 11/11/17 08:50 Received: 11/11/17 12:50</b>									
<b>Biochemical Oxygen Demand</b>	<b>3.2</b>	3.0	mg/L	1	1708694	11/12/17	11/17/17	SM5210B	
<b>Total Suspended Solids</b>	<b>6.0</b>	5.0	"	"	1708704	11/13/17	11/13/17	SM2540D	



# CALIFORNIA LABORATORY SERVICES

Page 3 of 5

11/20/17 12:04

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

**CLS Work Order #: 17K0588**  
COC #: 179987

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K0588-01) WW Sampled: 11/11/17 09:00 Received: 11/11/17 12:50</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708691	11/11/17	11/13/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K0597 COC #: 179988
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K0597-01) WW    Sampled: 11/12/17 09:00    Received: 11/12/17 11:40</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708708	11/12/17	11/14/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K0617 COC #: 179990
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K0617-01) WW Sampled: 11/13/17 09:00 Received: 11/13/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708717	11/13/17	11/15/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

11/21/17 12:36

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K0687 COC #: 179991
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K0687-01) WW Sampled: 11/14/17 09:00 Received: 11/14/17 12:10</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708753	11/14/17	11/16/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K0746 COC #: 179992
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K0746-01) WW    Sampled: 11/15/17 09:00    Received: 11/15/17 12:20</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708783	11/15/17	11/17/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K0848 COC #: 179993
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K0848-01) WW    Sampled: 11/16/17 09:00    Received: 11/16/17 13:00</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708829	11/16/17	11/18/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K0948 COC #: 179994
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K0948-01) WW Sampled: 11/17/17 09:00 Received: 11/17/17 12:40</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708877	11/17/17	11/19/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K0966 COC #: 179995
--	--	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Aeration Basin (17K0966-02) WW    Sampled: 11/18/17 08:50    Received: 11/18/17 12:50</b>									
Total Suspended Solids	1700	5.0	mg/L	1	1708920	11/20/17	11/20/17	SM2540D	
<b>Final Eff. (17K0966-03) WW    Sampled: 11/18/17 08:50    Received: 11/18/17 12:50</b>									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1708943	11/19/17	11/24/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1708920	11/20/17	11/20/17	SM2540D	



# CALIFORNIA LABORATORY SERVICES

Page 3 of 5

11/29/17 11:08

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K0966 COC #: 179995
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K0966-01) WW Sampled: 11/18/17 09:00 Received: 11/18/17 12:50</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708895	11/18/17	11/20/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K0974 COC #: 179997
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K0974-01) WW Sampled: 11/19/17 09:00 Received: 11/19/17 12:00</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708916	11/19/17	11/21/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K0991 COC #: 179998
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K0991-01) WW Sampled: 11/20/17 09:00 Received: 11/20/17 12:00</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708933	11/20/17	11/22/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

11/30/17 14:33

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K1049 COC #: 179999
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K1049-01) WW    Sampled: 11/21/17 09:00    Received: 11/21/17 11:35</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1708975	11/21/17	11/23/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

12/01/17 12:23

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K1128 COC #: 185300
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K1128-01) WW Sampled: 11/22/17 09:00 Received: 11/22/17 12:00</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709004	11/22/17	11/24/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K1163 COC #: 185301
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K1163-01) WW Sampled: 11/23/17 09:00 Received: 11/23/17 11:35</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709028	11/23/17	11/25/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K1168 COC #: 185302
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K1168-01) WW Sampled: 11/24/17 09:00 Received: 11/24/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709029	11/24/17	11/26/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

12/04/17 13:37

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17K1175  
COC #: 185303

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K1175-01) WW Sampled: 11/25/17 09:00 Received: 11/25/17 12:30</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709033	11/25/17	11/27/17	SM 9221	



# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K1181 COC #: 185304
--	--	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K1181-01) WW Sampled: 11/26/17 09:00 Received: 11/26/17 11:50</b>									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1709031	11/26/17	12/01/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1709087	11/28/17	11/28/17	SM2540D	
<b>MLSS (17K1181-02) WW Sampled: 11/26/17 09:00 Received: 11/26/17 11:50</b>									
<b>Total Suspended Solids</b>	<b>2700</b>	5.0	mg/L	1	1709087	11/28/17	11/28/17	SM2540D	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K1181 COC #: 185304
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K1181-01) WW Sampled: 11/26/17 09:00 Received: 11/26/17 11:50</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709060	11/26/17	11/28/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

12/04/17 13:38

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 17K1206  
COC #: 185305

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K1206-01) WW Sampled: 11/27/17 09:00 Received: 11/27/17 12:20</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709072	11/27/17	11/29/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K1266 COC #: 185307
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K1266-01) WW    Sampled: 11/28/17 09:00    Received: 11/28/17 12:10</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709100	11/28/17	11/30/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K1322 COC #: 185308
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>tert. Eff. (17K1322-01) WW Sampled: 11/29/17 09:00 Received: 11/29/17 12:10</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709135	11/29/17	12/01/17	SM 9221	

# CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K1321 COC #: 181486
--	--	--

## Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Inf. (17K1321-01) WW Sampled: 11/29/17 08:00 Received: 11/29/17 12:15</b>									
Biochemical Oxygen Demand	530	3.0	mg/L	1	1709127	11/29/17	12/04/17	SM5210B	
Total Dissolved Solids	730	10	"	"	1709162	11/30/17	12/01/17	SM2540C	
Total Suspended Solids	1100	5.0	"	"	1709161	11/30/17	11/30/17	SM2540D	
<b>Sec. Eff (17K1321-02) WW Sampled: 11/29/17 08:00 Received: 11/29/17 12:15</b>									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1709127	11/29/17	12/04/17	SM5210B	
Total Suspended Solids	5.3	5.0	"	"	1709161	11/30/17	11/30/17	SM2540D	
<b>Tert. Eff. (17K1321-03) WW Sampled: 11/29/17 08:00 Received: 11/29/17 12:15</b>									
Ammonia as N	ND	0.10	mg/L	1	1709174	11/30/17	11/30/17	SM4500-NH3F-1997	
Biochemical Oxygen Demand	4.9	3.0	"	"	1709127	11/29/17	12/04/17	SM5210B	
Nitrate as N	9.5	2.0	"	5	1709110	11/29/17	11/29/17	EPA 300.0	
Nitrate/Nitrite as N	9.5	2.0	"	"	"	"	"	"	
Total Dissolved Solids	710	10	"	1	1709162	11/30/17	12/01/17	SM2540C	
Total Kjeldahl Nitrogen	0.52	0.20	"	"	1709211	12/01/17	12/01/17	SM4500-NH3F-1997	
Total Nitrogen	10	0.40	"	"	1709214	12/01/17	12/01/17	EPA 351.3/300	
Total Suspended Solids	ND	5.0	"	"	1709161	11/30/17	11/30/17	SM2540D	
<b>MLSS (17K1321-04) WW Sampled: 11/29/17 08:00 Received: 11/29/17 12:15</b>									
Total Suspended Solids	2400	5.0	mg/L	1	1709161	11/30/17	11/30/17	SM2540D	
<b>Storage Pond (17K1321-05) TWW Sampled: 11/29/17 08:00 Received: 11/29/17 12:15</b>									
Nitrate/Nitrite as N	6.9	2.0	mg/L	5	1709110	11/29/17	11/29/17	EPA 300.0	
Total Dissolved Solids	560	10	"	1	1709162	11/30/17	12/01/17	SM2540C	
Total Kjeldahl Nitrogen	1.2	1.0	"	5	1709211	12/01/17	12/01/17	SM4500-NH3F-1997	
Total Nitrogen	8.1	0.40	"	1	1709214	12/01/17	12/01/17	EPA 351.3/300	

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

12/07/17 14:38

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17K1383 COC #: 185309
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Tert. Eff. (17K1383-01) WW Sampled: 11/30/17 09:00 Received: 11/30/17 12:05</b>									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709179	11/30/17	12/02/17	SM 9221	