

Electronic Report Transmittal Form

Attention: Brendan Kenny (916) 464-4635
Central Valley Regional Water Quality Control Board
11020 Sun Center Drive #200
Rancho Cordova, Ca 95670-6114

Discharger: Wild Wings County Service Area
Name of Facility: Wild Wings Water Recycling Facility
MRP No: R5-2002-0077
CIWQS Place ID: 272537
County: Yolo

I am hereby submitting to the Central Valley Water Board the following information:

Check all that apply:

Technical Report Title and Date **Self-Monitoring Report for Wild Wings**

Monthly Monitoring Report for the Month of **December 2017**

1st / 2nd / 3rd / 4th (**circle one**) Quarterly Monitoring Report for the year _____.

1st / 2nd (**circle one**) Semi-annual Monitoring Report for the year _____.

Annual Monitoring Report for the year _____.

Violation Notification:

During the Monitoring period, **(there were)** were not (circle one) any violations of the WDRs.


1. The Violations were: See Below
2. Have the violations been corrected? **(Yes)** No. If no, what will be done to correct the violations:

The County contracted with EEI to perform repairs on the failed tertiary filter. Repair work began on 12-20-17. In order to affect the necessary repairs, the contractor bypassed the tertiary filter to the recycled storage pond, therefore no e-coli samples were collected during the period December 21 through December 31, 2017.

Certification Statement:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Signature: _____



Phone: 702-236-1740

Printed Name: Jeff Lambeth

Date: 2/1/2018

Electronic Report Submittal:

To submit the electronic reports please do the following:

1. First, make a PDF copy of your report and include this form as the first page of the report.
2. Attach the PDF file to the email.
3. Send the email and PDF attachment to:
Centralvalleysacramento@waterboards.ca.gov (Please note that in order to ensure your reports are cataloged correctly and routed to the appropriate Regional Board staff, only one report/attachment shall be included with each e-mail.)

Dec

WDR Order No. R5-2002-0077

Wild Wings Water R

DATE	Influent Monitoring						Secondary Monitoring			Tertiary Effluent Monitoring				Tertiary Effluent Monitoring						
	Flow	pH	EC	TDS	BOD ₅	TSS	pH	BOD ₅	TSS	Flow	Turbidity	Cl ₂	Total Coliform	pH	BOD ₅	TSS	EC	TDS	TKN	Nitrate(N)
	Influent	Influent	Influent	Influent	Influent	Influent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent	Effluent
2013	GD	pH units	umhos/cm	mg/L	mg/L	mg/L	pH units	mg/L	mg/L	GD	NTU	mg/L	MPN/100 ml	pH units	mg/L	mg/L	umhos/cm	mg/L	mg/L	mg/L
	Measured	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Continuous	Continuous	Continuous	Grab	Grab	Grab	Grab	Grab	Grab	Grab	Grab
	Daily	Weekly	Weekly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Daily	Daily	Daily	Daily	Weekly	Weekly	Weekly	Monthly	Monthly	Monthly	Monthly
1-Dec	45,800									69712	2	>11	<1.8							
2-Dec	65,500									67422	1.7	>11	<1.8							
3-Dec	88,300									61350	2	>11	<1.8							
4-Dec	41,100									44416	1.9	>11	<1.8							
5-Dec	57,100									91271	1.8	>11	<1.8							
6-Dec	53,100	7.2	1120				7.3			87901	2	>11	<1.8	7.3			1210			
7-Dec	79,200									81664	2	>11	<1.8							
8-Dec	49,900									64544	2	>11	4.5							
9-Dec	67,100									87200	2	>11	<1.8		ND	ND				
10-Dec	59,700									71277	2	>11	1600							
11-Dec	47,000									15923	2	>11	<1.8							
12-Dec	47,900									52177	2	>11	<1.8							
13-Dec	47,500	7.4	1250							54091	1.8	>11	<1.8	7.4						
14-Dec	52,200									64209	2	>11	<1.8							
15-Dec	54,300									71739	2	>11	<1.8		3.80	ND				
16-Dec	53,700									72476	1.9	>11	1600							
17-Dec	55,100									142878	2.4	>11	<1.8							
18-Dec	64,200									33905	2.1	>11	<1.8	7.5						
19-Dec	55,000	7.3	1170								2.5	>11	<1.8							
20-Dec	56,300										3	>11	1600							
21-Dec	56,300																			
22-Dec	56,400																			
23-Dec	88,900																			
24-Dec	68,500																			
25-Dec	88,100																			
26-Dec	52,600	7.5	1210																	
27-Dec	52,200																			
28-Dec	53,200																			
29-Dec	57,100			790.0	120.00	110.00	7.10	7.30												
30-Dec	51,100																			
31-Dec	68,500																			
TOTAL	1,775,300																			
AVG	57,286	7.4	1,188	790	120	110	7	7.1	7.3	66,564	2.06	#DIV/0!	1,800.0	7.4	3.80	#DIV/0!	1,210	#DIV/0!	#DIV/0!	#DIV/0!
MINIMUM	41,100	7.2	1,120	790	120	110	7	7.1	7.3	15,923	1.70	0.0	1,800.0	7.3	3.80	0.0	1,210	0	0.00	0.0
MAXIMUM	79,200	7.5	1,250	790	120	110	7	7.1	7.3	142,878	3.00	0.0	1,800.0	7.5	3.80	0.0	1,210	0	0.00	0.0
Requirement #1	AVG - 100	Min 6.5		0.0						AVG. 2.0			MED 2.2	Min 6.5						
Times Exceeded	#N/A	1.0	0.0	#N/A						#N/A			0	0						
Requirement #2	Max 6.5			0						Max 10			Max 23	Max 6.5	Max 10	Max 10		Max 1500		
Times Exceeded	0			0						0			3.0	0	1	0		0		

J. P. ...
 Signature of Principle Executive Officer or Authorized Agent

Recycling Facility

		Recycled Water Storage Pond Monitoring						Recycled Water Area Monitoring							Surface Water Monitoring S-1						
Total N	NH ₃ as N	Freeboard	D.O.	pH	EC	TDS	Total N	Flow	Rainfall	Acreage	Application	Application	Total	TDS	pH	EC	TDS	Nitrate(N)	NH ₃ as N	Flow	
Effluent	Effluent	Pond	Pond	Pond	Pond	Pond	Pond	Irrigation		Applied	Rate	Period	Nitrogen		Irrigation	Irrigation	Irrigation	Irrigation	Irrigation	Irrigation	
mg/L	mg/L	Feet	mg/L	pH units	umhos/cm	mg/L	mg/L	GPD	Inches	acres	gal/acre/day	Hours	lbs/month	lbs/month	pH units	umhos/cm	mg/L	mg/L	mg/L	GPM	
Grab	Grab	Measurement	Grab	Grab	Grab	Grab	Grab	Measurement	Measured	Calculated	Calculated	Measured	Calculated	Calculated	Grab	Grab	Grab	Grab	Grab	Grab	Estimated
Monthly	Monthly	Weekly	Weekly	Weekly	Monthly	Monthly	Monthly	Weekly	Daily	Daily	Daily	Daily	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Weekly
		10.48							0												
									0												
									0												
									0												
			10.1	7.4	1315				0												
									0												
		9.79							0												
									0												
									0												
									0												
			10.2	7.4					0												
									0												
									0												
									0												
									0												
			11.1	7.3					0												
									0.01												
									0												
									0												
									0												
									0												
			10.5	7.1					0												
									0												
						700	6.10		0												
									0												
									0												
									0.01												
#DIV/0!	#DIV/0!	#DIV/0!	10.48	7.30	1,315	700	6.1	#DIV/0!	0.00	#DIV/0!	#DIV/0!			#DIV/0!							
0.00	0.00	0.00	10.10	7.10	1,315	700	6.1	0.00	0.00	0.0	0.00	0	0.0	0							
0.00	0.00	0.00	11.10	7.40	1,315	700	6.1	0	0.01	0.0	0.00	0	0.0	0							

CALIFORNIA LABORATORY SERVICES

Page 2 of 3

12/08/17 16:33

National O&M, Inc
P.O. Box 21187
Roanoke, VA 24018

Project: Wild Wings Recycling Facility
Project Number: [none]
Project Manager: Paul Bishop

CLS Work Order #: 17L0027
COC #: 185311

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17L0027-01) WW Sampled: 12/01/17 09:00 Received: 12/01/17 12:55									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709217	12/01/17	12/03/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

Page 2 of 3

12/11/17 12:15

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17L0054 COC #: 185313
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17L0054-01) WW Sampled: 12/02/17 09:00 Received: 12/02/17 13:00									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709231	12/02/17	12/04/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

Page 2 of 3

12/11/17 12:16

National O&M, Inc
P.O. Box 21187
Roanoke, VA 24018

Project: Wild Wings Recycling Facility
Project Number: [none]
Project Manager: Paul Bishop

CLS Work Order #: 17L0056
COC #: 185312

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17L0056-01) WW Sampled: 12/03/17 09:00 Received: 12/03/17 12:00									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709256	12/03/17	12/05/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17L0104 COC #: 185314
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17L0104-01) WW Sampled: 12/04/17 09:00 Received: 12/04/17 15:15									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709274	12/04/17	12/06/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

Page 2 of 3

12/12/17 15:30

National O&M, Inc
P.O. Box 21187
Roanoke, VA 24018

Project: Wild Wings Recycling Facility
Project Number: [none]
Project Manager: Paul Bishop

CLS Work Order #: 17L0153
COC #: 185315

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17L0153-01) WW Sampled: 12/05/17 09:00 Received: 12/05/17 12:28									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709302	12/05/17	12/07/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17L0242 COC #: 185316
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17L0242-01) WW Sampled: 12/06/17 09:00 Received: 12/06/17 12:35									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709344	12/06/17	12/08/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17L0322 COC #: 185317
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17L0322-01) WW Sampled: 12/07/17 09:00 Received: 12/07/17 12:00									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709390	12/07/17	12/09/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17L0371 COC #: 185318
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17L0371-01) WW Sampled: 12/08/17 09:00 Received: 12/08/17 12:20									
Total Coliforms	4.5	1.8	MPN/100 mL	1	1709432	12/08/17	12/12/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17L0393 COC #: 185319
--	--	--

Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff. (17L0393-02) WW Sampled: 12/09/17 08:40 Received: 12/09/17 13:00									
Biochemical Oxygen Demand	ND	3.0	mg/L	1	1709453	12/10/17	12/15/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1709465	12/11/17	12/11/17	SM2540D	
MLSS (17L0393-03) WW Sampled: 12/09/17 06:45 Received: 12/09/17 13:00									
Total Suspended Solids	1500	5.0	mg/L	1	1709465	12/11/17	12/11/17	SM2540D	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17L0393 COC #: 185319
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff (17L0393-01) WW Sampled: 12/09/17 09:00 Received: 12/09/17 13:00									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709451	12/09/17	12/11/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

Page 2 of 3

12/20/17 16:36

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17L0400 COC #: 185320
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Tert Eff (17L0400-01) WW Sampled: 12/10/17 09:00 Received: 12/10/17 11:45									
Total Coliforms	>1600	1.8	MPN/100 mL	1	1709466	12/10/17	12/12/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17L0421 COC #: 185321
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17L0421-01) WW Sampled: 12/11/17 09:00 Received: 12/11/17 12:10									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709477	12/11/17	12/13/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

Page 2 of 3

12/19/17 15:07

National O&M, Inc
P.O. Box 21187
Roanoke, VA 24018

Project: Wild Wings Recycling Facility
Project Number: [none]
Project Manager: Paul Bishop

CLS Work Order #: 17L0505
COC #: 185322

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17L0505-01) WW Sampled: 12/12/17 09:00 Received: 12/12/17 13:45									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709541	12/12/17	12/14/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17L0562 COC #: 185324
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17L0562-01) WW Sampled: 12/13/17 08:30 Received: 12/13/17 13:15									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709581	12/13/17	12/15/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

Page 2 of 3

12/21/17 15:04

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17L0627 COC #: 185325
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17L0627-01) WW Sampled: 12/14/17 09:00 Received: 12/14/17 13:00									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709619	12/14/17	12/16/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17L0687 COC #: 185326
--	--	--

Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17L0687-02) WW Sampled: 12/15/17 08:30 Received: 12/15/17 11:55									
Biochemical Oxygen Demand	3.8	3.0	mg/L	1	1709644	12/15/17	12/20/17	SM5210B	
Total Suspended Solids	ND	5.0	"	"	1709721	12/19/17	12/19/17	SM2540D	
MLSS (17L0687-03) WW Sampled: 12/15/17 08:45 Received: 12/15/17 11:55									
Total Suspended Solids	3000	5.0	mg/L	1	1709721	12/19/17	12/19/17	SM2540D	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17L0687 COC #: 185326
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17L0687-01) WW Sampled: 12/15/17 09:00 Received: 12/15/17 11:55									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709658	12/15/17	12/17/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17L0723 COC #: 185328
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Wild Wings (17L0723-01) WW Sampled: 12/16/17 09:00 Received: 12/16/17 12:50									
Total Coliforms	>1600	1.8	MPN/100 mL	1	1709690	12/16/17	12/19/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

Page 2 of 3

12/26/17 13:33

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17L0735 COC #: 185329
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17L0735-01) WW Sampled: 12/17/17 09:00 Received: 12/17/17 11:48									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709691	12/17/17	12/19/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

Page 2 of 3

12/26/17 13:34

National O&M, Inc
P.O. Box 21187
Roanoke, VA 24018

Project: Wild Wings Recycling Facility
Project Number: [none]
Project Manager: Paul Bishop

CLS Work Order #: 17L0753
COC #: 185330

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17L0753-01) WW Sampled: 12/18/17 09:00 Received: 12/18/17 12:15									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709699	12/18/17	12/20/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17L0818 COC #: 185331
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17L0818-01) WW Sampled: 12/19/17 09:00 Received: 12/19/17 11:55									
Total Coliforms	<1.8	1.8	MPN/100 mL	1	1709736	12/19/17	12/21/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17L0901 COC #: 185332
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
tert. Eff. (17L0901-01) WW Sampled: 12/20/17 09:00 Received: 12/20/17 12:09									
Total Coliforms	>1600	1.8	MPN/100 mL	1	1709776	12/20/17	12/22/17	SM 9221	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17L1033 COC #: 185333
--	--	--

Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MLSS (17L1033-01) Wastewater Sampled: 12/23/17 08:00 Received: 12/23/17 09:37									
Total Suspended Solids	3100	5.0	mg/L	1	1709872	12/26/17	12/26/17	SM2540D	

CALIFORNIA LABORATORY SERVICES

National O&M, Inc P.O. Box 21187 Roanoke, VA 24018	Project: Wild Wings Recycling Facility Project Number: [none] Project Manager: Paul Bishop	CLS Work Order #: 17L1220 COC #: 185335
--	--	--

Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Inf. (17L1220-01) Wastewater Sampled: 12/29/17 08:00 Received: 12/29/17 11:35									
Biochemical Oxygen Demand	120	3.0	mg/L	1	1709976	12/29/17	01/03/18	SM5210B	
Total Dissolved Solids	790	10	"	"	1800012	01/02/18	01/03/18	SM2540C	
Total Suspended Solids	110	5.0	"	"	1800010	01/02/18	01/02/18	SM2540D	
2nd Eff. (17L1220-02) Wastewater Sampled: 12/29/17 08:00 Received: 12/29/17 11:35									
Biochemical Oxygen Demand	7.1	3.0	mg/L	1	1709976	12/29/17	01/03/18	SM5210B	
Total Suspended Solids	7.3	5.0	"	"	1800010	01/02/18	01/02/18	SM2540D	
MLSS (17L1220-03) Wastewater Sampled: 12/29/17 08:00 Received: 12/29/17 11:35									
Total Suspended Solids	2800	5.0	mg/L	1	1800010	01/02/18	01/02/18	SM2540D	
Storage Pond (17L1220-04) Wastewater Sampled: 12/29/17 08:00 Received: 12/29/17 11:35									
Nitrate/Nitrite as N	4.8	2.0	mg/L	5	1709964	12/29/17	12/29/17	EPA 300.0	
Total Dissolved Solids	700	10	"	1	1800012	01/02/18	01/03/18	SM2540C	
Total Kjeldahl Nitrogen	1.3	1.0	"	5	1800030	01/02/18	01/02/18	SM4500-NH3F-1997	
Total Nitrogen	6.1	0.40	"	1	1800031	01/02/18	01/02/18	EPA 351.3/300	