## Quarterly Report for Disinfectant Residuals Compliance For Systems Using Chlorine or Chloramines

System Name:	WILD WINGS	System No .:	5710011
,		-,	

Calendar Year:

2018

Quarter: 1

1st Quarter			
Month		Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
	April		1.00
Previous Year	May		1.10
	June		0.90
	July		1.00
	August		1.00
	September		1.10
	October		1.00
	November		1.00
	December		1.00
Current Year	January	2	1.20
	February		1.15
Curr	March		1.35
Running Annual Average (RAA):		1.07	
Μ	eets standard?		✓ Yes
(i.e. RAA $\leq$ MRDL of 4.0 mg/L as Cl <sub>2</sub> )		V No	

2nd Quarter			
Month		Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
Previous Year	July		1.00
	August		1.00
	September		1.10
evior	October		1.00
ŗ	November		1.00
	December		1.00
	January		1.20
a	February		1.15
it Ye	March		1.35
Current Year	April		1.10
ü	May		1.25
	June		1.27
Running Annual Average (RAA):		1.12	
Meets standard? (i.e. RAA <u>&lt;</u> MRDL of 4.0 mg/L as Cl <sub>2</sub> )		<ul><li>✓ Yes</li><li>No</li></ul>	

3rd Quarter			
Month		Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
s Yr	October		1.00
Previous Yr	November		1.00
Pre	December		1.00
	January		1.20
	February		1.15
	March		1.35
'ear	April		1.10
Current Year	May		1.25
Curr	June		1.27
	July		1.10
	August		1.05
	September		1.00
Running Annual Average (RAA):		1.12	
Meets standard?		✓ Yes	
(i.e. RAA $\leq$ MRDL of 4.0 mg/L as Cl <sub>2</sub> )		No No	

4th Quarter			
Month		Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
	January		1.20
	February		1.15
	March		1.35
	April		1.10
ы	May		1.25
Current Year	June		1.27
urrer	July		1.10
C	August		1.05
	September		1.00
	October		0.90
	November		1.80
	December		1.35
Running Annual Average (RAA):		1.21	
Meets standard? (i.e. RAA <u>&lt;</u> MRDL of 4.0 mg/L as Cl <sub>2</sub> )		✓ Yes No	

Comments:

Signature:

Paul Bishop

Date:

2/6/2014