



April 17, 2018

State Water Resources Control Board  
Division of Drinking Water  
Salvador Turrubiartes, P.E., Associate Sanitary Engineer  
1001 I St, 13<sup>th</sup> Floor  
Sacramento, CA 95834

**Regarding: CA57100011-Wild Wings-1Q-MRDL**

Mr. Turrubiartes

Specialized Utilities Services Program, Inc., on behalf of the Wild Wings C.S.A. has prepared and is submitting to the Division of Drinking Water, the CA 57100011-Wild Wings-1Q-MRDL

Enclosed are the 1<sup>st</sup> Quarter Report for Disinfectant Residuals Compliance and analytical results.

Please note that no analytical results for February are included. No analytical or data available for the month of February.

Please contact me if you have any questions.

Sincerely yours,

A handwritten signature in blue ink, appearing to read "Dan DeMoss", is written over a light blue horizontal line.

Dan DeMoss.  
Operator  
Phone: (916) 616-7761  
Email: [ddemoss@calruralwater.org](mailto:ddemoss@calruralwater.org)

Quarterly report for Disinfectant Residuals Compliance  
For Systems Using Chlorine or Chloramines

System Name: Wild Wings  
Calendar Year: 2018

System No : 5710011  
Quarter: 1

1st Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Previous Year	April	1.0
	May	1.1
	June	0.9
	July	1.0
	August	1.0
	September	1.1
	October	1.0
	November	1.0
	December	1.0
	Current Year	January
February		*
March		2
Running Annual Average (RAA):		1.0
Meets standard? (i.e. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No)		RAA ≤ MRDL of 4.0 mg/l as cl <sub>2</sub>

2nd Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Previous Year	July	
	August	
	September	
	October	
	November	
	December	
Current Year	January	
	February	
	March	
	April	
	May	
	June	
Running Annual Average (RAA):		
Meets standard? (i.e. <input type="checkbox"/> Yes <input type="checkbox"/> No)		RAA ≤ MRDL of 4.0 mg/l as cl <sub>2</sub>

3rd Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Current Year	October	
	November	
	December	
Previous Year	January	
	February	
	March	
	April	
	May	
	June	
	July	
	August	
	September	
Running Annual Average (RAA):		
Meets standard? (i.e. <input type="checkbox"/> Yes <input type="checkbox"/> No)		RAA ≤ MRDL of 4.0 mg/l as cl <sub>2</sub>

4th Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Current Year	January	
	February	
	March	
	April	
	May	
	June	
	July	
	August	
	September	
	October	
	November	
	December	
Running Annual Average (RAA):		
Meets standard? (i.e. <input type="checkbox"/> Yes <input type="checkbox"/> No)		RAA ≤ MRDL of 4.0 mg/l as cl <sub>2</sub>

Comments: \* No analytical or data available for the month of February.

Signature:  
2/6/2014

Date:

# CALIFORNIA LABORATORY SERVICES

Page 2 of 3

01/19/18 14:43

National O&M, Inc  
P.O. Box 21187  
Roanoke, VA 24018

Project: Wild Wings Recycling Facility  
Project Number: [none]  
Project Manager: Paul Bishop

CLS Work Order #: 18A0755  
COC #: 181489

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Mallard (18A0755-01) Water</b> Sampled: 01/12/18 08:00 Received: 01/12/18 12:15									
E. Coli	Absent	0.0	N/A	1	1800392	01/12/18	01/13/18	SM 9223	
Residual Chlorine	1.20	0.10	mg/L	"	"	01/12/18	01/12/18	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	01/12/18	01/13/18	SM 9223	
<b>Mandarin (18A0755-02) Water</b> Sampled: 01/12/18 08:15 Received: 01/12/18 12:15									
E. Coli	Absent	0.0	N/A	1	1800392	01/12/18	01/13/18	SM 9223	
Residual Chlorine	1.20	0.10	mg/L	"	"	01/12/18	01/12/18	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	01/12/18	01/13/18	SM 9223	

CA SWRCB ELAP Accreditation/Registration Number 1233

3249 Fitzgerald Road Rancho Cordova, CA 95742

www.californialab.com

916-638-7301

Fax: 916-638-4510

