



July 2, 2018

State Water Resources Control Board
Division of Drinking Water
Salvador Turrubiartes, P.E., Associate Sanitary Engineer
1001 I St, 13th Floor
Sacramento, CA 95834

Regarding: CA57100011-Wild Wings-1Q-MRDL

Mr. Turrubiartes

Specialized Utilities Services Program, Inc., on behalf of the Wild Wings C.S.A. has prepared and is submitting to the Division of Drinking Water, the CA 57100011-Wild Wings-2nd Q-MRDL

Enclosed are the 2nd Quarter Report for Disinfectant Residuals Compliance and analytical results.

Please contact me if you have any questions.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Dan DeMoss", is written over a light blue horizontal line.

Dan DeMoss.

Operator

Phone: (916) 616-7761

Email: ddemoss@calruralwater.org

Quarterly report for Disinfectant Residuals Compliance
For Systems Using Chlorine or Chloramines

System Name: Wild Wings

System No : 5710011

Calendar Year: 2018

Date: July 2, 2018

1st Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Previous Year	April	1.0
	May	1.1
	June	0.9
	July	1.0
	August	1.0
	September	1.1
	October	1.0
	November	1.0
	December	1.0
	Current Year	January
February		2
March		2
Running Annual Average (RAA):		1.1
Meets standard? (i.e. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No)		RAA ≤ MRDL of 4.0 mg/l as cl ₂

2nd Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Previous Year	July	
	August	
	September	
	October	
	November	
	December	
	Current Year	January
February		2
March		2
April		2
May		2
June		2
Running Annual Average (RAA):		
Meets standard? (i.e. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No)		RAA ≤ MRDL of 4.0 mg/l as cl ₂

3rd Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Current Year	October	
	November	
	December	
Previous Year	January	
	February	
	March	
	April	
	May	
	June	
	July	
	August	
	September	
Running Annual Average (RAA):		
Meets standard? (i.e. <input type="checkbox"/> Yes <input type="checkbox"/> No)		RAA ≤ MRDL of 4.0 mg/l as cl ₂

4th Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Current Year	January	
	February	
	March	
	April	
	May	
	June	
	July	
	August	
	September	
	October	
	November	
	December	
Running Annual Average (RAA):		
Meets standard? (i.e. <input type="checkbox"/> Yes <input type="checkbox"/> No)		RAA ≤ MRDL of 4.0 mg/l as cl ₂

Comments:

Signature: 

Date: 7/10/2018



CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.

04/25/18 12:54

Page 2 of 3

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 18D0980 COC #: 186492
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mandarin D Sample Site (18D0980-01) Water Sampled: 04/18/18 07:30 Received: 04/18/18 11:55									
E. Coli	Absent	0.0	N/A	1	1803231	04/18/18	04/19/18	SM 9223	
Residual Chlorine	1.00	0.10	mg/L	"	"	04/18/18	04/18/18	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	04/18/18	04/19/18	SM 9223	

2



California Rural Water Association
1234 N. Market Blvd.
Sacramento, CA 95834

Project: Wild Wings
Project Number: [none]
Project Manager: Dan Demoss

CLS Work Order #: 18D0609
COC #: 186457

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
18118 Malard (18D0609-01) Water Sampled: 04/11/18 08:25 Received: 04/11/18 12:00									
Residual Chlorine	0.90	0.10	mg/L	1	1803009	04/11/18 08:25	04/11/18	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	04/11/18 12:30	04/12/18	SM 9223	
E. Coli	Absent	0.0	"	"	"	"	"	"	



California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 18E0506 COC #: 189306
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mandarin D Sample Site (18E0506-01) Water Sampled: 05/09/18 08:05 Received: 05/09/18 12:00									
E. Coli	Absent	0.0	N/A	1	1803870	05/09/18	05/10/18	SM 9223	
Residual Chlorine	0.92	0.10	mg/L	"	"	05/09/18	05/09/18	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	05/09/18	05/10/18	SM 9223	



California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 18E0924 COC #: 189307
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mallard D Sample Site (18E0924-01) Water Sampled: 05/16/18 08:00 Received: 05/16/18 12:40									
E. Coli	Absent	0.0	N/A	1	1804089	05/16/18	05/17/18	SM 9223	
Residual Chlorine	N/A	0.10	mg/L	"	"	05/16/18	05/16/18	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	05/16/18	05/17/18	SM 9223	

WATER



California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 18F0314 COC #: 189443
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mandarin D Sample Site (18F0314-01) Water Sampled: 06/06/18 08:01 Received: 06/06/18 12:25									
E. Coli	Absent	0.0	N/A	1	1804660	06/06/18	06/07/18	SM 9223	
Residual Chlorine	0.86	0.10	mg/L	"	"	06/06/18	06/06/18	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	06/06/18	06/07/18	SM 9223	

WATER



CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 18F0700 COC #: 189455
--	--	---

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mallard 'D' Sample Site (18F0700-01) Water Sampled: 06/13/18 08:05 Received: 06/13/18 12:30									
Residual Chlorine	1.20	0.10	mg/L	1	1804894	06/13/18 08:05	06/13/18	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	06/13/18 13:00	06/14/18	SM 9223	
E. Coli	Absent	0.0	"	"	"	"	"	"	