

Wastewater

Daily Operations:

The day-to-day operations are going well some notable issues were:

- In regards to equipment we have had blower issues that have been resolved currently but may need to be revisited.
- We have found glitches in the SCADA monitoring that is being addressed ongoing.
- Influent Lift station A pump B failure is being addressed.

Upcoming Projects:

- Emergency Overflow Pond cleaning.
- Recycle Pond cleaning.
- Storm Water Pond Cleaning – will be done based on prevailing North winds and public notification.
- Wastewater Plant Cleanup - The plant itself is in good shape, but the grounds need work. We will be ordering the first of several 20-yard dumpsters to clean up the debris and garbage around the plant.

Water

Daily Operations:

Staff have cleaned up the well sites and have familiarized themselves with system operations.

- In regards to equipment we experienced trouble with a broken check valve on the VFD drive for the jockey pump.
- A valve exercising program has been established.
- All Cla-Valves at Pintail and Canvasback have been serviced by the Cla-Valve company. We have five Cla-Valves left to service on the pond system and those should be done in the next month.
- We flushed the system and are developing a unidirectional flushing program. It will be implemented starting in October/November.

Upcoming Projects:

- The Itron reader needs to be correlated with the appropriate numbers on each meter and then activated with the Itron system.