

October 2018

Wastewater

Daily Operations:

The wastewater plant is running well. We have some equipment issues but were working through them. We have started the recycle pond and irrigation wet well project and will continue to remove old chemicals from the plant.

- New hypo tank is in use - tank has telemetry installed, but we need to meet with Univar on how to access
- Mud well - secondary EQ tank pumped out to remove snails and sludge
- Yardley irrigation pumping station completed
- Continue to treat for odors and FOG
- The starter has been replaced on the generator
- Chlorinating and monitoring recycle pond ready to start pumping any day - waiting on lab results

Upcoming Projects:

- Need SCADA repaired
- Emergency pond and recycle pond cleaning
- Slide gate repair on irrigation wet well
- Blower to EQ needs replaced
- Cat walk lighting needs repairing
- Polymer flash mixer

Water

Daily Operations:

Day operations are doing fine. We are caught up on water samples and will start on 4th quarter water sampling.

- Tel star calibrated meters at Pintail
- New hypo tank in use - tank has telemetry installed, but we need to meet with Univar on how to access
- Reservoir inspections completed - locked bottom latter access but the upper has not been secured (We need to order a harnesses and rail system fall protection)

Upcoming Projects:

- Generator at Pintail needs on board battery charger
- Itron Tech support to finish training and converting proper Transmitter ID numbers
- Cla-Valves ordered and will be installed shortly.