

*September 2018*

## Wastewater

---

### Daily Operations:

The day-to-day operations are going well some notable issues and tasked completed were

- Installed Micro Lift/IND probes at Site A & B (Lift Stations) for odor control and FOG control.
- Influent screen installed and operational.
- Influent submersible pumps installed site A completed.
- Storm Pond completed.
- Wastewater Plant nearly completed (still removing old chemicals).
- New Chlorine Tank delivered.
- Irrigation Pump #1 replaced.
- Recycled Pond Ladder installed.
- Wastewater Backflow assembly installed.
- Groundwater monitoring sampling (completed tomorrow).
- Emergency Generators Serviced.

### Upcoming Projects:

- Emergency overflow Pond clean up
- Recycle Pond clean up.
- Sludge Judge 2”to 8” from the inlet to east bank, sludge looks more like algae than solids
- Patriot environmental, Aqua Natural, and Blue frog will be putting in bid proposals for removal of irrigation pumps and filter rebuild.

## Water

---

**Daily Operations:** We will be receiving a Notice of Violation (NOV) for missing the 2<sup>nd</sup> quarter sampling for the Contaminant TCP 123 this is a new contaminant for sampling, the 1<sup>st</sup> and 3<sup>rd</sup> quarters were non-detect the NOV is simply for not taking the sample during the required quarter. The day to day operations are going well notable issues and tasked complete were:

- Cla-Valve maintenance
- Dedicated sampling site repair and maintenance.
- Emergency power generator serviced
- Quarterly sampling completed TCP 123 as well all sampling caught up per the state from as far back as 2015.
- Continue to monitor groundwater levels.

### Upcoming Projects:

- Quiet Check valves replacement at Pintail with Cla-Valve assemblies.
- Currently two bids have been received for installs of Cla-Valves.
- Ongoing SCADA up grades.
- Iron meter reading resolving IP address and ERT ID issues.
- Lowering of the bowls on both well sites.