



December 5, 2018

State Water Resources Control Board  
Division of Drinking Water  
Salvador Turrubiartes, P.E., Associate Sanitary Engineer  
1001 I St, 13<sup>th</sup> Floor  
Sacramento, CA 95834

**Regarding: Wild Wings C.S.A. November 2018 Monthly Water System Report**

Mr. Turrubiartes,

Specialized Utilities Services Program, Inc., on behalf of the Wild Wings C.S.A. has prepared and is submitting to the Division of Drinking Water, the November 2018 Monthly Water Monitoring Report.

Enclosed are the November Monthly Water System Flow Report, Summary of Distribution System Coliform Monitoring Report, the laboratory analytical results for bacteriological testing,

Please contact me if you have any questions.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Dan DeMoss". The signature is fluid and cursive, written over a white background.

Dan DeMoss.  
Operator  
Phone: (916) 616-7761  
Email: [ddemoss@calruralwater.org](mailto:ddemoss@calruralwater.org)

## MONTHLY SUMMARY OF DISTRIBUTION SYSTEM COLIFORM MONITORING

System Name <p style="text-align: center; font-size: 1.2em;">Wild Wings</p>	System Number <p style="text-align: center; font-size: 1.2em;">571011</p>
Sampling Period <p style="text-align: center; font-size: 1.2em; color: blue;">November</p>	Year <p style="text-align: center; font-size: 1.2em;">2018</p>

	Number Required	Number Collected	Number Total Coliform Positives	Number Fecal/ E.coli Positives
1. Routine Samples (see note 1)	<u>2</u>	<u>2</u>	<u>0</u>	<u>0</u>
2. Repeat Samples Following Samples Which are Total Coliform Positive and Fecal/E.coli <i>Negative</i> (see notes 5 and 6)		<u>0</u>	<u>0</u>	<u>0</u>
3. Repeat Samples Following Routine Samples Which are Total Coliform <i>Positive</i> and Fecal/E.coli Positive (see notes 5 and 6)		<u>0</u>	<u>0</u>	<u>0</u>
4. MCL Computation For Total Coliform Positive Samples				
a. Totals (sum of columns)	<u>0</u>	<u>0</u>	<u>0</u>	
b. If 40 or more samples collected in month, determine percent of samples that are total coliform positive [(total number positive/total number collected) x 100]	<u>0</u>			
c. Is system in compliance. . . with fecal/E. coli MCL? (see notes 2 and 3)		<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
. . . with monthly MCL? (see note 4)		<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	

5. Invalidated Samples  
(Note what samples, if any, were invalidated; who authorized the invalidation; and when replacement samples were collected. Attach additional sheets, if necessary.)

6. Summary Completed By:

Signature 	Title <p style="text-align: center; font-size: 1.2em;">Water Operator</p>	Date <p style="text-align: center; font-size: 1.2em;">12/5/2018</p>
---------------	--	--

**NOTES AND INSTRUCTIONS:**

1. Routine samples include:
    - a. Samples required pursuant to 22 CCR Section 64423, and any additional samples required by an approved routine sample siting plan established pursuant to 22 CCR Section 64422.
    - b. Extra samples required for systems collecting less than five routine samples per month that had one or more total coliform positives in previous month;
    - c. Extra samples for systems with high source water turbidities that are using surface water or groundwater under direct influence of surface water and do not practice filtration in compliance with regulations;
  2. Note: For a repeat sample following a total coliform positive sample, any fecal/E.coli positive repeat (boxed entry) **constitutes an MCL violation and requires immediate notification to the department** (22, CCR, Section 64426.1).
  3. Note: For repeat sample following a fecal/E.coli positive sample, any total coliform positive repeat (boxed entry) **constitutes an MCL violation and requires immediate notification to the department** (22, CCR, Section 64426.1).
  4. Total coliform MCL (**Notify Department within 24 hours of MCL violation**):
    - a. For systems collecting less than 40 samples, if two or more samples are total coliform positive, then the MCL is violated.
    - b. For systems collecting 40 or more samples, if more than 5.0 percent of samples collected are total coliform positive, then the MCL is violated.
  5. Positive results and their associated repeat samples must be tracked on the worksheet on the other side.
  6. For systems collecting more than one routine sample per month, three repeat samples must be collected for each total coliform positive sample. Repeat samples must be collected within 24 hours of being notified of the positive results.
  7. For systems collecting one or less routine samples per month, four repeat samples must be collected for each total coliform positive sample.
- CDPH 8477 (10/2007)


Date	PINTAIL WELL SITE			CANVAS WELL SITE			MONTH: Nov-18		
	Meter Read	Flow MGD	Reservoir CL <sub>2</sub> Residual	Meter Read	Flow MGD	Reservoir CL <sub>2</sub> Residual	Mallard CL <sub>2</sub> Residual	Mandarian CL <sub>2</sub> Residual	Total Volume MGD
1	1381.1063	0.2461	1.2	1156.2537	0.2430	N/A	0.97	1.00	0.4891
2	1381.3524	0.2279	0.75	1156.4967	0.1509	N/A	0.71	0.80	0.3788
3	1381.5803	0.2529	1.3	1156.6476	0.2645	N/A	*	*	0.5174
4	1381.8332	0.25	0.89	1156.9121	0.1085	N/A	*	*	0.3585
5	1382.0832	0.2248	0.99	1157.0206	0.1502	N/A	*	*	0.3750
6	1382.308	0.2536	1.09	1157.1708	0.2325	N/A	1.22	1.02	0.4861
7	1382.5616	0.2418	1.37	1157.4033	0.0600	N/A	1.45	1.33	0.3018
8	1382.8034	0.1778	0.83	1157.4633	0.0560	N/A	1.00	0.94	0.2338
9	1382.9812	0.225	1	1157.5193	0.1706	N/A	1.19	1.14	0.3956
10	1383.2062	0.2363	0.9	1157.6899	0.2528	N/A	*	*	0.4891
11	1383.4425	0.2266	0.75	1157.9427	0.0000	N/A	*	*	0.2266
12	1383.6691	0.2176	0.55	1157.9427	0.2397	N/A	*	*	0.4573
13	1383.8867	0.1154	0.81	1158.1824	0.0000	N/A	0.79	0.84	0.1154
14	1384.0021	0.2987	0.87	1158.1824	0.0000	N/A	0.81	0.78	0.2987
15	1384.3008	0.1671	0.98	1158.1824	0.0000	N/A	0.79	0.82	0.1671
16	1384.4679	0.2183	0.56	1158.1824	0.0640	N/A	0.55	0.60	0.2823
17	1384.6862	0.1677	0.52	1158.2464	0.1062	N/A	*	*	0.2739
18	1384.8539	0.2329	0.79	1158.3526	0.0578	N/A	*	*	0.2907
19	1385.0868	0.1464	0.86	1158.4104	0.0769	N/A	0.81	0.92	0.2233
20	1385.2332	0.2173	1.36	1158.4873	0.0000	N/A	1.10	1.01	0.2173
21	1385.4505	0.145	0.78	1158.4873	0.0167	N/A	0.75	0.79	0.1617
22	1385.5955	0.1411	1.06	1158.504	0.0000	N/A	*	*	0.1411
23	1385.7366	0.0701	0.9	1158.504	0.0201	N/A	*	*	0.0902
24	1385.8067	0.1431	0.76	1158.5241	0.0010	N/A	0.80	0.81	0.1441
25	1385.9498	0.1409	0.82	1158.5251	0.0628	N/A	0.97	0.63	0.2037
26	1386.0907	0.1408	1.11	1158.5879	0.1089	N/A	0.99	1.02	0.2497
27	1386.2315	0.1165		1158.6968	0.0104	N/A	*	*	0.1269
28	1386.348	0.098	1.1	1158.7072	0.0000	N/A	1.05	1.03	0.0980
29	1386.446	0.1382	1.18	1158.7072	0.0161	N/A	*	*	0.1543
30	1386.5842	0.0603	1.11	1158.7233	0.1515	N/A	1.10	1.01	0.2118
1	1386.6445			1158.8748					

Max	0.2987
Min	0.0603
Avg	0.1846
Total	5.5382

Max	0.2645
Min	0.0000
Avg	0.0874
Total	2.6211

Max	0.5174
Min	0.0902
Avg	0.2720
Total	8.1593

\* No chlorine residuals taken.




# CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 18K0431 COC #: 19253
--	--	---

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Mandarin P/A (18K0431-01) Water</b> <b>Sampled: 11/07/18 08:15</b> <b>Received: 11/07/18 12:30</b>									
E. Coli	Absent	0.0	N/A	1	1809538	11/07/18	11/08/18	SM 9223	
Residual Chlorine	1.33	0.10	mg/L	"	"	11/07/18	11/07/18	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	11/07/18	11/08/18	SM 9223	



**CALIFORNIA LABORATORY SERVICES**  
Committed. Responsive. Flexible.

*MALLARD*

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 18K1248 COC #: 19315
--	--	---

**Microbiological Parameters by APHA Standard Methods**

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Mallard 'D' Site (18K1248-01) DW</b> <b>Sampled: 11/21/18 08:00</b> <b>Received: 11/21/18 12:00</b>									
Residual Chlorine	0.75	0.10	mg/L	1	1809984	11/21/18 08:00	11/21/18	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	11/21/18 12:40	11/22/18	SM 9223	
E. Coli	Absent	0.0	"	"	"	"	"	"	