



January 7, 2019

State Water Resources Control Board
Division of Drinking Water
Salvador Turrubiartes, P.E., Associate Sanitary Engineer
1001 I St, 13th Floor
Sacramento, CA 95834

Regarding: CA57100011-Wild Wings-4th-MRDL

Mr. Turrubiartes

Specialized Utilities Services Program, Inc., on behalf of the Wild Wings C.S.A. has prepared and is submitting to the Division of Drinking Water, the CA 57100011-Wild Wings-4th Q-MRDL

Enclosed are the 4th Quarter Report for Disinfectant Residuals Compliance and analytical results.

Please contact me if you have any questions.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Dan DeMoss", is written over a white background.

Dan DeMoss.
Operator
Phone: (916) 616-7761
Email: ddemoss@calruralwater.org

Quarterly report for Disinfectant Residuals Compliance
For Systems Using Chlorine or Chloramines

System Name: Wild Wings
Calendar Year: 2018

System No : 5710011
Date: January 5, 2018

1st Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Previous Year	April	1.0
	May	1.1
	June	0.9
	July	1.0
	August	1.0
	September	1.1
	October	1.0
	November	1.0
	December	1.0
	Current Year	January
February		2
March		2
Running Annual Average (RAA):		1.1
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/l as cl ₂)		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

2nd Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Previous Year	July	1.0
	August	1.0
	September	1.1
	October	1.0
	November	1.0
	December	1.0
	Current Year	January
February		2
March		2
April		2
May		2
June		2
Running Annual Average (RAA):		1.085
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/l as cl ₂)		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

3rd Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Previous Year	October	1.0
	November	1.0
	December	1.0
Current Year	January	1.2
	February	1.55
	March	0.86
	April	0.95
	May	0.92
	June	1.03
	July	2
	August	2
	September	2
Running Annual Average (RAA):		
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/l as cl ₂)		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

4th Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Current Year	January	1.2
	February	1.55
	March	0.86
	April	0.95
	May	0.92
	June	1.03
	July	1.12
	August	1.35
	September	1.29
	October	2
	November	2
	December	2
Running Annual Average (RAA):		
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/l as cl ₂)		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Comments:

Signature: 

Date: 1/7/18



CALIFORNIA LABORATORY SERVICES
Committed. Responsive. Flexible.

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 18L0262 COC #: 192086
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mandarin Sample Distribution (18L0262-01) Water Sampled: 12/05/18 07:58 Received: 12/05/18 12:00									
E. Coli	Absent	0.0	N/A	1	1810355	12/05/18	12/06/18	SM 9223	
Residual Chlorine	0.87	0.10	mg/L	"	"	12/05/18	12/05/18	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	12/05/18	12/06/18	SM 9223	



CALIFORNIA LABORATORY SERVICES
Committed. Responsive. Flexible.

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 18L0973 COC #: 194359
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mallard 'D' Site (18L0973-01) DW Sampled: 12/18/18 07:15 Received: 12/18/18 14:05									
E. Coli	Absent	0.0	N/A	1	1810720	12/18/18	12/19/18	SM 9223	
Residual Chlorine	1.28	0.10	mg/L	"	"	12/18/18	12/18/18	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	12/18/18	12/19/18	SM 9223	



CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.

MALLARD

Page 1 of 1

11/30/18 15:05

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 18K1248 COC #: 1931
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mallard 'D' Site (18K1248-01) DW Sampled: 11/21/18 08:00 Received: 11/21/18 12:00									
Residual Chlorine	0.75	0.10	mg/L	1	1809984	11/21/18 08:00	11/22/18	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	11/21/18 12:40	11/22/18	SM 9223	
E. Coli	Absent	0.0	"	"	"	"	"	"	



CALIFORNIA LABORATORY SERVICES
Committed. Responsive. Flexible.

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 18K0431 COC #: 192133
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mandarin P/A (18K0431-01) Water Sampled: 11/07/18 08:15 Received: 11/07/18 12:30									
E. Coli	Absent	0.0	N/A	1	1809538	11/07/18	11/08/18	SM 9223	
Residual Chlorine	1.33	0.10	mg/L	"	"	11/07/18	11/07/18	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	11/07/18	11/08/18	SM 9223	

WATER




CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 18J1141 COC #: 192040
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mallard P/A (18J1141-01) Water Sampled: 10/17/18 07:56 Received: 10/17/18 13:00									
E. Coli	Absent	0.0	N/A	1	1808858	10/17/18	10/18/18	SM 9223	
Residual Chlorine	1.41	0.10	mg/L	"	"	10/17/18	10/17/18	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	10/17/18	10/18/18	SM 9223	



CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.

WATER

California Rural Water Association
1234 N. Market Blvd.
Sacramento, CA 95834

Project: Wild Wings
Project Number: [none]
Project Manager: Dan Demoss

CLS Work Order #: 18J0284
COC #: 192028

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mandarin P/A (18J0284-01) Water Sampled: 10/03/18 08:00 Received: 10/03/18 12:30									
E. Coli	Absent	0.0	N/A	1	1808411	10/03/18	10/04/18	SM 9223	
Residual Chlorine	1.20	0.10	mg/L	"	"	10/03/18	10/03/18	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	10/03/18	10/04/18	SM 9223	