



April 30, 2019

State Water Resources Control Board
Division of Drinking Water
Salvador Turrubiartes, P.E., Associate Sanitary Engineer
1001 I St, 13th Floor
Sacramento, CA 95834

Regarding: CA57100011-Wild Wings-1Q-MRDL

Mr. Turrubiartes

Specialized Utilities Services Program, Inc., on behalf of the Wild Wings C.S.A. has prepared and is submitting to the Division of Drinking Water, the CA 57100011-Wild Wings-1Q-MRDL

Enclosed are the 1st Quarter Report for Disinfectant Residuals Compliance and analytical results.

Please note that no analytical results for February are included. Used February report for Chlorine residuals for that month.

Please contact me if you have any questions.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Dan DeMoss", is written over a light blue horizontal line.

Dan DeMoss.
Operator
Phone: (916) 616-7761
Email: ddemoss@calruralwater.org

Quarterly report for Disinfectant Residuals Compliance
For Systems Using Chlorine or Chloramines

System Name: Wild Wings
Calendar Year: 2018

System No : 5710011
Date: April 30, 2019

1st Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Previous Year	April	1.0
	May	1.1
	June	0.9
	July	1.0
	August	1.0
	September	1.1
	October	1.0
	November	1.0
	December	1.0
	Current Year	January
February		2
March		2
Running Annual Average (RAA):		1.0
Meets standard? (i.e. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No)		RAA ≤ MRDL of 4.0 mg/l as cl ₂

2nd Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Previous Year	July	
	August	
	September	
	October	
	November	
	December	
Current Year	January	
	February	
	March	
	April	
	May	
	June	
Running Annual Average (RAA):		
Meets standard? (i.e. <input type="checkbox"/> Yes <input type="checkbox"/> No)		RAA ≤ MRDL of 4.0 mg/l as cl ₂

3rd Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Current Year	October	
	November	
	December	
Previous Year	January	
	February	
	March	
	April	
	May	
	June	
	July	
	August	
	September	
Running Annual Average (RAA):		
Meets standard? (i.e. <input type="checkbox"/> Yes <input type="checkbox"/> No)		RAA ≤ MRDL of 4.0 mg/l as cl ₂

4th Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Current Year	January	
	February	
	March	
	April	
	May	
	June	
	July	
	August	
	September	
	October	
	November	
	December	
Running Annual Average (RAA):		
Meets standard? (i.e. <input type="checkbox"/> Yes <input type="checkbox"/> No)		RAA ≤ MRDL of 4.0 mg/l as cl ₂

Comments:

Signature: 

Date: 04/30/2019



CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.

01/16/19 13:13

Page 1 of 2

California Rural Water Association
1234 N. Market Blvd.
Sacramento, CA 95834

Project: Wild Wings
Project Number: [none]
Project Manager: Dan Demoss

CLS Work Order #: 19A0421
COC #: 194714

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mallard 'D' Sample (19A0421-01) DW Sampled: 01/09/19 07:30 Received: 01/09/19 12:15									
Residual Chlorine	1.14	0.10	mg/L	1	1900219	01/09/19 07:30	01/09/19	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	01/09/19 12:30	01/10/19	SM 9223	
E. Coli	Absent	0.0	"	"	"	"	"	"	



California Rural Water Association
1234 N. Market Blvd.
Sacramento, CA 95834

Project: Wild Wings
Project Number: [none]
Project Manager: Dan Demoss

CLS Work Order #: 19A0421
COC #: 194714

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mallard 'D' Sample (19A0421-01) DW Sampled: 01/09/19 07:30 Received: 01/09/19 12:15									
Residual Chlorine	1.14	0.10	mg/L	1	1900219	01/09/19 07:30	01/09/19	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	01/09/19 12:30	01/10/19	SM 9223	
E. Coli	Absent	0.0	"	"	"	"	"	"	



CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 19C0855 COC #: 195528
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mandarin 'D' Sample Site (19C0855-01) Water Sampled: 03/15/19 07:45 Received: 03/15/19 11:50									
E. Coli	Absent	0.0	N/A	1	1902138	03/15/19	03/16/19	SM 9223	
Residual Chlorine	0.56	0.10	mg/l.	"	"	03/15/19	03/15/19	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	03/15/19	03/16/19	SM 9223	



CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 19B1242 COC #: 195509
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								
Mallard 'D' Sample Site (19B1242-01) Water Sampled: 02/23/19 08:01 Received: 02/23/19 11:35										
E. Coli	Absent	0.0		N/A	1	1901563	02/23/19	02/24/19	SM 9223	
Residual Chlorine	1.17	0.10		mg/l	"	"	02/23/19	02/23/19	SM 4500-CL-G	
Total Coliforms	Absent	0.0		N/A	"	"	02/23/19	02/24/19	SM 9223	



CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 19C1082 COC #: 196410
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mallard 'D' Sample Site (19C1082-01) Water Sampled: 03/20/19 07:45 Received: 03/20/19 11:45									
Residual Chlorine	1.00	0.10	mg/L	1	1902275	03/20/19 07:45	03/20/19	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	03/20/19 12:15	03/21/19	SM 9223	
E. Coli	Absent	0.0	"	"	"	"	"	"	