



July 5, 2019

State Water Resources Control Board
Division of Drinking Water
Salvador Turrubiartes, P.E., Associate Sanitary Engineer
1001 I St, 13th Floor
Sacramento, CA 95834

Regarding: Wild Wings C.S.A. June 2019 Monthly Water System Report

Mr. Turrubiartes,

Specialized Utilities Services Program, Inc., on behalf of the Wild Wings C.S.A. has prepared and is submitting to the Division of Drinking Water, the June 2019 Monthly Water Monitoring Report.

Enclosed are the June Monthly Water System Flow Report, Summary of Distribution System Coliform Monitoring Report, the laboratory analytical results for bacteriological testing,

Please contact me if you have any questions.

Sincerely yours,

A handwritten signature in black ink that reads "Dan DeMoss". The signature is written in a cursive style with a large initial "D".

Dan DeMoss.
Operator
Phone: (916) 616-7761
Email: ddemoss@calruralwater.org

MONTHLY SUMMARY OF DISTRIBUTION SYSTEM COLIFORM MONITORING

System Name <p style="text-align: center; font-size: 1.2em;">Wild Wings</p>	System Number <p style="text-align: center; font-size: 1.2em;">5710011</p>
Sampling Period <p style="text-align: center; font-size: 1.2em; color: blue;">June</p>	Year <p style="text-align: center; font-size: 1.2em;">2019</p>

	Number Required	Number Collected	Number Total Coliform Positives	Number Fecal/ E.coli Positives
1. Routine Samples (see note 1)	2	2	0	0
2. Repeat Samples Following Samples Which are Total Coliform Positive and Fecal/E.coli <i>Negative</i> (see notes 5 and 6)		0	0	0
3. Repeat Samples Following Routine Samples Which are Total Coliform <i>Positive</i> and Fecal/E.coli Positive (see notes 5 and 6)		0	0	0
4. MCL Computation For Total Coliform Positive Samples				
a. Totals (sum of columns)	0	0	0	
b. If 40 or more samples collected in month, determine percent of samples that are total coliform positive [(total number positive/total number collected) x 100]		0		
c. Is system in compliance. ...with fecal/E. coli MCL? (see notes 2 and 3)		<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
...with monthly MCL? (see note 4)		<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	

5. Invalidated Samples

(Note what samples, if any, were invalidated; who authorized the invalidation; and when replacement samples were collected. Attach additional sheets, if necessary.)

6. Summary Completed By:

Signature 	Title <p style="text-align: center; font-size: 1.2em;">Water Operator</p>	Date <p style="text-align: center; font-size: 1.2em; color: blue;">7/5/2019</p>
---------------	--	--

NOTES AND INSTRUCTIONS:

1. Routine samples include:

- a. Samples required pursuant to 22 CCR Section 64423, and any additional samples required by an approved routine sample siting plan established pursuant to 22 CCR Section 64422.
- b. Extra samples required for systems collecting less than five routine samples per month that had one or more total coliform positives in previous month;
- c. Extra samples for systems with high source water turbidities that are using surface water or groundwater under direct influence of surface water and do not practice filtration in compliance with regulations;

2. Note: For a repeat sample following a total coliform positive sample, any fecal/E.coli positive repeat (boxed entry) **constitutes an MCL violation and requires immediate notification to the department** (22, CCR, Section 64426.1).

3. Note: For repeat sample following a fecal/E.coli positive sample, any total coliform positive repeat (boxed entry) **constitutes an MCL violation and requires immediate notification to the department** (22, CCR, Section 64426.1).

4. Total coliform MCL (Notify Department within 24 hours of MCL violation):

- a. For systems collecting less than 40 samples, if two or more samples are total coliform positive, then the MCL is violated.
- b. For systems collecting 40 or more samples, if more than 5.0 percent of samples collected are total coliform positive, then the MCL is violated.

5. Positive results and their associated repeat samples must be tracked on the worksheet on the other side.

6. For systems collecting more than one routine sample per month, three repeat samples must be collected for each total coliform positive sample. Repeat samples must be collected within 24 hours of being notified of the positive results.

7. For systems collecting one or less routine samples per month, four repeat samples must be collected for each total coliform positive sample.

Date	PINTAIL WELL SITE			CANVAS WELL SITE			MONTH: Jun-19		
	Meter Read	Flow MGD	Reservoir CL ₂ Residual	Meter Read	Flow MGD	Reservoir CL ₂ Residual	Mallard CL ₂ Residual	Mandarian CL ₂ Residual	Total Volume MGD
1	1408.4866	0.3517	1.43	1176.0434	0.2313	0.82	*	*	0.5830
2	1408.8383	0.3452	1.41	1176.2747	0.2918	0.77	1.3	1.32	0.6370
3	1409.1835	0.2681	1.13	1176.5665	0.4227	0.5	1.08	1.19	0.6908
4	1409.4516	0.3792	1.09	1176.9892	0.4180	0.49	1.07	1.17	0.7972
5	1409.8308	0.346	0.87	1177.4072	0.2246	0.49	0.81	0.81	0.5706
6	1410.1768	0.2905	0.55	1177.6318	0.2436	0.5	0.69	0.55	0.5341
7	1410.4673	0.3222	0.89	1177.8754	0.4922	0.5	0.9	0.89	0.8144
8	1410.7895	0.3656	1.01	1178.3676	0.4220	0.47	0.99	0.94	0.7876
9	1411.1551	0.3708	1.51	1178.7896	0.4436	0.72	*	1.5	0.8144
10	1411.5259	0.3401	1.16	1179.2332	0.4293	0.45	0.73	1.2	0.7694
11	1411.866	0.2993	1.17	1179.6625	0.5011	0.36	1.08	1.22	0.8004
12	1412.1653	0.4457	1.27	1180.1636	0.4587	0.47	1.11	1.18	0.9044
13	1412.611	0.4174	1.07	1180.6223	0.4377	0.85	1.15	1.44	0.8551
14	1413.0284	0.3521	0.77	1181.06	0.3778	0.84	1.38	1.12	0.7299
15	1413.3805	0.3812	0.69	1181.4378	0.4823	0.73	0.93	0.80	0.8635
16	1413.7617	0.3912	0.68	1181.9201	0.2255	0.7	0.71	0.63	0.6167
17	1414.1529	0.4082	0.77	1182.1456	0.3573	0.8	0.49	0.99	0.7655
18	1414.5611	0.3111	0.77	1182.5029	0.3574	0.89	0.57	0.66	0.6685
19	1414.8722	0.7912	1.44	1182.8603	0.6670	0.92	0.84	0.79	1.4582
20	1415.6634	0.2238	*	1183.5273	0.6706	*	*	*	0.8944
21	1415.8872	0.2238	1.37	1184.1979	0.8677	0.57	1.34	1.46	1.0915
22	1416.111	0.4122	1.51	1185.0656	0.4761	0.85	1.30	1.17	0.8883
23	1416.5232	0.416	1.36	1185.5417	0.1819	0.84	1.27	1.34	0.5979
24	1416.9392	0.3498	1.35	1185.7236	0.7548	0.54	1.21	1.64	1.1046
25	1417.289	0.394	1.08	1186.4784	0.4903	0.55	1.19	1.39	0.8843
26	1417.683	0.3364	0.68	1186.9687	0.6797	0.54	1.27	1.29	1.0161
27	1418.0194	0.4382	0.66	1187.6484	0.2890	0.53	0.77	0.67	0.7272
28	1418.4576	0.3593	1.02	1187.9374	0.4183	0.53	0.29	0.30	0.7776
29	1418.8169	0.4238	1.56	1188.3557	0.5421	0.52	0.93	1.02	0.9659
30	1419.2407	0.4217	1.26	1188.8978	0.4742	0.5	1.18	1.26	0.8959
1	1419.6624			1189.372					

Max	0.7912
Min	0.2238
Avg	0.3725
Total	11.1758

Max	0.8677
Min	0.1819
Avg	0.4443
Total	13.3286

Max	1.4582
Min	0.5341
Avg	0.8168
Total	24.5044

* No chlorine residuals taken.



CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.


California Rural Water Association
1234 N. Market Blvd.
Sacramento, CA 95834

Project: Wild Wings
Project Number: [none]
Project Manager: Dan Demoss

CLS Work Order #: 19F0666
COC #: 194378

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mandarin #1 (19F0666-01) Water Sampled: 06/12/19 07:55 Received: 06/12/19 11:45									
Residual Chlorine	1.18	0.10	mg/L	1	1904849	06/12/19 07:55	06/12/19	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	06/12/19 12:30	06/13/19	SM 9223	
E. Coli	Absent	0.0	"	"	"	"	"	"	



CALIFORNIA LABORATORY SERVICES
Committed. Responsive. Flexible.

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 19F1468 COC #: 201722
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mallard "D" Sample Site (19F1468-01) Water Sampled: 06/26/19 07:55 Received: 06/26/19 12:30									
E. Coli	Absent	0.0	N/A	1	1905298	06/26/19	06/27/19	SM 9223	
Residual Chlorine	1.39	0.10	mg/L	"	"	"	06/26/19	SM 4500-CL-G	FT-C
Total Coliforms	Absent	0.0	N/A	"	"	"	06/27/19	SM 9223	