

West Plainfield Fire Department
24901 County Road 95 Davis, CA 95616
530-756-0212



YOLO COUNTY AIRPORT HANGAR INSPECTION NOTICE

Address/Hangar #: _____ Aviation Ave. Davis, CA 95616

Occupant: _____ Phone #: _____ Date of Inspection: _____

1 Building		<u>Cleared Date</u>
a	Address/Hangar # must be posted (Shall be posted to be plainly legible from road fronting the property with minimum height of 4" with contrasting color of structure) CFC 505.1	
b	Provide and prominently display NFPA 704 placards, when required by permit, plainly legible from the road fronting the property. CFC 5003.5 – 5003.6	
2 Electrical		<u>Cleared Date</u>
a	Discontinue use of extension cords in lieu of permanent wiring CFC 605.5	
b	Discontinue use of non-approved multi plug adapters (must be UL listed) CFC 605.4	
c	Replace/repair covers on electrical service panel or outlet boxes CFC 605.6	
d	Maintain wiring in good condition and protect from damage CFC 605.1	
e	Electrical panel and equipment shall have a minimum of 36" clearance front, 30" sides and 76" high. CFC 605.	
3 Aviation		<u>Cleared Date</u>
a	Open flames, flame producing-producing devices and other sources of ignition Shall not be permitted in a Hangar, except in approved locations. CFC 2003.1	
b	Aircraft operation area (AOA) shall be kept free from combustible debris at all times. CFC 2003.3	
c	Provide metal drip pans located under the engines of all aircraft. CFC 1103.3	
d	Flammable liquids must be stored in original containers or closed metal cans. CFC 5704.3	
4 Fire Protection		<u>Cleared Date</u>
a	Provide fire extinguisher(s) (3A 40 BC min) spaced no further than 50' of travel. CCR T-19	
b	Extinguishers must be serviced every 6 years, inspected annually and visually inspected monthly. Initial and annual training will be provided for all users. CFC 5704 CCR T-19 CFC 906	
c	Extinguishers must be accessible and located appropriately CFC 2005.7	
d	Maintain integrity of fire doors, occupancy and area separation walls. CFC 703.1	
5 Storage		<u>Cleared Date</u>
a	Remove storage from exits, aisles, corridors and under stairs. CFC 1028	
b	Reduce storage height to at least 2 feet below ceiling in buildings not protected by sprinklers. CFC 315.3.1 CFC 5303.5.3 CFC 5303.4.2	
c	Secure and identify compressed gas cylinders. CFC 3003.5.2	
6 Exiting and Housekeeping		<u>Cleared Date</u>
a	Remove combustible storage, waste, trash or weeds. CFC 304	
b	Remove or store waste material and oily rags in approved/listed closed metal container. CFC 301	
c	Follow approved safety precautions for handling and storage of hazardous materials CFC 5003.9 – 5003.9.10	

Comments/Additional Items:

_____ A reasonable degree of fire safety exists at this time. Thank you.
 _____ You are hereby notified to correct the above noted conditions immediately upon receipt of this notice. A re-inspection to determine if you have complied will be conducted on or about _____. Please call prior to this date to schedule a re-inspection. (530) 756-0212

Inspection conducted by: _____ Phone: _____

Received by (print and sign): _____