



April 6, 2020

State Water Resources Control Board  
Division of Drinking Water  
Austin Peterson, P.E., Associate Sanitary Engineer  
1001 I St, 13<sup>th</sup> Floor  
Sacramento, CA 95834

**Regarding: Wild Wings C.S.A. March 2020 Monthly Water System Report**

Mr. Peterson,

Specialized Utilities Services Program, Inc., on behalf of the Wild Wings C.S.A. has prepared and is submitting to the Division of Drinking Water, the March 2020 Monthly Water Monitoring Report.

Enclosed are the March Monthly Water System Flow Report, Summary of Distribution System Coliform Monitoring Report, the laboratory analytical results for bacteriological testing,

Please contact me if you have any questions.

Sincerely yours,

A handwritten signature in black ink that reads "Dan DeMoss". The signature is written in a cursive style with a large initial "D".

Dan DeMoss.  
Operator  
Phone: (916) 616-7761  
Email: [ddemoss@calruralwater.org](mailto:ddemoss@calruralwater.org)

## MONTHLY SUMMARY OF DISTRIBUTION SYSTEM COLIFORM MONITORING

System Name <p style="text-align: center; font-size: 1.2em;">Wild Wings</p>	System Number <p style="text-align: center; font-size: 1.2em;">571011</p>
Sampling Period <p style="text-align: center; font-size: 1.2em; color: blue;">March</p>	Year <p style="text-align: center; font-size: 1.2em;">2020</p>

	Number Required	Number Collected	Number Total Coliform Positives	Number Fecal/ E.coli Positives
1. Routine Samples (see note 1)	<u>2</u>	<u>2</u>	<u>0</u>	<u>0</u>
2. Repeat Samples Following Samples Which are Total Coliform Positive and Fecal/E.coli <i>Negative</i> (see notes 5 and 6)		<u>0</u>	<u>0</u>	<u>0</u>
3. Repeat Samples Following Routine Samples Which are Total Coliform <i>Positive</i> and Fecal/E.coli Positive (see notes 5 and 6)		<u>0</u>	<u>0</u>	<u>0</u>
4. MCL Computation For Total Coliform Positive Samples				
a. Totals (sum of columns)	<u>0</u>	<u>0</u>	<u>0</u>	
b. If 40 or more samples collected in month, determine percent of samples that are total coliform positive [(total number positive/total number collected) x 100]	<u>0</u>			
c. Is system in compliance. . . with fecal/E. coli MCL? (see notes 2 and 3)		<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
. . . with monthly MCL? (see note 4)		<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	

5. Invalidated Samples  
(Note what samples, if any, were invalidated; who authorized the invalidation; and when replacement samples were collected. Attach additional sheets, if necessary.)

6. Summary Completed By:

Signature 	Title <p style="text-align: center; font-size: 1.2em;">Water Operator</p>	Date <p style="text-align: center; font-size: 1.2em;">04/06/2020</p>
---------------	--	---

**NOTES AND INSTRUCTIONS:**

1. Routine samples include:
    - a. Samples required pursuant to 22 CCR Section 64423, and any additional samples required by an approved routine sample siting plan established pursuant to 22 CCR Section 64422.
    - b. Extra samples required for systems collecting less than five routine samples per month that had one or more total coliform positives in previous month;
    - c. Extra samples for systems with high source water turbidities that are using surface water or groundwater under direct influence of surface water and do not practice filtration in compliance with regulations;
  2. Note: For a repeat sample following a total coliform positive sample, any fecal/E.coli positive repeat (boxed entry) **constitutes an MCL violation and requires immediate notification to the department** (22, CCR, Section 64426.1).
  3. Note: For repeat sample following a fecal/E.coli positive sample, any total coliform positive repeat (boxed entry) **constitutes an MCL violation and requires immediate notification to the department** (22, CCR, Section 64426.1).
  4. Total coliform MCL (**Notify Department within 24 hours of MCL violation**):
    - a. For systems collecting less than 40 samples, if two or more samples are total coliform positive, then the MCL is violated.
    - b. For systems collecting 40 or more samples, if more than 5.0 percent of samples collected are total coliform positive, then the MCL is violated.
  5. Positive results and their associated repeat samples must be tracked on the worksheet on the other side.
  6. For systems collecting more than one routine sample per month, three repeat samples must be collected for each total coliform positive sample. Repeat samples must be collected within 24 hours of being notified of the positive results.
  7. For systems collecting one or less routine samples per month, four repeat samples must be collected for each total coliform positive sample.
- CDPH 8477 (10/2007)


Date	PINTAIL WELL SITE			CANVAS WELL SITE			MONTH: Mar-20		
	Meter Read	Flow MGD	Reservoir CL <sub>2</sub> Residual	Meter Read	Flow MGD	Reservoir CL <sub>2</sub> Residual	Mallard CL <sub>2</sub> Residual	Mandarian CL <sub>2</sub> Residual	Total Volume MGD
1	1479.3978	0.2161	1.29	1223.3601	0.0000	0.58	1.34	1.36	0.2161
2	1479.6139	0.1487	1.31	1223.3601	0.4749	0.59	1.32	1.34	0.6236
3	1479.7626	0.2319	1.28	1223.835	0.1945	*	1.27	1.27	0.4264
4	1479.9945	0.2106	1.31	1224.0295	0.1851	*	1.2	1.41	0.3957
5	1480.2051	0.1474	1.32	1224.2146	0.5453	0.57	1.33	1.37	0.6927
6	1480.3525	0.1061	1.28	1224.7599	0.4061	0.51	1.28	1.38	0.5122
7	1480.4586	0.249	1.2	1225.166	0.0000	0.53	1.13	1.19	0.2490
8	1480.7076	0.2047	1.32	1225.166	0.1997	0.5	1.17	1.22	0.4044
9	1480.9123	0.1519	1.16	1225.3657	0.3916	0.46	1.05	1.01	0.5435
10	1481.0642	0.154	1.29	1225.7573	0.3584	0.75	1.68	1.56	0.5124
11	1481.2182	0.2249	1.35	1226.1157	0.0000	0.8	1.18	1.47	0.2249
12	1481.4431	0.2234	1.33	1226.1157	0.3693	0.81	1.42	1.52	0.5927
13	1481.6665	0.2091	1.2	1226.485	0.4148	0.87	1.47	1.31	0.6239
14	1481.8756	0.1508	1.39	1226.8998	0.2903	0.73	1.47	1.39	0.4411
15	1482.0264	0.2084	1.39	1227.1901	0.2693	0.73	1.4	1.52	0.4777
16	1482.2348	0.1412	1.41	1227.4594	0.1717	0.66	1.42	1.48	0.3129
17	1482.376	0.1434	1.35	1227.6311	0.0000	0.81	1.49	1.4	0.1434
18	1482.5194	0.1412	1.39	1227.6311	0.0000	0.93	1.35	1.39	0.1412
19	1482.6606	0.1384	1.31	1227.6311	0.0000	0.98	1.39	1.35	0.1384
20	1482.799	0.1363	1.21	1227.6311	0.0000	0.93	1.33	1.33	0.1363
21	1482.9353	0.2104	1.04	1227.6311	0.0000	0.93	1.09	1.11	0.2104
22	1483.1457	0.1345	1.15	1227.6311	0.0000	0.81	1.78	1.26	0.1345
23	1483.2802	0.1728	1.21	1227.6311	0.0000	0.83	1.22	1.32	0.1728
24	1483.453	0.1743	0.91	1227.6311	0.0000	0.85	1.13	1.19	0.1743
25	1483.6273	0.1415	1.08	1227.6311	0.0000	0.99	1.19	1.22	0.1415
26	1483.7688	0.1333	1.04	1227.6311	0.0000	0.98	1.63	1.28	0.1333
27	1483.9021	0.2139	1.42	1227.6311	0.0000	0.99	1.41	1.33	0.2139
28	1484.116	0.1426	1.38	1227.6311	0.0000	0.94	1.44	1.91	0.1426
29	1484.2586	0.1335	1.32	1227.6311	0.0000	0.94	1.46	1.50	0.1335
30	1484.3921	0.2074	1.22	1227.6311	0.0000	0.94	1.42	1.50	0.2074
31	1484.5995	0.36	1.28	1227.6311	0.0000	0.94	1.48	1.45	0.3600
1	1484.9595			1227.6311					

Max	0.3600
Min	0.1061
Avg	0.1794
Total	5.5617

Max	0.5453
Min	0.0000
Avg	0.1378
Total	4.2710

Max	0.6927
Min	0.1333
Avg	0.3172
Total	9.8327

\* No chlorine residuals taken.




**CALIFORNIA LABORATORY SERVICES**  
*Committed. Responsive. Flexible.*

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 20C0859 COC #: 203287
--	--	--

**Microbiological Parameters by APHA Standard Methods**

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Mallard # 2 (20C0859-01) Water</b> <b>Sampled: 03/17/20 08:30</b> <b>Received: 03/17/20 13:30</b>									
Residual Chlorine	1.49	0.10	mg/L	1	2002197	03/17/20 08:30	03/17/20	SM 4500-CL-G	FT-C
Total Coliforms	Absent	0.0	N/A	"	"	03/17/20 14:00	03/18/20	SM 9223	
E. Coli	Absent	0.0	"	"	"	"	"	"	



**CALIFORNIA LABORATORY SERVICES**  
*Committed. Responsive. Flexible.*

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 20C0211 COC #: 203261
--	--	--

**Microbiological Parameters by APHA Standard Methods**

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Mandarin # 1 (20C0211-01) Water</b> Sampled: 03/04/20 08:15    Received: 03/04/20 12:40									
Residual Chlorine	1.41	0.10	mg/L	1	2001811	03/04/20 08:15	03/04/20	SM 4500-CL-G	FT-C
Total Coliforms	Absent	0.0	N/A	"	"	03/04/20 13:15	03/05/20	SM 9223	
E. Coli	Absent	0.0	"	"	"	"	"	"	