



July 8, 2020

State Water Resources Control Board
Division of Drinking Water
Austin Peterson, P.E., Associate Sanitary Engineer
1001 I St, 13th Floor
Sacramento, CA 95834

Regarding: Wild Wings C.S.A. June 2020 Monthly Water System Report

Mr. Peterson,

Specialized Utilities Services Program, Inc., on behalf of the Wild Wings C.S.A. has prepared and is submitting to the Division of Drinking Water, the June 2020 Monthly Water Monitoring Report.

Enclosed are the June Monthly Water System Flow Report, Summary of Distribution System Coliform Monitoring Report, the laboratory analytical results for bacteriological testing,

Please contact me if you have any questions.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Dan DeMoss". The signature is fluid and cursive, written over a white background.

Dan DeMoss.
Operator
Phone: (916) 616-7761
Email: ddemoss@calruralwater.org

MONTHLY SUMMARY OF DISTRIBUTION SYSTEM COLIFORM MONITORING

System Name <p style="text-align: center; font-size: 1.2em;">Wild Wings</p>	System Number <p style="text-align: center; font-size: 1.2em;">571011</p>
Sampling Period <p style="text-align: center; font-size: 1.2em;">June</p>	Year <p style="text-align: center; font-size: 1.2em;">2020</p>

	Number Required	Number Collected	Number Total Coliform Positives	Number Fecal/ E.coli Positives
1. Routine Samples (see note 1)	<u>2</u>	<u>2</u>	<u>0</u>	<u>0</u>
2. Repeat Samples Following Samples Which are Total Coliform Positive and Fecal/E.coli <i>Negative</i> (see notes 5 and 6)		<u>0</u>	<u>0</u>	<u>0</u>
3. Repeat Samples Following Routine Samples Which are Total Coliform <i>Positive</i> and Fecal/E.coli Positive (see notes 5 and 6)		<u>0</u>	<u>0</u>	<u>0</u>
4. MCL Computation For Total Coliform Positive Samples				
a. Totals (sum of columns)	<u>0</u>	<u>0</u>	<u>0</u>	
b. If 40 or more samples collected in month, determine percent of samples that are total coliform positive [(total number positive/total number collected) x 100]		<u>0</u>		
c. Is system in compliance. ...with fecal/E. coli MCL? (see notes 2 and 3)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		
...with monthly MCL? (see note 4)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		

5. Invalidated Samples

(Note what samples, if any, were invalidated; who authorized the invalidation; and when replacement samples were collected. Attach additional sheets, if necessary.)

6. Summary Completed By:

Signature 	Title <p style="text-align: center; font-size: 1.2em;">Water Operator</p>	Date <p style="text-align: center; font-size: 1.2em;">7/8/2020</p>
---------------	--	---

NOTES AND INSTRUCTIONS:


1. Routine samples include:
 - a. Samples required pursuant to 22 CCR Section 64423, and any additional samples required by an approved routine sample siting plan established pursuant to 22 CCR Section 64422.
 - b. Extra samples required for systems collecting less than five routine samples per month that had one or more total coliform positives in previous month;
 - c. Extra samples for systems with high source water turbidities that are using surface water or groundwater under direct influence of surface water and do not practice filtration in compliance with regulations;
2. Note: For a repeat sample following a total coliform positive sample, any fecal/E.coli positive repeat (boxed entry) **constitutes an MCL violation and requires immediate notification to the department** (22, CCR, Section 64426.1).
3. Note: For repeat sample following a fecal/E.coli positive sample, any total coliform positive repeat (boxed entry) **constitutes an MCL violation and requires immediate notification to the department** (22, CCR, Section 64426.1).
4. Total coliform MCL (**Notify Department within 24 hours of MCL violation**):
 - a. For systems collecting less than 40 samples, if two or more samples are total coliform positive, then the MCL is violated.
 - b. For systems collecting 40 or more samples, if more than 5.0 percent of samples collected are total coliform positive, then the MCL is violated.
5. Positive results and their associated repeat samples must be tracked on the worksheet on the other side.
6. For systems collecting more than one routine sample per month, three repeat samples must be collected for each total coliform positive sample. Repeat samples must be collected within 24 hours of being notified of the positive results.
7. For systems collecting one or less routine samples per month, four repeat samples must be collected for each total coliform positive sample.

Date	PINTAIL WELL SITE			CANVAS WELL SITE			MONTH: Jun-20		
	Meter Read	Flow MGD	Reservoir CL ₂ Residual	Meter Read	Flow MGD	Reservoir CL ₂ Residual	Mallard CL ₂ Residual	Mandarian CL ₂ Residual	Total Volume MGD
1	1502.4699	0.3358	0.88	1239.9091	0.3995	0.8	1.1	1.77	0.7353
2	1502.8057	0.3833	1.19	1240.3086	0.4572	0.78	1.37	1.22	0.8405
3	1503.189	0.3866	1.2	1240.7658	0.9179	0.7	1.1	1.30	1.3045
4	1503.5756	0.4589	1.18	1241.6837	0.9180	0.95	1.11	0.99	1.3769
5	1504.0345	0.3569	0.95	1242.6017	0.4699	1.16	0.91	0.72	0.8268
6	1504.3914	0.3718	1.21	1243.0716	0.0000	1.17	1.31	1.32	0.3718
7	1504.7632	0.4355	1.1	1243.0716	0.3672	1.09	1.26	1.35	0.8027
8	1505.1987	0.3639	1.13	1243.4388	0.1047	1.22	0.93	1.10	0.4686
9	1505.5626	0.4452	1.29	1243.5435	0.3359	0.77	1.3	1.11	0.7811
10	1506.0078	0.4695	0.94	1243.8794	0.5636	1	1.1	0.88	1.0331
11	1506.4773	0.4292	1.27	1244.443	0.0000	0.96	0.85	1.04	0.4292
12	1506.9065	0.5164	0.9	1244.443	0.0000	1.23	0.87	1.02	0.5164
13	1507.4229	0.4368	1.2	1244.443	0.0000	1.07	0.86	0.99	0.4368
14	1507.8597	0.4296	0.95	1244.443	1.1604	1.02	0.88	0.92	1.5900
15	1508.2893	0.4063	1.08	1245.6034	0.0252	1	0.92	0.99	0.4315
16	1508.6956	0.3782	1.08	1245.6286	0.3382	1.01	1.07	1.18	0.7164
17	1509.0738	0.3822	1.24	1245.9668	0.2727	0.99	1.12	1.14	0.6549
18	1509.456	0.4193	1.27	1246.2395	1.5099	0.96	1.68	1.23	1.9292
19	1509.8753	0.4339	1.26	1247.7494	0.0000	0.93	1.33	1.21	0.4339
20	1510.3092	0.4229	1.26	1247.7494	0.0000	0.92	1.19	1.17	0.4229
21	1510.7321	0.536	1.21	1247.7494	0.0000	1.09	1.38	1.3	0.5360
22	1511.2681	0.3823	1.02	1247.7494	0.4019	1.01	0.90	0.82	0.7842
23	1511.6504	0.4789	0.96	1248.1513	1.3598	0.99	0.93	1.01	1.8387
24	1512.1293	0.4244	1.03	1249.5111	0.1674	0.89	1.17	1.21	0.5918
25	1512.5537	0.4154	1.01	1249.6785	0.0025	0.9	0.97	0.71	0.4179
26	1512.9691	0.4661	1.09	1249.681	0.3683	0.97	0.89	1.01	0.8344
27	1513.4352	0.4543	1.09	1250.0493	0.0000	1.06	0.99	0.92	0.4543
28	1513.8895	0.4143	1.18	1250.0493	0.0000	1.02	0.74	0.99	0.4143
29	1514.3038	0.3804	0.98	1250.0493	0.4686	0.93	1.48	0.79	0.8490
30	1514.6842	0.4045	1.04	1250.5179	0.4104	0.92	1.01	0.94	0.8149
1	1515.0887			1250.9283					

Max	0.5360
Min	0.3358
Avg	0.4206
Total	12.6188

Max	1.5099
Min	0.0000
Avg	0.3673
Total	11.0192

Max	1.9292
Min	0.3718
Avg	0.7879
Total	23.6380




CALIFORNIA LABORATORY SERVICES
Committed. Responsive. Flexible.

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 20F0420 COC #: 206590
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mandarin #1 (20F0420-01) Water Sampled: 06/08/20 07:40 Received: 06/08/20 12:15									
E. Coli	Absent	0.0	N/A	1	2004498	06/08/20	06/09/20	SM 9223	
Residual Chlorine	1.06	0.10	mg/L	"	"	06/08/20	06/08/20	SM 4500-CL-G	FT-C
Total Coliforms	Absent	0.0	N/A	"	"	06/08/20	06/09/20	SM 9223	



CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 20F1015 COC #: 207166
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								
Mallard # 2 (20F1015-01) Water Sampled: 06/18/20 07:50 Received: 06/18/20 12:30										
Residual Chlorine	1.68	0.10	mg/L	1	2004810	06/18/20 07:50	06/18/20	SM 4500-CL-G		FT-C
Total Coliforms	Absent	0.0	N/A	"	"	06/18/20 14:30	06/19/20	SM 9223		
E. Coli	Absent	0.0	"	"	"	"	"	"		