



November 9, 2020

State Water Resources Control Board  
Division of Drinking Water  
Austin Peterson, P.E., Associate Sanitary Engineer  
1001 I St, 13<sup>th</sup> Floor  
Sacramento, CA 95834

**Regarding: Wild Wings C.S.A. October 2020 Monthly Water System Report**

Mr. Peterson,

Specialized Utilities Services Program, Inc., on behalf of the Wild Wings C.S.A. has prepared and is submitting to the Division of Drinking Water, the October 2020 Monthly Water Monitoring Report.

Enclosed are the September Monthly Water System Flow Report, Summary of Distribution System Coliform Monitoring Report, the laboratory analytical results for bacteriological testing,

Please contact me if you have any questions.

Sincerely yours,

A handwritten signature in black ink that reads "Dan DeMoss". The signature is written in a cursive, flowing style.

Dan DeMoss.  
Operator  
Phone: (916) 616-7761  
Email: [ddemoss@calruralwater.org](mailto:ddemoss@calruralwater.org)

## MONTHLY SUMMARY OF DISTRIBUTION SYSTEM COLIFORM MONITORING

System Name <p style="text-align: center; font-size: 1.2em;">Wild Wings</p>	System Number <p style="text-align: center; font-size: 1.2em;">571011</p>
Sampling Period <p style="text-align: center; font-size: 1.2em; color: blue;">October</p>	Year <p style="text-align: center; font-size: 1.2em;">2020</p>
Month	

	Number Required	Number Collected	Number Total Coliform Positives	Number Fecal/ E.coli Positives
1. Routine Samples (see note 1)	<u>2</u>	<u>2</u>	<u>0</u>	<u>0</u>
2. Repeat Samples Following Samples Which are Total Coliform Positive and Fecal/E.coli <i>Negative</i> (see notes 5 and 6)		<u>0</u>	<u>0</u>	<u>0</u>
3. Repeat Samples Following Routine Samples Which are Total Coliform <i>Positive</i> and Fecal/E.coli Positive (see notes 5 and 6)		<u>0</u>	<u>0</u>	<u>0</u>
4. MCL Computation For Total Coliform Positive Samples				
a. Totals (sum of columns)	<u>0</u>	<u>0</u>	<u>0</u>	
b. If 40 or more samples collected in month, determine percent of samples that are total coliform positive [(total number positive/total number collected) x 100]	<u>0</u>			
c. Is system in compliance. . . with fecal/E. coli MCL? (see notes 2 and 3)		<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
. . . with monthly MCL? (see note 4)		<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	

5. Invalidated Samples  
(Note what samples, if any, were invalidated; who authorized the invalidation; and when replacement samples were collected. Attach additional sheets, if necessary.)

6. Summary Completed By:

Signature 	Title <p style="text-align: center; font-size: 1.2em;">Water Operator</p>	Date <p style="text-align: center; font-size: 1.2em;">11/9/2020</p>
---------------	--	--

**NOTES AND INSTRUCTIONS:**

1. Routine samples include:
    - a. Samples required pursuant to 22 CCR Section 64423, and any additional samples required by an approved routine sample siting plan established pursuant to 22 CCR Section 64422.
    - b. Extra samples required for systems collecting less than five routine samples per month that had one or more total coliform positives in previous month;
    - c. Extra samples for systems with high source water turbidities that are using surface water or groundwater under direct influence of surface water and do not practice filtration in compliance with regulations;
  2. Note: For a repeat sample following a total coliform positive sample, any fecal/E.coli positive repeat (boxed entry) **constitutes an MCL violation and requires immediate notification to the department** (22, CCR, Section 64426.1).
  3. Note: For repeat sample following a fecal/E.coli positive sample, any total coliform positive repeat (boxed entry) **constitutes an MCL violation and requires immediate notification to the department** (22, CCR, Section 64426.1).
  4. Total coliform MCL (**Notify Department within 24 hours of MCL violation**):
    - a. For systems collecting less than 40 samples, if two or more samples are total coliform positive, then the MCL is violated.
    - b. For systems collecting 40 or more samples, if more than 5.0 percent of samples collected are total coliform positive, then the MCL is violated.
  5. Positive results and their associated repeat samples must be tracked on the worksheet on the other side.
  6. For systems collecting more than one routine sample per month, three repeat samples must be collected for each total coliform positive sample. Repeat samples must be collected within 24 hours of being notified of the positive results.
  7. For systems collecting one or less routine samples per month, four repeat samples must be collected for each total coliform positive sample.
- CDPH 8477 (10/2007)

Date	PINTAIL WELL SITE			CANVAS WELL SITE			MONTH: Oct-20		
	Meter Read	Flow MGD	Reservoir CL <sub>2</sub> Residual	Meter Read	Flow MGD	Reservoir CL <sub>2</sub> Residual	Mallard CL <sub>2</sub> Residual	Mandarian CL <sub>2</sub> Residual	Total Volume MGD
1	1551.7184	0.3527	1.84	1272.6741	0.1763	0.8	1.55	1.84	0.5290
2	1552.0711	0.2667	1.81	1272.8504	0.1807	0.81	1.44	1.81	0.4474
3	1552.3378	0.3507	1.12	1273.0311	0.0000	0.7	1.31	1.12	0.3507
4	1552.6885	0.3439	1.53	1273.0311	0.0000	0.71	1.47	1.53	0.3439
5	1553.0324	0.2779	1.56	1273.0311	0.0000	0.76	1.48	1.56	0.2779
6	1553.3103	0.3392	1.54	1273.0311	0.0000	0.77	1.52	1.54	0.3392
7	1553.6495	0.3331	1.47	1273.0311	0.0000	0.88	1.39	1.47	0.3331
8	1553.9826	0.2586	1.36	1273.0311	0.0000	0.73	1.46	1.36	0.2586
9	1554.2412	0.2468	1.47	1273.0311	0.0000	0.74	1.6	1.47	0.2468
10	1554.488	0.3268	1.44	1273.0311	0.0000	0.7	1.46	1.44	0.3268
11	1554.8148	0.2683	1.41	1273.0311	0.0000	0.74	1.32	1.41	0.2683
12	1555.0831	0.3136	1.43	1273.0311	0.0000	0.68	1.33	1.43	0.3136
13	1555.3967	0.3387	1.42	1273.0311	0.0000	0.68	1.32	1.42	0.3387
14	1555.7354	0.2718	1.45	1273.0311	0.0000	0.98	1.33	1.45	0.2718
15	1556.0072	0.391	1.42	1273.0311	0.1131	0.99	1.39	1.42	0.5041
16	1556.3982	0.3817	1.45	1273.1442	0.1586	0.98	1.41	1.45	0.5403
17	1556.7799	0.2931	1.42	1273.3028	0.0000	0.94	1.45	1.4	0.2931
18	1557.073	0.3515	1.46	1273.3028	0.0000	0.9	1.44	1.46	0.3515
19	1557.4245	0.2645	1.36	1273.3028	0.0000	0.74	1.38	1.36	0.2645
20	1557.689	0.3416	1.38	1273.3028	0.0000	0.94	1.23	1.38	0.3416
21	1558.0306	0.2987	1.39	1273.3028	0.0000	0.93	1.35	1.39	0.2987
22	1558.3293	0.298	1.33	1273.3028	0.0000	0.89	1.37	1.33	0.2980
23	1558.6273	0.3726	1.38	1273.3028	0.0000	0.84	1.24	1.38	0.3726
24	1558.9999	0.3298	1.57	1273.3028	0.0000	0.75	1.28	1.57	0.3298
25	1559.3297	0.2535	1.48	1273.3028	0.0000	0.93	1.30	1.48	0.2535
26	1559.5832	0.3094	1.63	1273.3028	0.0000	0.84	1.55	1.63	0.3094
27	1559.8926	0.2921	1.56	1273.3028	0.0000	0.93	1.57	1.56	0.2921
28	1560.1847	0.3173	1.55	1273.3028	0.0000	0.72	1.64	1.55	0.3173
29	1560.502	0.2608	1.46	1273.3028	0.0000	0.86	1.54	1.46	0.2608
30	1560.7628	0.5635	1.21	1273.3028	0.0000	0.85	1.88	1.21	0.5635
31	1561.0003	0.326	1.68	1273.3028	0.0000	0.81	1.86	1.68	0.3260
1	1561.3263								

Max	0.5635
Min	0.2468
Avg	0.3204
Total	9.6079

Max	0.1807
Min	0.0000
Avg	0.0203
Total	0.6287

Max	0.5635
Min	0.2468
Avg	0.3407
Total	10.2366

\* No chlorine residuals taken.



# CALIFORNIA LABORATORY SERVICES

*Committed. Responsive. Flexible.*

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 20J0610 COC #: 208474
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Mandarine #1 (20J0610-01) Wastewater    Sampled: 10/09/20 07:45    Received: 10/09/20 12:05</b>									
E. Coli	Absent	0.0	N/A	1	2008295	10/09/20	10/10/20	SM 9223	
Total Coliforms	Absent	0.0	"	"	"	"	"	"	



# CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 20J1219 COC #: 208490
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Mallard #2 (20J1219-01) Water    Sampled: 10/21/20 08:00    Received: 10/21/20 12:20</b>									
E. Coli	Absent	0.0	N/A	1	2008624	10/21/20	10/22/20	SM 9223	
Residual Chlorine	1.35	0.10	mg/L	"	"	10/21/20	10/21/20	SM 4500-CL-G	FT-C
Total Coliforms	Absent	0.0	N/A	"	"	10/21/20	10/22/20	SM 9223	