

Electronic Report Transmittal Form

Attention: Brendan Kenny (916) 464-4635
Central Valley Regional Water Quality Control Board
11020 Sun Center Drive #200
Rancho Cordova, CA 95670-6114

Discharger: Wild Wings County Service Area
Name of Facility: Wild Wings Water Recycling Facility
WDRs Order Number: R5-2002-0077
CIWQS Place ID: 272537
County: Yolo

I am hereby submitting to the Central Valley Water Board the following information:

Check all that apply:

Technical Report Title and Date Self-Monitoring Report for Wild Wings

Monthly Monitoring Report for the month of June 2020

1st / 2nd / 3rd / 4th (**circle one**) Quarterly Monitoring Report for the year of _____

1st / 2nd (**circle one**) Semi-annual Monitoring Report for the year _____

Annual Monitoring Report for the year _____

Violation Notification:

During the monitoring period, there (**were**), were not (circle one) any violations of the WDRs.
/ (were not)

1. The violations were Maximum Daily Total Coliform (twice)
2. Have the violations been corrected? (**Yes**) / No. If no, what will be done to correct the violations? Sampling pump and piping have been changed out to avoid contamination.

Certification Statement:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for knowingly submitting false information, including the possibility of fine and imprisonment."

Signature:  Phone: 707-330-4402

Printed Name: Michael Lane Date: 7-27-2020

WILD WINGS WASTE TREATMENT FACILITY
Monitoring and Reporting Program No. RS 2002-0077

Month of **June** **2020**

Date	INFLUENT						SECONDARY EFFLUENT		
	DAILY	WEEKLY		MONTHLY			MONTHLY		
	DAILY MGD	pH S.U.	E.C. umhos/cm	BOD mg/L	TSS mg/L	TDS mg/L	BOD mg/L	TSS mg/L	pH S.U.
1	0.063229								
2	0.057170								
3	0.059482								
4	0.057543	7.15	1700	260	200	870	ND	ND	7.48
5	0.057929								
6	0.057929								
7	0.069116								
8	0.056611								
9	0.055546								
10	0.053430	7.23	1700						
11	0.056461								
12	0.053504								
13	0.053328								
14	0.054239								
15	0.050034								
16	0.053952	7.37	1800						
17	0.052227								
18	0.056006								
19	0.056691								
20	0.054213								
21	0.059239								
22	0.057248								
23	0.050385	7.37	1400						
24	0.057962								
25	0.052453								
26	0.057997								
27	0.055333								
28	0.057355								
29	0.062536								
30	0.062135	7.56	1600						
31									
TOTAL	1.7013	MG							
AVG.	0.0565	MGD							
Max	0.0691	MGD							

**WILD WINGS WASTE TREATMENT FACILITY
TERTIARY INFLUENT MONITORING**

Month of **June** **2020**

TERTIARY EFFLUENT MONITORING															
Date	DAILY					WEEKLY			MONTHLY						
	EFFL. MGD	Clar. Turb. NTU	Eff. Turb. NTU	Cl ₂ Resid. Mg/L	Coloform MPN	pH S.U.	BOD mg/L	TSS mg/L	E.C.	TDS mg/L	TKN	NITRATE as N2	TOTAL NITROGEN	AMMONIA as N	
1	0.066012	1.480	0.403	20.0	1.8										
2	0.063144	1.418	0.286	16.8	1.8										
3	0.077040	0.960	0.322	20.0	1.8										
4	0.061492	1.432	0.328	20.0	1.8	7.93	ND	ND	1500	970	0.37	39	40	ND	
5	0.064268	1.699	0.307	20.0	1.8										
6	0.068072	1.744	0.359	20.0	1.8										
7	0.070064	2.482	0.340	20.0	1.8										
8	0.062210	1.747	0.487	20.0	1.8										
9	0.062486	3.050	0.363	20.0	1.8										
10	0.063656	1.144	0.471	20.0	1.8	7.87	5.8	ND	1700						
11	0.058792	1.413	0.599	20.0	1.8										
12	0.048192	1.293	0.375	20.0	2.0										
13	0.058976	1.258	0.550	13.0	1.8										
14	0.059448	1.355	0.442	20.0	1.8										
15	0.056464	1.133	0.501	20.0	1.8										
16	0.055120	1.481	0.578	20.0	1.8	8.07	11	ND	1700						
17	0.060504	1.411	1.074	20.0	1.8										
18	0.057752	1.790	0.482	20.0	1.8										
19	0.060848	0.388	0.601	17.1	2.0										
20	0.058216	1.423	0.838	8.8	1.8										
21	0.067160	1.640	0.910	20.0	4.5										
22	0.060144	1.760	0.943	20.0	1.8										
23	0.058312	2.125	0.842	13.6	1.8	7.72	6.5	ND	1500						
24	0.059416	2.744	1.051	20.0	1.8										
25	0.055536	1.985	1.000	11.4	2.0										
26	0.053888	2.310	0.988	14.5	1.8										
27	0.061800	1.766	0.995	19.5	1.8										
28	0.061744	2.094	0.747	10.7	70.0										
29	0.072944	1.669	1.015	20.0	12.0										
30	0.068688	2.920	0.957	6.2	33.0	7.75	3	ND	1600						
31	0.000000														
TOT.	1.8524	MG		Median	1.8										
AVG.	0.0595	MGD													
Max	0.0770	MGD													

Recycle
Monitoring and Reporting Program No. RS 2002-0077

Month of **June** **2020**

WILD WINGS WASTE TREATMENT FACILITY
RECYCLED WATER MONITORING

DATE	RECYCLED WATER STORAGE POND MONITORING								RECYCLED WATER AREA MONITORING						
	WEEKLY			MONTHLY					WEEKLY	DAILY			MONTHLY		
	Freeboard Ft.	D.O. mg/L	pH S.U.	E.C. u mhos/cm	TDS mg/L	Nitrate/N mg/L	Kjeldahl N mg/L	Total N mg/L	FLOW GPD	RAIN Inches	Acreage Applied	App.Rate gal/ac/day	App. Per. Hours	Total N2 pounds	TDS Pounds
1	10.50								291805		68	4291			
2	10.50								291805		68	4291			
3	10.40								286504		68	4213			
4	9.70	19.1	9.24	910.1	510	5.4	0.63	6	338772		68	4982		16.95	1441
5	8.80								286504		68	4213			
6	8.70														
7	32.00								272068		68	4001			
8	8.50								338772		68	4982			
9	8.50	20+	9.13	912											
10	8.50								332553		68	4890			
11	8.40								332553		68	4890			
12	7.20								334706		68	4922			
13	7.70								320270		68	4710			
14	8.50								51518		3	17173			
15	9.00								386974		68	5691			
16	9.50	19.92	9.17	920.1					386974		68	5691			
17	9.90								334706		68	4922			
18	9.90								389154		68	5723			
19	7.40								336885		68	4954			
20	8.20								105965		68	1558			
21	8.60								322449		68	4742			
22	9.10								389153		68	5723			
23	9.60	19.83	9.23	929.4					389153		68	5723			
24	9.60								336885		68	4954			
25	8.10								389153		68	5723			
26	8.50								68133		8	8517			
27	9.00								374717		68	5511			
28	9.50								53697		3	17899			
29	9.50								389153		68	5723			
30	9.10	20+	9.51	930					389153		68	5723			
31															
TOTALS									8,520,134	0.00				17	1,441
MG									8.52						

