

## Electronic Report Transmittal Form

Attention: Brendan Kenny (916) 464-4635  
Central Valley Regional Water Quality Control Board  
11020 Sun Center Drive #200  
Rancho Cordova, CA 95670-6114

Discharger: Wild Wings County Service Area  
Name of Facility: Wild Wings Water Recycling Facility  
WDRs Order Number: R5-2002-0077  
CIWQS Place ID: 272537  
County: Yolo

I am hereby submitting to the Central Valley Water Board the following information:

### **Check all that apply:**

Technical Report Title and Date Self-Monitoring Report for Wild Wings

Monthly Monitoring Report for the month of July 2020

1st / 2nd / 3rd / 4th (**circle one**) Quarterly Monitoring Report for the year of \_\_\_\_\_

1st / 2nd (**circle one**) Semi-annual Monitoring Report for the year \_\_\_\_\_

Annual Monitoring Report for the year \_\_\_\_\_

### **Violation Notification:**

During the monitoring period, there (**were**), were not (circle one) any violations of the WDRs.  
/ (were not)

1. The violations were Maximum Daily Total Coliform
2. Have the violations been corrected? (**Yes**) / No. If no, what will be done to correct the violations? Sampling pump and piping have been changed out to avoid contamination.

### **Certification Statement:**

*"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for knowingly submitting false information, including the possibility of fine and imprisonment."*

Signature:  Phone: 707-330-4402

Printed Name: Michael Lane Date 8-27-2020

**WILD WINGS WASTE TREATMENT FACILITY**  
**Monitoring and Reporting Program No. RS 2002-0077**

Month of **JULY**      **2020**

Date	INFLUENT						SECONDARY EFFLUENT		
	DAILY	WEEKLY		MONTHLY			MONTHLY		
	DAILY MGD	pH S.U.	E.C. umhos/cm	BOD mg/L	TSS mg/L	TDS mg/L	BOD mg/L	TSS mg/L	pH S.U.
1	0.063858								
2	0.055093								
3	0.058945								
4	0.061742								
5	0.056570								
6	0.057515								
7	0.055140	7.28	1600	250	310	880	5.8	6.3	7.54
8	0.055402								
9	0.056760								
10	0.053283								
11	0.055219								
12	0.057630								
13	0.057926								
14	0.058045	7.53	1700						
15	0.054314								
16	0.055219								
17	0.057591								
18	0.059980								
19	0.059617								
20	0.056757								
21	0.059669	7.63	1800						
22	0.060356								
23	0.065415								
24	0.061924								
25	0.059735								
26	0.060299								
27	0.069944								
28	0.058361								
29	0.063721								
30	0.065250	7.76	1800						
31	0.071832								
<b>TOTAL</b>	<b>1.8431</b>	MG							
<b>AVG.</b>	<b>0.0593</b>	MGD							
<b>Max</b>	<b>0.0718</b>	MGD							





