



January 9, 2020

State Water Resources Control Board
Division of Drinking Water
Austin Peterson, P.E., Associate Sanitary Engineer
1001 I St, 13th Floor
Sacramento, CA 95834

Regarding: CA5710011-Wild Wings-4th Q 2019-MRDL

Mr. Peterson

Specialized Utilities Services Program, Inc., on behalf of the Wild Wings C.S.A. has prepared and is submitting to the Division of Drinking Water, the CA 5710011-Wild Wings-4th Q-MRDL

Enclosed are the 4th Quarter Report for Disinfectant Residuals Compliance and analytical results.

Please contact me if you have any questions.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Dan DeMoss", is written over a light blue horizontal line.

Dan DeMoss.
Operator
Phone: (916) 616-7761
Email: ddemoss@calruralwater.org

Quarterly report for Disinfectant Residuals Compliance
For Systems Using Chlorine or Chloramines

System Name: Wild Wings
Calendar Year: 2019

System No : 5710011
Date: January 9, 2020

1st Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Previous Year	April	1.0
	May	1.1
	June	0.9
	July	1.0
	August	1.0
	September	1.1
	October	1.0
	November	1.0
	December	1.0
	Current Year	January
February		2
March		2
Running Annual Average (RAA):		1.1
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/l as cl ₂)		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

2nd Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Previous Year	July	1.0
	August	1.0
	September	1.1
	October	1.0
	November	1.0
	December	1.0
	Current Year	January
February		2
March		2
April		2
May		2
June		2
Running Annual Average (RAA):		1.085
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/l as cl ₂)		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No


3rd Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Previous Year	October	1.0
	November	1.0
	December	1.0
Current Year	January	1.2
	February	1.55
	March	0.86
	April	0.95
	May	0.92
	June	1.03
	July	2
	August	2
	September	2
	Running Annual Average (RAA):	
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/l as cl ₂)		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

4th Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Current Year	January	1.2
	February	1.55
	March	0.86
	April	0.95
	May	0.92
	June	1.03
	July	1.12
	August	1.35
	September	1.61
	October	2
	November	2
	December	2
Running Annual Average (RAA):		
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/l as cl ₂)		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Comments:

Signature: 


Date: 1/9/2020



California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 19L0894 COC #: 204367
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mallard #2 (19L0894-01) Water Sampled: 12/16/19 08:05 Received: 12/16/19 12:00									
Residual Chlorine	0.67	0.10	mg/L	1	1910558	12/16/19 08:05	12/16/19	SM 4500-CL-G	FT-C
Total Coliforms	Absent	0.0	N/A	"	"	12/16/19 12:15	12/17/19	SM 9223	
E. Coli	Absent	0.0	"	"	"	"	"	"	



California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 19L0121 COC #: 202693
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mandarin # 1 (19L0121-01) Wastewater Sampled: 12/03/19 07:30 Received: 12/03/19 12:20									
Residual Chlorine	1.94	0.10	mg/L	1	1910147	12/03/19 07:30	12/03/19 SM 4500-CL-G		FT-C
Total Coliforms	Absent	0.0	N/A	"	"	12/03/19 13:00	12/04/19 SM 9223		
E. Coli	Absent	0.0	"	"	"	"	"	"	