



January 20, 2021

State Water Resources Control Board  
Division of Drinking Water  
Austin Peterson, P.E., Associate Sanitary Engineer  
1001 I St, 13<sup>th</sup> Floor  
Sacramento, CA 95834

**Regarding: CA5710011-Wild Wings-4<sup>th</sup> Q 2020-MRDL**

Mr. Peterson

Specialized Utilities Services Program, Inc., on behalf of the Wild Wings C.S.A. has prepared and is submitting to the Division of Drinking Water, the CA 5710011-Wild Wings-4th Q-MRDL

Enclosed are the 4th Quarter Report for Disinfectant Residuals Compliance and analytical results.

Please contact me if you have any questions.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Dan DeMoss", is written over a horizontal line.

Dan DeMoss.  
Operator  
Phone: (916) 616-7761  
Email: [ddemoss@calruralwater.org](mailto:ddemoss@calruralwater.org)

Quarterly report for Disinfectant Residuals Compliance  
For Systems Using Chlorine or Chloramines

System Name: Wild Wings  
Calendar Year: 2020

System No : 5710011  
Date: January 20, 2021

1st Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Previous Year	April	0.95
	May	0.92
	June	1.03
	July	1.12
	August	1.35
	September	1.61
	October	1.54
	November	1.75
	December	1.3
	Current Year	January
February		2
March		2
Running Annual Average (RAA):		1.3
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/l as cl <sub>2</sub> )		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

2nd Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Previous Year	July	1.12
	August	1.35
	September	1.61
	October	1.54
	November	1.75
	December	1.3
Current Year	January	2
	February	2
	March	2
	April	2
	May	2
	June	2
Running Annual Average (RAA):		1.31
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/l as cl <sub>2</sub> )		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

3rd Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Previous Year	October	1.54
	November	1.75
	December	1.3
Current Year	January	0.78
	February	1.28
	March	1.45
	April	1.63
	May	1.37
	June	1.36
	July	2
	August	2
	September	2
	Running Annual Average (RAA):	
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/l as cl <sub>2</sub> )		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

4th Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Current Year	January	0.78
	February	1.28
	March	1.45
	April	1.63
	May	1.37
	June	1.36
	July	1.45
	August	1.16
	September	1.35
	October	2
	November	2
	December	2
Running Annual Average (RAA):		
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/l as cl <sub>2</sub> )		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Comments:

Signature: 

Date: 1-21-2021



**CALIFORNIA LABORATORY SERVICES**  
*Committed. Responsive. Flexible.*

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 20L0419 COC #: 211196
--	--	--

**Microbiological Parameters by APHA Standard Methods**

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Main Drain #1 (20L0419-01) Water</b> <b>Sampled: 12/08/20 08:00</b> <b>Received: 12/08/20 11:35</b>									
E. Coli	Absent	0.0	N/A	1	2009995	12/08/20	12/09/20	SM 9223	
Residual Chlorine	1.80	0.10	mg/L	"	"	12/08/20	12/08/20	SM 4500-CL-G	FT-C
Total Coliforms	Absent	0.0	N/A	"	"	12/08/20	12/09/20	SM 9223	



# CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 20L0881 COC #: 209807
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Mallard #2 (20L0881-01) Water</b> <b>Sampled: 12/16/20 07:45</b> <b>Received: 12/16/20 12:10</b>									
E. Coli	Absent	0.0	N/A	1	2010277	12/16/20	12/17/20	SM 9223	
Residual Chlorine	1.72	0.10	mg/L	"	"	12/16/20	12/16/20	SM 4500-CL-G	FT-C
Total Coliforms	Absent	0.0	N/A	"	"	12/16/20	12/17/20	SM 9223	



**CALIFORNIA LABORATORY SERVICES**  
*Committed. Responsive. Flexible.*

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 20K0389 COC #: 211159
--	--	--

**Microbiological Parameters by APHA Standard Methods**

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Mandarin # 1 (20K0389-01) Water</b> <b>Sampled: 11/06/20 08:15</b> <b>Received: 11/06/20 12:50</b>									
E. Coli	Absent	0.0	N/A	1	2009119	11/06/20	11/07/20	SM 9223	
Residual Chlorine	1.34	0.10	mg/L	"	"	11/06/20	11/06/20	SM 4500-CL-G	FT-C
Total Coliforms	Absent	0.0	N/A	"	"	11/06/20	11/07/20	SM 9223	



**CALIFORNIA LABORATORY SERVICES**  
*Committed. Responsive. Flexible.*

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 20K0917 COC #: 211171
--	--	--

**Microbiological Parameters by APHA Standard Methods**

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Mallard # 2 (20K0917-01) Water</b> <b>Sampled: 11/17/20 07:55</b> <b>Received: 11/17/20 13:05</b>									
E. Coli	Absent	0.0	N/A	1	2009417	11/17/20	11/18/20	SM 9223	
Residual Chlorine	1.30	0.10	mg/L	"	"	11/17/20	11/17/20	SM 4500-CL-G	FT-C
Total Coliforms	Absent	0.0	N/A	"	"	11/17/20	11/18/20	SM 9223	



**CALIFORNIA LABORATORY SERVICES**  
*Committed. Responsive. Flexible.*

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 20J0610 COC #: 208474
--	--	--

**Microbiological Parameters by APHA Standard Methods**

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Mandarin #1 (20J0610-01) Wastewater</b> <b>Sampled: 10/09/20 07:45</b> <b>Received: 10/09/20 12:05</b>									
E. Coli	Absent	0.0	N/A	1	2008295	10/09/20	10/10/20	SM 9223	
Total Coliforms	Absent	0.0	"	"	"	"	"	"	



**CALIFORNIA LABORATORY SERVICES**  
*Committed. Responsive. Flexible.*

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 20J1219 COC #: 208490
--	--	--

**Microbiological Parameters by APHA Standard Methods**

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Mallard #2 (20J1219-01) Water</b> <b>Sampled: 10/21/20 08:00</b> <b>Received: 10/21/20 12:20</b>									
E. Coli	Absent	0.0	N/A	1	2008624	10/21/20	10/22/20	SM 9223	
Residual Chlorine	1.35	0.10	mg/L	"	"	10/21/20	10/21/20	SM 4500-CL-G	FT-C
Total Coliforms	Absent	0.0	N/A	"	"	10/21/20	10/22/20	SM 9223	