



March 30, 2021

State Water Resources Control Board  
Division of Drinking Water  
Austin Peterson, P.E., Associate Sanitary Engineer  
1001 I St, 13<sup>th</sup> Floor  
Sacramento, CA 95834

**Regarding: CA57100011-Wild Wings-1Q2021-TCR**

Mr. Peterson

Specialized Utilities Services Program, Inc., on behalf of the Wild Wings C.S.A. has prepared and is submitting to the Division of Drinking Water, the CA 57100011-Wild Wings-1Q-TCR


Enclosed are the 1<sup>st</sup> Quarter Report for Total Coliform analytical results.

Please contact me if you have any questions.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Dan DeMoss". The signature is fluid and cursive, written over a white background.

Dan DeMoss.  
Operator  
Phone: (916) 616-7761  
Email: [ddemoss@calruralwater.org](mailto:ddemoss@calruralwater.org)



# CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 21B0994 COC #: 210215
--	--	--

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Canvas Backwell (21B0994-01) Water    Sampled: 02/17/21 07:35    Received: 02/17/21 11:55</b>									
E. Coli	Absent	0.0	N/A	1	2101394	02/17/21	02/18/21	SM 9223	
Total Coliforms	Absent	0.0	"	"	"	"	"	"	
<b>Pintail Well (21B0994-02) Water    Sampled: 02/17/21 07:55    Received: 02/17/21 11:55</b>									
E. Coli	Absent	0.0	N/A	1	2101394	02/17/21	02/18/21	SM 9223	
Total Coliforms	Absent	0.0	"	"	"	"	"	"	