



July 8, 2020

State Water Resources Control Board
Division of Drinking Water
Austin Peterson, P.E., Associate Sanitary Engineer
1001 I St, 13th Floor
Sacramento, CA 95834

Regarding: CA57100011-Wild Wings-2ndQ2020-TCR

Mr. Peterson

Specialized Utilities Services Program, Inc., on behalf of the Wild Wings C.S.A. has prepared and is submitting to the Division of Drinking Water, the CA 57100011-Wild Wings-2nd-TCR


Enclosed are the 2nd Quarter Report for Total Coliform analytical results.

Please contact me if you have any questions.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Dan DeMoss". The signature is fluid and cursive, written over a white background.

Dan DeMoss.
Operator
Phone: (916) 616-7761
Email: ddemoss@calruralwater.org




CALIFORNIA LABORATORY SERVICES
Committed. Responsive. Flexible.

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 20E0275 COC #: 205705
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Pintail Well (20E0275-01) Water Sampled: 05/06/20 07:30 Received: 05/06/20 12:10									
E. Coli	Absent	0.0	N/A	1	2003611	05/06/20	05/07/20	SM 9223	
Total Coliforms	Absent	0.0	"	"	"	"	"	"	



CALIFORNIA LABORATORY SERVICES
Committed. Responsive. Flexible.

Page 4 of 8

05/13/20 09:34

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 20E0175 COC #: 205713
--	--	--

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Canvas Back Well (20E0175-01) Water Sampled: 05/05/20 07:40 Received: 05/05/20 13:20									
E. Coli	Absent	0.0	N/A	1	2003572	05/05/20	05/06/20	SM 9223	
Total Coliforms	Absent	0.0	"	"	"	"	"	"	