



February 25, 2020

State Water Resources Control Board  
Division of Drinking Water  
Austin Peterson, P.E., Associate Sanitary Engineer  
1001 I St, 13<sup>th</sup> Floor  
Sacramento, CA 95834

**Regarding: CA5710011-Wild Wings-1stQ2020-Arsenic**

Mr. Peterson

Specialized Utilities Services Program, Inc., on behalf of the Wild Wings C.S.A. has prepared and is submitting to the Division of Drinking Water, the CA 5710011-Wild Wings-1stQ-Arsenic

Enclosed are the 1st Quarter Report for Arsenic Compliance and analytical results.

Please contact me if you have any questions.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Dan DeMoss". The signature is fluid and cursive, with a large initial "D" and "M".

Dan DeMoss.  
Operator  
Phone: (916) 616-7761  
Email: [ddemoss@calruralwater.org](mailto:ddemoss@calruralwater.org)



# CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.

California Rural Water Association  
1234 N. Market Blvd.  
Sacramento, CA 95834

Project: Wild Wings  
Project Number: [none]  
Project Manager: Dan Demoss

CLS Work Order #: 20B0374  
COC #: 204402

## Metals (Drinking Water) by EPA 200 Series Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>Canvas Back Well (20B0374-01) Water</b> Sampled: 02/07/20 07:45 Received: 02/07/20 12:15									
Arsenic	10	2.0	µg/L	1	2001097	02/10/20	02/10/20	EPA 200.8	
<b>Pintail Well (20B0374-02) Water</b> Sampled: 02/07/20 08:15 Received: 02/07/20 12:15									
Arsenic	6.6	2.0	µg/L	1	2001097	02/10/20	02/11/20	EPA 200.8	