



July 8, 2020

State Water Resources Control Board
Division of Drinking Water
Austin Peterson, P.E., Associate Sanitary Engineer
1001 I St, 13th Floor
Sacramento, CA 95834

Regarding: CA5710011-Wild Wings-2ndQ2020-Arsenic

Mr. Peterson

Specialized Utilities Services Program, Inc., on behalf of the Wild Wings C.S.A. has prepared and is submitting to the Division of Drinking Water, the CA 5710011-Wild Wings-2ndQ-Arsenic


Enclosed are the 2nd Quarter Report for Arsenic Compliance and analytical results.

Please contact me if you have any questions.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Dan DeMoss", is written over a light blue horizontal line.

Dan DeMoss.
Operator
Phone: (916) 616-7761
Email: ddemoss@calruralwater.org




CALIFORNIA LABORATORY SERVICES
Committed. Responsive. Flexible.

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 20E0275 COC #: 205705
--	--	--

Metals (Drinking Water) by EPA 200 Series Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Pintail Well (20E0275-01) Water Sampled: 05/06/20 07:30 Received: 05/06/20 12:10									
Arsenic	7.1	2.0	µg/L	1	2003610	05/07/20	05/07/20	EPA 200.8	
Manganese	17	10	"	"	2003613	05/07/20	05/07/20	EPA 200.7	



CALIFORNIA LABORATORY SERVICES
Committed. Responsive. Flexible.

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 20E0175 COC #: 205713
--	--	--

Metals by EPA 200 Series Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Canvas Back Well (20E0175-01) Water Sampled: 05/05/20 07:40 Received: 05/05/20 13:20									
Arsenic	9.8	2.0	µg/L	1	2003562	05/06/20	05/06/20	EPA 200.8	
Manganese	43	10	"	"	2003588	05/06/20	05/11/20	EPA 200.7	
Sodium	110	1.0	mg/L	"	"	"	05/06/20	"	