



July 21, 2021

State Water Resources Control Board
Division of Drinking Water
Austin Peterson, P.E., Associate Sanitary Engineer
1001 I St, 13th Floor
Sacramento, CA 95834

Regarding: CA57100011-Wild Wings-2ndQ2021-MRDL

Mr. Peterson

Specialized Utilities Services Program, Inc., on behalf of the Wild Wings C.S.A. has prepared and is submitting to the Division of Drinking Water, the CA 57100011-Wild Wings-2ndQ-MRDL-2021

Enclosed are the 2ndQuarter Report for Disinfectant Residuals Compliance and analytical results.

Please contact me if you have any questions.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Dan DeMoss". The signature is written in a cursive style with a large initial "D".

Dan DeMoss.
Operator
Phone: (916) 616-7761
Email: ddemoss@calruralwater.org

Quarterly report for Disinfectant Residuals Compliance
For Systems Using Chlorine or Chloramines

System Name: Wild Wings

System No : 5710011

Calendar Year: 2021

Date: July 21, 2021

1st Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Previous Year	April	1.63
	May	1.37
	June	1.36
	July	1.45
	August	1.16
	September	1.35
	October	1.37
	November	1.32
	December	1.77
	Current Year	January
February		2
March		2
Running Annual Average (RAA):		1.43
Meets standard? (i.e. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No)		RAA ≤ MRDL of 4.0 mg/l as cl ₂

2nd Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Previous Year	July	1.45
	August	1.16
	September	1.35
	October	1.37
	November	1.32
	December	1.77
	Current Year	January
February		2
March		2
April		2
May		2
June		2
Running Annual Average (RAA):		1.43
Meets standard? (i.e. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No)		RAA ≤ MRDL of 4.0 mg/l as cl ₂


3rd Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Previous Year	October	
	November	
	December	
Current Year	January	
	February	
	March	
	April	
	May	
	June	
	July	
	August	
	September	
Running Annual Average (RAA):		
Meets standard? (i.e. <input type="checkbox"/> Yes <input type="checkbox"/> No)		RAA ≤ MRDL of 4.0 mg/l as cl ₂

4th Quarter		
Month	Number of Samples Taken	Monthly Avg. chlorine Level (mg/l)
Current Year	January	
	February	
	March	
	April	
	May	
	June	
	July	
	August	
	September	
	October	
	November	
	December	
Running Annual Average (RAA):		
Meets standard? (i.e. <input type="checkbox"/> Yes <input type="checkbox"/> No)		RAA ≤ MRDL of 4.0 mg/l as cl ₂

Comments:

Signature: 

Date: 7/21/2021



CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.

Page 2 of 3

California Rural Water Association
1234 N. Market Blvd.
Sacramento, CA 95834


Project: Wild Wings
Project Number: [none]
Project Manager: Dan Demoss

04/29/21 12:24

CLS Work Order #: 21D1254
COC #: 213166

Microbiological Parameters by APHA Standard Methods

Analytic	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mallard #2 (21D1254-01) DW Sampled: 04/22/21 07:45 Received: 04/22/21 12:10									
E. Coli	Absent	0.0	N/A	1	2103328	04/22/21	04/23/21	SM 9223	
Residual Chlorine	1.40	0.10	mg/L	"	"	04/22/21	04/22/21	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N/A	"	"	04/22/21	04/23/21	SM 9223	FT-C



CALIFORNIA LABORATORY SERVICES
Committed. Responsive. Flexible.

Page 2 of 3

California Rural Water Association
1234 N. Market Blvd.
Sacramento, CA 95834


Project: Wild Wings
Project Number: [none]
Project Manager: Dan Demoss

04/13/21 13:09

CLS Work Order #: 21D0240
COC #: 212541

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mandarin #1 (21D0240-01) DW Sampled: 04/06/21 07:30 Received: 04/06/21 13:30									
E. Coli	Absent	0.0	N/A	1	2102803	04/06/21	04/07/21	SM 9223	
Residual Chlorine	2.12	0.10	mg/L	"	"	04/06/21	04/06/21	SM 4500-CL-G	FT-C
Total Coliforms	Absent	0.0	N/A	"	"	04/06/21	04/07/21	SM 9223	



CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.


Page 2 of 3

05/25/21 10:01

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 21E.0973 COC #: 213193
--	--	---

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mallard # 2 (21E.0973-01) Water Sampled: 05/18/21 07:15 Received: 05/18/21 12:45									
E. Coli	Absent	0.0	N A	1	2104096	05 18 21	05 19 21	SM 9223	
Residual Chlorine	1.40	0.10	mg/L	"	"	05 18 21	05 18 21	SM 4500-CL-G	FT-C
Total Coliforms	Absent	0.0	N A	"	"	05 18 21	05 19 21	SM 9223	



CALIFORNIA LABORATORY SERVICES
Committed. Responsive. Flexible.

Page 2 of 3

05/25/21 11:27


California Rural Water Association
1234 N. Market Blvd.
Sacramento, CA 95834

Project: Wild Wings
Project Number: [none]
Project Manager: Dan Demoss

CLS Work Order #: 21E0350
COC #: 213178

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mandarin #1 (21E0350-01) DW Sampled: 05/06/21 07:45 Received: 05/06/21 11:55									
E. Coli	Absent	0.0	N.A	1	2103782	05 06 21	05 07 21	SM 9223	
Residual Chlorine	1.20	0.10	mg/L	"	"	05 06 21	05 06 21	SM 4500-CL-G	
Total Coliforms	Absent	0.0	N.A	"	"	05 06 21	05 07 21	SM 9223	FT-C



CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.

Page 2 of 3

06/18/21 14:09


California Rural Water Association
1234 N. Market Blvd.
Sacramento, CA 95834

Project: Wild Wings
Project Number: [none]
Project Manager: Dan Demoss

CLS Work Order #: 21F0745
COC #: 213917

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mandarin #1 (21F0745-01) DW Sampled: 06/11/21 07:30 Received: 06/11/21 14:00									
E. Coli	Absent	0.0	N/A	1	2104816	06/11/21	06/12/21	SM 9223	
Residual Chlorine	1.00	0.10	mg/L	"	"	06/11/21	06/11/21	SM 4500-CL-G	FT-C
Total Coliforms	Absent	0.0	N/A	"	"	06/11/21	06/12/21	SM 9223	



CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.

Page 2 of 3

06/28/21 15:02

California Rural Water Association
1234 N. Market Blvd.
Sacramento, CA 95834

Project: Wild Wings
Project Number: [none]
Project Manager: Dan Demoss

CLS Work Order #: 21F1115
COC #: 213929

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Mallard # 2 (21F1115-01) Water Sampled: 06/21/21 07:30 Received: 06/21/21 12:15									
E. Coli	Absent	0.0	N/A	1	2105071	06/21/21	06/22/21	SM 9223	
Residual Chlorine	1.55	0.10	mg/L	"	"	06/21/21	06/21/21	SM 4500-CL-G	FT-C
Total Coliforms	Absent	0.0	N/A	"	"	06/21/21	06/22/21	SM 9223	