



July 21, 2021

State Water Resources Control Board
Division of Drinking Water
Austin Peterson, P.E., Associate Sanitary Engineer
1001 I St, 13th Floor
Sacramento, CA 95834

Regarding: CA57100011-Wild Wings-2ndQ2021-TCR

Mr. Peterson

Specialized Utilities Services Program, Inc., on behalf of the Wild Wings C.S.A. has prepared and is submitting to the Division of Drinking Water, the CA 57100011-Wild Wings-2nd-TCR


Enclosed are the 2nd Quarter Report for Total Coliform analytical results.

Please contact me if you have any questions.

Sincerely yours,

A handwritten signature in black ink that reads "Dan DeMoss". The signature is written in a cursive style with a large, looping initial "D".

Dan DeMoss.
Operator
Phone: (916) 616-7761
Email: ddemoss@calruralwater.org



CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.

Page 3 of 5

05/20/21 13:42


California Rural Water Association
1234 N. Market Blvd.
Sacramento, CA 95834

Project: Wild Wings
Project Number: [none]
Project Manager: Dan Demoss

CLS Work Order #: 21E0784
COC #: 213144

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Canvas Backwell (21E0784-01) Water Sampled: 05/13/21 09:15 Received: 05/13/21 13:03									
E. Coli	Absent	0.0	N/A	1	2103961	05/13/21	05/14/21	SM 9223	
Residual Chlorine	ND	0.10	mg/L	"	"	05/13/21	05/13/21	SM 4500-CL-G	FT-C
Total Coliforms	Absent	0.0	N/A	"	"	05/13/21	05/14/21	SM 9223	



CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.

California Rural Water Association
1234 N. Market Blvd.
Sacramento, CA 95834

Project: Wild Wings
Project Number: [none]
Project Manager: Dan Demoss

CLS Work Order #: 21E1066
COC #: 213147

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Pintail Well (21E1066-01) Water Sampled: 05/19/21 07:35 Received: 05/19/21 12:25									
E. Coli	Absent	0.0	N/A	1	2104132	05/19/21	05/20/21	SM 9223	
Residual Chlorine	2.34	0.10	mg/L	"	"	05/19/21	05/19/21	SM 4500-CL-G	FT-C
Total Coliforms	Absent	0.0	N/A	"	"	05/19/21	05/20/21	SM 9223	