



July 21, 2021

State Water Resources Control Board
Division of Drinking Water
Austin Peterson, P.E., Associate Sanitary Engineer
1001 I St, 13th Floor
Sacramento, CA 95834

Regarding: CA5710011-Wild Wings-2ndQ2021-Arsenic

Mr. Peterson

Specialized Utilities Services Program, Inc., on behalf of the Wild Wings C.S.A. has prepared and is submitting to the Division of Drinking Water, the CA 5710011-Wild Wings-2ndQ-Arsenic


Enclosed are the 2nd Quarter Report for Arsenic Compliance and analytical results.

Please contact me if you have any questions.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Dan DeMoss". The signature is fluid and cursive, written over a white background.

Dan DeMoss.
Operator
Phone: (916) 616-7761
Email: ddemoss@calruralwater.org




CALIFORNIA LABORATORY SERVICES
Committed. Responsive. Flexible.

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 21E0784 COC #: 213144
--	--	--

Metals by EPA 200 Series Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Canvas Backwell (21E0784-01) Water Sampled: 05/13/21 09:15 Received: 05/13/21 13:03									
Arsenic	7.1	2.0	µg/L	1	2103963	05/14/21	05/20/21	EPA 200.8	



CALIFORNIA LABORATORY SERVICES

Committed. Responsive. Flexible.

California Rural Water Association 1234 N. Market Blvd. Sacramento, CA 95834	Project: Wild Wings Project Number: [none] Project Manager: Dan Demoss	CLS Work Order #: 21E1066 COC #: 213147
--	--	--

Metals (Drinking Water) by EPA 200 Series Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Pintail Well (21E1066-01) Water Sampled: 05/19/21 07:35 Received: 05/19/21 12:25									
Arsenic	9.0	2.0	µg/L	1	2104145	05/20/21	05/24/21	EPA 200.8	