

## 2023 Consumer Confidence Report

*Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Wild Wings Community System a 625 Court St. Room 202 Woodland, CA 95695 or (530) 666-8431 para asistirlo en español.*

### Water System Information

Water System Name: Wild Wings Golf Community CA5710011

Report Date: 2/12/2024

Type of Water Source(s) in Use: Two Ground Water Wells

Name and General Location of Source(s): The Pintail well and the Canvas Back well (standby) are located in the Wild Wings Golf Community service area. During 2023, drinking water was provided from the Pintail Well. Water from the Canvas Back well (standby) was not used. The results in this report reflect the water quality delivered to customers in 2023.

Drinking Water Source Assessment Information: DWSAPs were performed for both the Pintail and Canvas Back Well in 2004. Based on the DWSAP reports and the Source Water Protection Plan completed in 2019, the Wild Wings Golf Community is most susceptible to contamination via fuel spills from an airport located within source water protection areas and from agricultural drainage. A copy of the assessment may be viewed at: Yolo County Administration Office, 625 Court Street, Room 202 Woodland, CA 95695.

Time and Place of Regularly Scheduled Board Meetings for Public Participation: Board meetings are scheduled at 6:30 p.m. on the first Wednesday of every other month at the Nest located at 18544 Wild Wings Dr. Woodland, CA 95695

For More Information, Contact: Kimberly Villa, Community Service Analyst, Phone: (530) 666-8431

### About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2023, and may include earlier monitoring data.

### Terms Used in This Report

Term	Definition
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

Term	Definition
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
ND	Not detectable at testing limit.
N/A	Not applicable
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)
pCi/L	picocuries per liter (a measure of radiation)
µS/cm	Microsiemens per centimeter; a unit of measure for electrical conductivity

## Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally occurring or be the result of oil and gas production and mining activities.

## Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead-Specific Language:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Wild Wings Golf Community is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

**Arsenic-Specific Language:** While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the cost of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

## About Your Drinking Water Quality

### Drinking Water Contaminants Detected

Tables 1, 2, 3, and 4 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, is more than one year old. Any violation of an AL, MCL, or MRDL is asterisked. The Wild Wings Golf Community did not have any drinking water violations in 2023.

**Table 1. Detection of Contaminants with a Primary Drinking Water Standard**

Chemical or Constituent (reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Arsenic (ppb)	2023	7.4	6.8 – 8.3	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Fluoride (ppm)	2022	0.1	ND – 0.17	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Total Trihalomethanes (ppb)	2023	7.8	5.3 – 9.9	80	N/A	Byproduct of drinking water disinfection
Total Haloacetic Acids (ppb)	2023	1.3	ND – 2.4	60	N/A	Byproduct of drinking water disinfection
Chlorine (ppm)	2023	0.93	0.69 – 1.22	[4]	[4]	Drinking water disinfectant added for treatment

**Table 2. Detection of Contaminants with a Secondary Drinking Water Standard**

Chemical or Constituent (reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Turbidity (NTU)	2022	0.15	N/A	5	N/A	Soil runoff
Total Dissolved Solids (ppm)	2023	460	N/A	1,000	N/A	Runoff/leaching from natural deposits
Specific Conductance ( $\mu$ S/cm)	2023	850	N/A	1,600	N/A	Substances that form ions when in water; seawater influence
Chloride (ppm)	2023	38	N/A	500	N/A	Runoff/leaching from natural deposits; seawater influence
Sulfate (ppm)	2023	60	N/A	500	N/A	Runoff/leaching from natural deposits; industrial wastes

**Table 3. Sampling Results for Sodium and Hardness**

Chemical or Constituent (reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2023	170	N/A	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	2023	28	N/A	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**Table 4. Detection of Unregulated Contaminants**

Chemical or Constituent (reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects
Boron (ppm)	2022	2	N/A	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.